[23] Air Conditioning of Multi-Room Buildings, by R. W. Waterfill (A.S.H.A.E. TRANSACTIONS, Vol. 61, 1955, p. 233).

[24] Air Conditioning Multi-Story Buildings, by P. B. Gordon (*Heating Piping and Air Conditioning*, April 1955, p. 112. Discussed loc. cit. May 1955, p. 103).

[25] Standards of the *National Board of Fire Underwriters* (*N.B.F.U.* Pamphlet No. 90, p. 21).

BIBLIOGRAPHY

FLUID FLOW (See Chapter 4)

Elementary Mechanics of Fluids, by Hunter Rouse, 1946. (John Wiley & Sons, Inc.).

Engineering Applications of Fluid Mechanics, by J. C. Hunsaker and B. G. Rightmire, 1947 (McGraw-Hill Book Company, Inc.).

Fluid Flow in Pipes, by Clifford McClain, 1952. (The Industrial Press, New York).

Flow and Fan—Principles of Moving Air Through Ducts, by Harold C. Berry, 1954. (The Industrial Press, New York).

The Flow of Fluids in Closed Conduits, by R. J. S. Pigott (*Mechanical Engineering*, Vol. 55, 1933, p. 497).

A Study of the Data on the Flow of Fluids in Pipes, by E. Kemler (*ASME* Transactions, Vol. 55, 1933, Hydraulics, p. 7).

FLOW OF AIR IN DUCTS

A.S.H.V.E. RESEARCH REPORT No. 1105—Frictional Resistance to the Flow of Air in Straight Ducts, by F. C. Houghten, J. B. Schmieler, J. A. Zalovcik, and N. Ivanovic (A.S.H.V.E. TRANSACTIONS, Vol. 45, 1939, p. 35).

A.S.H.V.E. RESEARCH REPORT No. 1154—Analysis of Factors Affecting Duct Friction, by J. B. Schmieler F. C. Houghten, and H. T. Olson (A.S.H.V.E. TRANSACTIONS, Vol. 46, 1940, p. 193).

Pressure Loss Characteristics of Small Diameter Round Duct Systems, by G. R. Whitnah and J. V. Borry. (A.S.H.V.E. Journal Section, *Heating, Piping & Air Conditioning*, November 1952, p. 111).

A.S.H.V.E. Research Report No. 1470—Pressure Losses in 4-Inch Diameter Galvanized Metal Duct and Fittings, by H. G. Conn, W. G. Colborne, and W. G. Brown. (A.S.H.V.E. TRANSACTIONS, Vol. 59, 1953, p. 139).

PRESSURE LOSS IN ELBOWS

Loss of Pressure Due to Elbows in the Transmission of Air Through Pipes or Ducts, by Frank L. Busey (A.S.H.V.E. TRANSACTIONS, Vol. 19, 1913, pp. 366–376).

New Data for the Design of Elbows in Duct Systems, by Loring Wirt (*General Electric Review*, Vol. 30, June 1927, pp. 286–296).

An Investigation of Pressure Losses in Air Duct Elbows, by Oliver E. Parker (*Northeastern University* thesis, May 28, 1934).

Investigation of Air Flow in Right Angle Elbows in a Rectangular Duct, by Charles H. McLellan and Walter A. Bartlett, Jr. (*National Advisory Committee for Aeronautics, Advanced Restricted Report* L-328, October, 1941).

A.S.H.V.E. RESEARCH REPORT No. 1211—Pressure Loss Caused by Elbows in Eight-Inch Round Ventilating Duct, by M. C. Stuart, C. F. Warner and W. C. Roberts (A.S.H.V.E. TRANSACTIONS, Vol. 48, 1942, pp. 335–350).

Experimental Investigation of Velocity Distributions Downstream of Single Duct Bends, by John R. Weske (*National Advisory Committee for Aeronautics Technical Note* 1471, January, 1948).

Investigations of the Flow in Curved Ducts at Large Reynolds Numbers, by John R. Weske (*Journal* of Applied Mechanics, December, 1948, pp. 344–348).

How Much Pressure Loss in Round Elbows?, by R. K. Guthrie (*Heating, Piping & Air Conditioning*, March 1955, p. 130 and discussions by R. D. Madison and R. M. Conner, April 1955, p. 89, and by the author, June 1955, p. 81).

PRESSURE LOSS IN DIVIDED-FLOW FITTINGS

A.S.H.V.E. RESEARCH REPORT No. 1392—Fitting Losses for Extended-Plenum Forced Air Systems, by H. H. Korst, H. A. Buckley, S. Konzo, and R. W. Rouse. (A.S.H.V.E. TRANSACTIONS, Vol. 56, 1950, p. 259).

A.S.H.V.E. RESEARCH REPORT No. 1430—Pressure Losses of Take-Offs for Extended-Plenum Duct Systems, by J. W. Holl, S. F. Gilman, R. J. Martin, and S. Konzo. (A.S.H.V.E. TRANSACTIONS, Vol. 57, 1951, p. 419).

DUCT DESIGN

A.S.H.V.E. RESEARCH REPORT No. 1050—A Rational Method of Duct Design, by L. G. Miller. (A.S.H.V.E. TRANSACTIONS, Vol. 43, 1937, p. 71).

Modern Thinking Applied to Duct Design, by Kirby Walker, (*Heating, Piping & Air Conditioning*, March 1949, p. 85; April 1949, p. 104; May 1949, p. 91; July 1949, p. 95; September 1949, p. 96; November 1949, p. 97; March 1950, p. 97 and May 1950, p. 94).

Pointers on Air Conditioning Duct Design and Installation (*Heating and Ventilating's* Reference Section, *Heating and Ventilating*, October, 1951).

Economical Duct Layouts, by Peter Franck (*Heating, Piping & Air Conditioning*, December 1952, p. 100).

The Design of Aluminum Duct Systems, by F. W. Hutchinson, 1954 (Kaiser Aluminum & Chemical Sales, Inc., Oakland, Cal.).

MISCELLANEOUS

Performance Tests of Asbestos Insulating Air Ducts, by R. H. Heilman and R. A. McArthur (A.S.H.V.E. TRANSACTIONS, Vol. 44, 1938, p. 197).

CHAPTER 32

FANS

Types, Fan Performance, Fan Laws, Fan Performance Curves, System Characteristics, Fan Arrangements, Fan Control, Motive Power, Fan Selection, Fan Installation, Fan Applications

IN HEATING, ventilating and air conditioning practice, the devices used to produce air flow are variously known as fans, blowers, exhausters or propellers. The *A.S.M.E.* Test Code[1] limits fans to those in which the fluid density change does not exceed 7 percent (one psi at atmospheric pressure) and labels as compressors those devices operating beyond that pressure range. Since air conditioning rarely requires pressures of over $\frac{1}{2}$ psi, all such devices will be known as *fans* and the air will be considered non-compressible.

Types

Fans are divided into two general classifications: (1) *centrifugal or radial flow* in which the air flows radially through the impeller within a scroll type housing, and (2) *axial flow* in which the air flows axially through the impeller within a cylinder or ring.

Centrifugal fans are further subdivided into types denoted by the curvature or slope of the impeller blades, the angle of which largely determines the operating characteristics. For a given output, a forward inclination of blade indicates a relatively low speed of operation, and a backward inclination, a relatively high speed of operation. Many intermediate forms are also found.

Axial flow fans are subdivided into types differentiated mainly by their enclosures and refinements of impellers and appurtenances. All types vary in shape, number and angles of blades; ratios of hub diameter to impeller diameter; materials and methods of fabrication, depending upon design and preference of manufacturer. *Tubeaxial* and *vaneaxial* fans, usually used against appreciable resistance, commonly have relatively large hubs and helical blades (the angle varies radially along the blade). The blades may be of uniform thickness, either flat or cambered, and either cast or made of plates; or they may be of air foil sections, either cast or of double thickness sheet. Streamlining of both impeller and enclosure is common practice. *Vaneaxial* fans incorporate guide vanes to modify performance and increase efficiency. *Propeller* fans customarily used for free delivery, or against low resistance, also are found with a variety of blade conformations, but are simple in construction. They are merely mounted within a plate or ring.

The fan nomenclature in Fig. 1 has been standardized by the *National Association of Fan Manufacturers.*[2]

FAN PERFORMANCE

Fan performance is a statement of volume, total pressures, static pressures, speed, power input, mechanical and static efficiency, at a stated density. These terms are defined by the *National Association of Fan Manufacturers*[2] as follows:

1. *Volume* handled by a fan is the number of cubic feet of air per minute expressed at fan outlet conditions.