

RESPONSE TO CL2 RELEASES

RESPONSE TO CHLORINE, TOXIC RELEASE OR
ENVIROMENTAL INCIDENTCHLORINE RELEASE

1. Notify Gate 1 by telephone at 333 or by emergency radio :
 - a. Tell them the type of release, gas or liquid.
 - b. Magnitude of the release, Category 1,2,or 3.
 - c. Give Midas Scenario
 - d. Area of the release.
2. Sound the general alarm for the block :
 - a. Announce the area of the release.
 - b. Announce the wind direction and evauation points.
 - c. In the event of a large release, account for all personnel.
 - d. Evacuate all non-essential personnel.
3. Keep Gate 1 informed with frequent status reports of progress in containing the release.

TOXIC RELEASE

1. Notify Gate 1 by telephone at 333 or by emergency radio :
 - a. Tell them the type of release
 - b. Magnitude of the release, Category 1,2,or 3.
 - c. Give Midas Scenario
 - d. Area of the release.
2. Sound the general alarm for the block:
 - a. Announce the area of the release.
 - b. Announce the wind direction and area evauation point.
3. Keep Gate 1 informed with frequent status reports of progress in containing the release.

ENVIROMENTAL INCIDENT

1. Refer to the PDP-11 for the reporting quantities and actions to tak

REVISED July 19, 1991

RESPONSE.EMP #672 RL000144.DOC 49-15-01-27

DO A 023237
CONFIDENTIAL

CARBON TETRACHLORIDE RELEASE

CARBON TETRACHLORIDE RELEASE

DANGERS and/or PROBLEMS

1. Toxic fumes.
2. Skin irritation.

CORRECTIVE ACTIONS

S.O.S. ACTIONS

1. Call Plant Security (8888) and Plant Supervision immediately. Us 333 for those instances which present immediate hazard, such as get into the ditch.
2. Block in the receiving line.
3. Block in the line to E-55 / 65 to prevent product from backing up.

O.S. ACTIONS - LIQUEFACTION

1. Notify the Control Room immediately.
2. Make sure the diked in area drain is closed.
3. Manually block the receiving line and the outlet of the tank to E-5 and E-65.

REVISED July 19, 1991

CCL4SPILL.EMP #670 RL000142.DOC 49-15-01-25

DO A 023238
CONFIDENTIAL