Monsanto

FROM (NAME & LOCATION) EVAN J. YOUNG - AKRON - 160

DATE : September 12, 1979

SUBJECT : PCB DISPOSAL

REFERENCE : EJY/RL Plan of Action 5/25/79

TO : Mr. R. L. Liss
GO: B2SC

CC: S. O. Dingler
J. A. Finch
M. E. Gatens
D. Wood

Ray, attached are analytical results from Dayton on half a dozen samples of Therminol taken at various places in our heating/cooling system.

I am pleased at the uniformity and consistency, and also satisfied that the level is about right.

However, the average of 20,000 ppm PCB is orders of magnitude above the prescribed 50 ppm limit. Therefore, we will have to change out the system.

Please advise us on two key points:

1. What are acceptable containers into which to drain the system? Where can we obtain them, etc.?

2. Where can we send the drainage for approved disposal?

Since we have to do it, we plan to drain and refill in the last two weeks of October.

Please advise promptly.

Evan

Evan J. Young

EJY/mrg

IN - 10 REV. 1/72

PCB-ARCH-EXT0376440