

1N7.1

June 17, 1974



American Telephone and
Telegraph Company
195 Broadway
New York, N. Y. 10007
Phone (212) 393-9800

Mr. G. M. Wilkening, Head
Environmental Safety and Health Department
Bell Telephone Laboratories
600 Mountain Avenue
Murray Hill, New Jersey 07974

Dear George:

The Bell System Practices section covering the placement of fiber-cement (transite) conduit is due for revision. Since the material contains some asbestos, we would like to determine the appropriate precautions, if any, that should be followed when cutting the duct during work operations as per OSHA standard on exposure to asbestos fiber.

In order for us to determine if any precautions are necessary, we would appreciate your initiating a program to determine:


1. The level of airborne asbestos fibers that employees could be exposed to when the duct is cut with a regular saw while it is dry;
2. if the level of asbestos is high in (1) above,
 - (a) does wetting the duct significantly reduce this level?
 - (b) what is the level of exposure when the duct is cut with a circular device like a pipe cutter?

It is important that these tests be conducted in an open atmosphere, closely resembling the actual working environment.

Mr. R. Callahan, who can be reached on 212-393-4753, will be glad to answer any questions you may have on this request.

Very truly yours,


Manager - Safety and Supplies


Engineering Manager - Outside Plant
Methods and Materials

cc: C. Harmon - Practice Writer - Winston-Salem
Dr. R. W. Stone - Medical Director - AT&T
G. R. Crimp - Assistant Engineering Manager - AT&T

MTW:mm

PLAINTIFF'S EXHIBIT

SWB-21

CONFIDENTIAL

003662



JUN

1973-11-11

Western Electric

Service
Common Installation Engineering

3800 Golf Road
Rolling Meadows, Ill. 60008
312 956-2000

JUN 05 1973

MR. W. PFERD, Head
Telephone Buildings Planning Department

Whippany

Re: Transite Cable Hole Covers

File: I.E. 30

This is in reference to a phone conversation on May 10, 1973 between Mr. C. Bendersky of your organization and Mr. A. Skirpstunas of CIE, concerning airborne concentrations of asbestos fibers in Central Offices generated from cutting of transite cable hole covers.

In order to minimize any adverse affects upon the Installer when working with asbestos, installation practices require that the Installer handling asbestos, mineral wool or rock wool wear plastic safety goggles, leather palmed canvas gloves and a respirator to protect the nose and mouth.

The airborne concentration in a Central Office of asbestos fibers generated from the transite cutting process is presently unknown. However, we have been advised that we may be in violation of OSHA, when working with transite cable hole covers in new Central Offices or on additions.

We have requested Western Electric Headquarters to clarify the corporate stand in regard to a periodic physical examination for persons being exposed to airborne asbestos particles. We have also requested them to assist us in evaluating what the airborne asbestos particle concentration level is while the Installer cuts asbestos.

In view of the fact that your organization is actively engaged in testing and evaluation of the present cable hole concept, we feel that this condition has an impact on your studies and requires immediate attention.

CONFIDENTIAL

003665

Transite Cable Hole Cover
Plates - Case 20233-3

AS
Carpenter



Bell Laboratories

Whippany Road
Whippany, New Jersey 07981
Phone (201) 386-3000

MAR 21 RECD
March 18, 1974

Mr. J. Glowacki
Assistant Manager
Common Installation Engineering and Services
WE - Rolling Meadows

Re: Letter of June 5, 1973, concerning use of transite cable
hole covers.

The health problems associated with the generation of asbestos particles in the field use of transite cable hole cover plates are fully understood by the Buildings and Power Laboratory. My department has completed a test program evaluating the fire resistance of cable holes packed with KS-5048 bags and is nearing completion of a similar evaluation program on the cable hole closure filled to 25 percent by volume with communication cable. A report is currently being issued on the first program and the report on the second group of tests will be issued shortly thereafter.

Based on the results from these two programs, it is our opinion that a steel cover plate, comparable to the present ceiling plate, should be used as an interim measure to replace the transite cover plate. It should be cut and handled identically to the ceiling plate. Several alternative materials are being considered for possible future use but will require test evaluation to determine their compatibility with closure design requirements. We shall keep you informed as to progress in this area.

W. Pford
W. Pford
Head
Telephone Building
Planning Department

WH-2431-CB-bfg

Copy to
Messrs. R. J. Finnerty - AT&T - 195 Broadway

R. M. Riley
J. Simpson
R. J. Skrabal
C. H. F. Spring

CONFIDENTIAL

003664