

INTERNAL CORRESPONDENCE

 SWRCO/ES&H (UNIT)	TO	M. Hoeltzel	DATE	December 6, 1990
	FROM	S. Settles	SUBJECT	MAIN LAB

The Insulation Shop collected twelve bulk samples in the Main Lab. Analysis shows that two of the samples meet the definition of asbestos containing material (ACM).

These two samples represent approximately 375 sq. ft. of ACM in the Cat/Sulfolane Lab closet and 21 linear ft. of ACM on a 1 1/2" line in the A.C. room.

Due to the scope of this abatement project, the removal work will need to be contracted out.

SJS:iew
SS-90111

c: Roger Clark

SJS

1B 002843