

MON-1969

Monsanto

FROM (NAME & LOCATION) G. T. McVay - ED

February 29, 1984

cc ✓ SHAC
W. G. Howe
A. R. Mathison

SUBJECT 4th Qtr. Safety Inspection

REFERENCE Letter Dated February 2, 1984

TO : R. L. Hammond

Responses to the items referenced by the Inspection Team for the 4th Quarter Housekeeping Inspection that apply to the Electrical Shop are:

1. Ladders stored against north wall: The retaining chain was removed and missing. A permanently attached chain is being installed and bolted in place.

Responsibility: A. R. Mathison

Due Date : 3/15/84

2. Barricades around diesel and transformer reorganized: Barricades are now arranged so as only the transformers and filters are included.

3. Generator: Hearing protection signs will be mounted on generator.

Responsibility: A. R. Mathison

Due Date : 3/15/84

Gerald

G. T. McVay

:js