pump installation, or may be a self-contained domestic-water heat pump.

Various designs of self-contained domestic water heat pumps are available, and one particular arrangement is shown in Fig. 17.

Hot water heating by means of a heat pump is not yet advisable where high water temperatures are desired. This is due to the fact that higher water outlet temperatures result in lower coefficients of performance.

For coefficients of performance of 4 or higher, the heat-pump water heater may be more economical to operate than a conventional water heater.

Although the first cost of domestic hot water heat pumps is somewhat high, they have the advantages of operating without products of combustion, odors, soot, or chimney. A further advantage is that they may be used for cooling purposes. With a coefficient of performance of 2½ to 3, water temperatures of 140 to 150 F may be obtained.[8]

REFERENCES

[1] R. B. Hunter: *Water Distributing Systems for Buildings* (*National Bureau of Standards Report* BMS79, p. 6). (Charts extended to flow of 0.30 gpm.)

[2] Private communication from H. E. Degler.

[3] T. Z. Dunn, R. N. Spear, B. E. Twigg, and Don Williams (Members of Water Heating and Steam Generation Committee of A.G.A.): Water heating for commercial kitchens (*Air Conditioning, Heating and Ventilating*, May 1959, p. 70). Also published as a bulletin entitled *Enough Hot Water—Hot Enough* (American Gas Association, 1959).

[4] E. F. Hebrank: Investigation of the performance of automatic storage-type gas and electric domestic water heaters (University of Illinois, *Engineering Experiment Station Bulletin* No. 436, 1956).

[5] Svend Plum: *Plumbing Practice and Design* (John Wiley and Sons, New York, 1943).

[6] P. Sporn and E. R. Ambrose: Progress report on a heat pump water heater (*Heating and Ventilating*, Vol. 46, February 1949, p. 78).

BIBLIOGRAPHY

H. C. Russell: Laundry, kitchen and hospital equipment (ASHVE TRANSACTIONS, Vol. 35, 1929, p. 45).

G. C. St. Laurent: Water consumption, cost and savings (*Hotel Engineering*, Vol. 1, American Hotel Association, 1940).

F. M. Dawson and A. A. Kalinske: *Water-Supply Piping for the Plumbing System* (*National Association of Master Plumbers Technical Bulletin* No. 3).

F. A. Brooks: *Use of Solar Energy for Heating Water* (Smithsonian Institution, Washington, D.C.).

R. B. Hunter: *Methods of Estimating Loads in Plumbing Systems* (*National Bureau of Standards Report* BMS65, 1940).

Plumbing Manual, Report of the Subcommittee on Plumbing, Central Housing Committee on Research, Design and Construction (*National Bureau of Standards Report* BMS66, 1940).

R. B. Hunter: *Water-Distributing Systems for Buildings* (*National Bureau of Standards Report* BMS79, 1941).

M. B. Mackay: Hot water requirements (*Modern Sanitation*, Vol. 1, August 1949, p. 30).

M. A. Pond: Urban domestic water consumption (*Journal of the American Water Works Association*, Vol. 31, No. 12, 1939, p. 2003).

J. C. Church: Hot water for hospitals (*Heating and Ventilating*, October 1952, p. 97).

R. Murray: How to size and install gas water heaters correctly (*Air Conditioning, Heating and Ventilating*, February 1955, p. 86).

J. C. Church: Water supply for tall buildings (*Air Conditioning, Heating and Ventilating*, February 1955, p. 99).

F. M. Reiter: Service hot water design for multi-story buildings (*Air Conditioning, Heating and Ventilating*, December 1955, p. 79).

F. M. Reiter: Service hot water for commercial and industrial use (*Air Conditioning, Heating and Ventilating*, February 1956, p. 89).

F. M. Reiter: Design data for service hot water (*Air Conditioning, Heating and Ventilating*, April 1956, p. 81).

G. R. Jerus: Design of swimming pools (*Air Conditioning, Heating and Ventilating*, February 1957, p. 113).

J. Nachbar: Water supply for industrial plants (*Air Conditioning, Heating and Ventilating*, December 1957, p. 53).

National Plumbing Code (American Standards Association, ASA A40.8-1955).

Spray Type Dishwashing Machines (*Standard* No. 3, National Sanitation Foundation, 1953).

Commercial Gas and Electrically Heated Hot Water Generating Equipment for Food Service Establishments Using Dishwashing Machines (*Standard* No. 5, National Sanitation Foundation, 1959).

CHAPTER 76

SNOW MELTING

Design: Heating Requirement, Hydraulic Requirement, Installation: Safety, Internal Corrosion, Slab Construction, Thermal Stresses, Control, Testing, Draining, Drifting Snow, Design Example

THE practicability of melting snow by means of heated coils has been demonstrated in a large number of installations in sidewalks, roadways, ramps, and runways. In addition to eliminating the need for snow removal, other advantages gained are greater safety to pedestrians and vehicles, and reduction of labor in removal of slush from floors.

The design of a snow-melting system must determine and satisfy two primary requirements: (1) the heating requirement, and (2) the hydraulic requirement. Each of these is treated in this chapter. Several points regarding installation practices are also discussed.

DESIGN

Heating Requirement

The heating requirement for snow melting is affected by four atmospheric factors: (1) rate of snowfall, (2) air temperature, (3) wind velocity, and (4) humidity. The effects of these factors can be evaluated by consideration of the action of snow falling on a warmed surface.

The first flakes fall on a dry, warm surface, and are then warmed to 32 F and melted. The water from the melted snow soon forms a film over the entire area and starts to evaporate. The evaporation of the film is a *mass* transfer from the surface to the atmosphere. In addition, there is a *heat* transfer from the film to the ambient air and surfaces.

Mass transfer due to evaporation. The rate of evaporation of the melted snow from the snow-melting slab is affected by the wind speed and the vapor-pressure difference between the air and the melted snow. The vapor pressure of air, however, is fixed by the relative humidity and the temperature of the air. If the slab surface temperature is fixed, then the evaporation loss varies with changes in air temperature, relative humidity, and wind speed.

Heat transfer by convection and radiation from the melted snow to the ambient air and surfaces. A combined film coefficient has been used with sufficient accuracy to determine the combined convection and radiation loss. This coefficient is based on a heat transfer from a *wetted* surface, such as the film of melted snow, to air. The coefficient is a function of wind speed alone. The heat transfer, of course, is dependent upon the film coefficient and the temperature difference between the surface and the air. Since the surface temperature is fixed, the convection and radiation losses vary with changes in air temperature and wind speed.

To determine evaporation and heat transfer from the melted snow to the air it is necessary to know three of the four climatic factors: (1) wind speed, (2) air temperature, and (3) relative humidity, and (4) rate of snowfall. The fourth factor, rate of snowfall, is necessary to determine the heat required to warm the snow to 32 F, and to melt it.

Before deriving equations to give quantitative values for the effects of these four factors, it is necessary to consider the insulating effect of the snow before it is melted. As stated previously, the first flakes fall on a dry, warm surface, and are then warmed to 32 F and melted. During the time that the flakes are being warmed, and before they are completely melted, they can be considered as tiny blankets or insulators. The effect of this insulation has been measured[1] and can be of considerable magnitude. Since the snowflakes cover a fraction of the surface area, it has been convenient to think of the insulating effect as an area ratio. The area covered by the snowflakes is the insulated area, and the uncovered area is the uninsulated area. The term free area ratio A_r has been adopted to represent the ratio of the uncovered, or free, area to the total area or,

$$A_r = \frac{A_f}{A_t} \qquad (1)$$

where

A_r = Free area ratio.
A_f = Free area, sq ft.
A_t = Total area, sq ft.

hence

$$0 \leq A_r \leq 1$$

For $A_r = 1$, the system would have to melt the snow so rapidly that the snow accumulation would be absolutely zero. This is impossible from a theoretical standpoint, but for all practical purposes it is permissible to have $A_r = 1$ as a maximum. For $A_r = 0$, the surface would be completely covered with snow to a depth sufficient to completely prevent evaporation and heat transfer losses. Research on the insulating