

FILE NAME: Pfizer (PFIZ)

DATE: 1968 Dec 30

DOC#: PFIZ038

DOCUMENT DESCRIPTION: DC Govt License

GOVERNMENT OF THE DISTRICT OF COLUMBIA
DEPARTMENT OF LICENSES AND INSPECTIONS
OFFICE OF THE DIRECTOR
WASHINGTON D. C.



CERTIFICATE OF APPROVAL

Research File No.

RE 69-2 (BM)

Date of Application
December 30, 1968

Name of Applicant
Chas. Pfizer & Co., Inc.

Address of Applicant

% Harry E. Bourke
Name of Product or System
Kilnoise

Description of Product or System

An acoustical plaster used for soundproofing and comprising part of a floor and ceiling assembly.

Requested Use
For 4 hours; 2 1/2 inches of concrete and steel joist with suspended ceiling of 1/2 inch perlite plaster on metal lath and finished with 1/2 inch of acoustical plaster

Verification Submitted
Underwriters Laboratories Inc. Report on Retardant 4206-1 dated August 17, 1959.

Accepted Use

Same as requested when erected in accordance with the U.L. test report.

Code Authority

Section 3-903 of the 1961 D.C. Building Code.

Recommended for Approval by the Research and Standards Engineer

Date of Publication of Intent to Approve

Robert M. Rygal

Concurred in (Name and Title)

William H. Driggs
WILLIAM H. DRIGGS, Superintendent
Inspection Division

Published in

D. C. Register

APPROVED SUBJECT TO CONDITIONS LISTED ABOVE

John J. Jones
Director

January 13, 1969
Date

(this approval shall not be used for advertising purposes)

CODE FOR RESEARCH FILES

BM Building Material
Elec Electrical
Elev Elevator

HACV Heating Air Conditioning and Ventilation
P Plumbing
SS Structural System

Form 1021
3-5-64

SAMPLE 16405

Sample PFZ0041