

EXECUTIVE SUMMARY - Detection Highlights

D7C140365

PARAMETER	RESULT	REPORTING LIMIT	UNITS	ANALYTICAL METHOD
✓ DRRWTP RAW WATER 03/13/07 13:05 001				
PFOS	0.0073 J	0.010	ug/L	DEN -LC-0012
PFOA	0.0068 J	0.015	ug/L	DEN -LC-0012
✓ DRRWTP INLET 03/13/07 07:55 002				
PFOS	0.0066 J	0.010	ug/L	DEN -LC-0012
PFOA	0.0069 J	0.015	ug/L	DEN -LC-0012
✓ DRRWTP SETTLED 03/13/07 07:55 003				
PFOS	0.0086 J	0.010	ug/L	DEN -LC-0012
PFOA	0.0073 J	0.015	ug/L	DEN -LC-0012
✓ DRRWTP FILTER EFFLUENT 03/13/07 07:55 004				
PFOS	0.0052 J	0.010	ug/L	DEN -LC-0012
PFOA	0.0062 J	0.015	ug/L	DEN -LC-0012
✓ DRRWTP PLANT EFFLUENT 03/13/07 07:55 005				
PFOS	0.0059 J	0.010	ug/L	DEN -LC-0012
PFOA	0.0068 J	0.015	ug/L	DEN -LC-0012
✓ BIRCH CREEK WELL 6 03/13/07 10:40 011				
PFOS	0.0064 J	0.010	ug/L	DEN -LC-0012
PFOA	0.052	0.015	ug/L	DEN -LC-0012
BIRCH CREEK WELL 6 POST FILTER 03/13/07 10:50 012				
PFOS	0.0054 J	0.010	ug/L	DEN -LC-0012
PFOA	0.052	0.015	ug/L	DEN -LC-0012
BIRCH CREEK WELL 6 POE 03/13/07 11:06 013				
PFOS	0.0066 J	0.010	ug/L	DEN -LC-0012
PFOA	0.050	0.015	ug/L	DEN -LC-0012
BIRCH CREEK WELL 4 03/13/07 11:00 014				
PFOA	0.030	0.015	ug/L	DEN -LC-0012

STL Denver

3

CONFIDENTIAL, SUBJECT TO PROTECTIVE ORDER IN
ROWE/COLES

NJAW000257

EXECUTIVE SUMMARY - Detection Highlights

D7D180342

<u>PARAMETER</u>	<u>RESULT</u>	<u>REPORTING LIMIT</u>	<u>UNITS</u>	<u>ANALYTICAL METHOD</u>
BIRCH CREEK POB 04/17/07 08:25 001				
PFOS	0.0067 J	0.010	ug/L	DEN -LC-0012
PFOA	0.062	0.015	ug/L	DEN -LC-0012
BIRCH CREEK WELL 6 04/17/07 08:20 002				
PFOS	0.0072 J	0.010	ug/L	DEN -LC-0012
PFOA	0.061	0.015	ug/L	DEN -LC-0012
BIRCH CREEK WELL 4 04/17/07 08:45 003				
PFOS	0.0021 J	0.010	ug/L	DEN -LC-0012
PFOA	0.029	0.015	ug/L	DEN -LC-0012
DRRWTP INLET 04/17/07 13:05 004				
PFOS	0.0045 J	0.010	ug/L	DEN -LC-0012
PFOA	0.0094 J	0.015	ug/L	DEN -LC-0012
DRRWTP PE 04/17/07 13:05 005				
PFOS	0.0047 J	0.010	ug/L	DEN -LC-0012
PFOA	0.010 J	0.015	ug/L	DEN -LC-0012

STL Denver

3

CONFIDENTIAL, SUBJECT TO PROTECTIVE ORDER IN
ROWE/COLES

NJAW001584