


Interoffice Memorandum.



TO: (Name and Location) Mr. J. B. Towers	DATE October 30, 1987
FROM: (Name and Location) R. W. King	REFERENCE NO. RWK-65-87

cc: G. E. Organ --> T. N. Moody
C. R. Pennington --> N. V. Smith
G. B. Durett
I. O. Coleman, Jr.
C. J. Libby
R. E. Allan
~~G. Ille~~
S. R. Starks - Arthur Bros.



SUBJECT: Asbestos Sampling

Attached please find the results for analyses of personnel/area monitoring samples for asbestos performed on the noted samples (Table I). The air samples are reported as fibers per cubic centimeter (f/cc).

Table II lists the bulk samples and the location where they were taken. These samples are reported by asbestos type.

Please communicate this information to your employees who work at these locations.

R. W. King / G. Ille
R. W. King

RWK/glf

Attach.

005904

DO IT RIGHT THE FIRST TIME

Table I

<u>Cassette Number</u>	<u>Date</u>	<u>Location</u>	<u>Name</u>	<u>Fiber/cc</u>	<u>Sx/Time Minutes</u>
----------------------------	-------------	-----------------	-------------	-----------------	----------------------------

Samples taken during clean up of asbestos removal area, first weekend of asbestos ceiling tile removal in Administration Bldg.

285	10/17/87	Reception area, outside double doors.	Area	<0.03	357.3
286	10/17/87	Outside exit shower in hall- way.	Area	<0.03	359.1
287	10/17/87	Outside plastic barrier, next to coffee bar.	Area	<0.03	358.3

Samples taken during clearance of asbestos removal area, Administration Bldg.

288	10/13/87	Hallway, by Exit next to Traffic Office.	Area	<0.03	245.8
289	10/13/87	Hallway, return A/C air going to coffee bar.	Area	<0.03	241.9
290	10/13/87	Hallway, half- way down, E. Tejml office.	Area	<0.03	241.7

005905

Table I
(Cont.)

Samples taken during second weekend of asbestos ceiling tile removal by P/H
Asbestos removal contractor for final air clearance.

291	10/24/87	Hallway, middle between Nurse's office and Mailroom.	Area	<0.03	243
292	10/24/87	Hallway, from Nurse's office to Traffic office.	Area	<0.03	243
293	10/24/87	Hallway, from Mail- room to Coffee Bar.	Area	<0.03	241

005906

Table II
Bulk Samples

<u>Sample #</u>	<u>Date</u>	<u>Location</u>	<u>Asbestos %</u>	
			<u>Amosite</u>	<u>Chrysotile</u>
0297	10/18/87	Material from panel over window in Administration Bldg.	-	15

005907