


(See manufacturer's data for exact value for meter used)
Fig. 6.... Pressure Losses in Disc-type Water Meters

varies considerably with the design even in meters of the same nominal size. The values given in Table 5 are ample for the well-known disc meters now on the market.

The water demand for hose bibbs or other large demand fixtures taken off the building main is frequently the cause of inadequate water supply to the upper floor of a building. This condition may be prevented by sizing the distribution system so that the pressure drops from the street main to all fixtures are the same. It is good practice to maintain the building main of ample size (not less than 1 in. where possible) until all branches to hose bibbs have been connected. Where the street main pressure is excessive and a pressure reducing valve is used to prevent water hammer or excessive pressure at the fixtures, it is frequently desirable to connect hose bibbs ahead of the reducing valve.



- A. 1/2-in. laundry bibb (old style).
B. Laundry compression faucet.
C-1. 1/2-in. compression sink faucet (Mfr. 1).
C-2. 1/2-in. compression sink faucet (Mfr. 2).
D. Combination compression bathtub faucets (both spout).
E. Combination compression sink faucet.
F. Basin faucet.
G. Spring self-closing faucet.
H. Slow self-closing faucet.

(Dashed lines indicate recommended extrapolation)
Fig. 7.... Variation of Pressure Loss with Rate of Flow for Various Faucets and Cocks

Table 3.... Performance Requirements of Water Meters*

Size, in.	Normal Test-Flow Limits, gpm	Minimum Test-Flow, gpm
3/8	1 to 20	1/8
1/2	2 to 34	1/4
3/4	3 to 53	3/8
1	5 to 100	1/2
2	8 to 160	2
3	15 to 315	4
4	28 to 500	7
6	48 to 1,000	12

* American Water Works Association Standards.
Registration. The registration on the meter dial shall indicate the quantity recorded to be not less than 98 percent nor more than 102 percent of the water actually passed through the meter while it is being tested at rates of flow within the specified limits herein under normal test flow limits. There shall be not less than 90 percent of the actual flow recorded when a test is made at the rate of flow set forth under minimum test flow.

The principles involved in sizing either up-feed or down-feed systems are the same. The principal difference in procedure is that in the down-feed system, the difference in elevation between the house tank and the fixtures provides the pressure required to overcome pipe friction, and thus reduces pipe sizes, since friction pressure loss and height pressure loss are not additive as with an up-feed system.

Procedure for Sizing Cold Water Systems

The recommended procedure for sizing piping systems is outlined in following paragraphs 1 to 6, inclusive.

1. Draw a sketch of the main lines, risers, and branches, and indicate the fixtures to be served. Indicate the rate of flow of each fixture.
2. Using Table 2, compute the demand weights of the fixtures in fixture units.
3. Determine the total demand in fixture units and, using Fig. 1 or Fig. 2, find the expected demand in gallons per minute.
4. Determine the equivalent length of pipe in the main lines, risers, and branches. Since the sizes of the pipes are not known, the exact equivalent length for various fittings, etc., cannot be made. Add the equivalent lengths, starting at the street main

Table 4.... Allowance in Equivalent Length of Pipe for Friction Loss in Valves and Threaded Fittings*

Diameter of Fitting, in.	Equivalent Length of Pipe for Various Fittings						
	90-Deg Standard El, ft	45-Deg Standard El, ft	90-Deg Side Tee, ft	Coupling for Straight Run of Tee, ft	Gate Valve, ft	Globe Valve, ft	Angle Valve, ft
3/8	1	0.6	1.5	0.3	0.2	8	4
1/2	2	1.2	3	0.6	0.4	15	8
3/4	2.5	1.5	4	0.8	0.5	20	12
1	3	1.8	5	0.9	0.6	25	15
1 1/4	4	2.4	6	1.2	0.8	35	18
1 1/2	5	3	7	1.5	1.0	45	22
2	7	4	10	2	1.3	55	28
2 1/2	8	5	12	2.5	1.6	65	34
3	10	6	15	3	2	80	40
3 1/2	12	7	18	3.6	2.4	100	50
4	14	8	21	4	2.7	125	55
5	17	10	25	5	3.3	140	70
6	20	12	30	6	4	165	80

* From NBS Report BM366 Plumbing Manual.

Water Services

Table 5.... Equivalent Lengths of Iron Pipe to Give Same Loss as Special Fittings and Apparatus*

Fitting Apparatus	Nominal Diameter of Pipe—Inches			
	3/4	1	1 1/4	1 1/2
30-gal. Vertical hot water tank, 1/2-in. pipe.	4	17	56	—
30-gal. Horizontal hot water tank, 1/2-in. pipe.	1.2	5	16	—
Water meters (No valves included)	6.7	28	90	—
1/2 in. with 1/2-in. connections	4.8	20	64	—
3/4 in. with 3/4-in. connections	3.4	14	45	—
1 in. with 1-in. connections	—	9	30	115
1 1/4 in. with 1 1/4-in. connections	—	4.4	14	54
Water softener	—	50-200	—	—

* The designer should check manufacturer's data for maximum losses through softeners, as well as filters. Friction loss increases with use in this equipment.

and proceeding along the service line, the main line in the building, and up the riser to the top fixture of the group served.

5. Determine the average minimum pressure in the street main and the minimum pressure required for the operation of the topmost fixture. This latter pressure should be 8 to 25 psi.

6. Calculate, by means of Equation 1, the approximate design value of the average pressure drop per 100 ft of pipe in the equivalent length determined in paragraph 4.

$$p = [P_s - 0.434H - P_f - P_m] \frac{100}{L} \quad (1)$$

where

p = average pressure loss per 100 ft of equivalent length of pipe, psi.

P_s = pressure in street main, psig.

P_f = minimum pressure required to operate topmost fixture, psig.

P_m = pressure drop through water meter, psi.

H = height of highest fixture above street main, feet.

L = equivalent length determined in paragraph 4, feet.

If the system is of the down-feed supply from a gravity tank, the height of water in the tank, converted to pounds per square inch by multiplying by 0.434, replaces the street main pressure, and the term $0.434H$ in Equation 1 is added instead of subtracted in calculating the term p . In this case, H will be the vertical distance of the fixture below the bottom of the tank.

7. From the expected rate of flow, determined as in paragraph 3, and the value of p , calculated as in paragraph 6, choose the size of pipe from Figs. 3, 4, or 5.

Example 2: Assume a minimum street main pressure of 55 psig; a height of topmost fixture (a urinal with flush valve) above

Table 6.... Computation of Branch Size in Example 2

Fixtures No. and Kind	Fixture Units (From Table 2 and Note c)	Demand (From Fig. 2) gpm	Pipe Size (From Fig. 4) in.
3 flush valves	3 x 6 = 18		
2 bathtubs	1/2 (2 x 2) = 3		
3 lavatories	3/4 (3 x 1) = 2.25		
Total	23.25	38	1 1/4

Table 7.... Allowable Number of 1/2-in. Connections for Various Sizes of Water Pipe

Pipe Size, in.	Average Demand	100 Percent Demand
1/2	1	1
3/4	4	3
1	10	6
1 1/4	20	12
1 1/2	30	20
2	50	35
2 1/2	70	60
3	125	100
4	200	165

street main of 50 ft; a developed pipe length from water main to highest fixture of 100 ft; a total load on the system of 50 fixture units; and that the water closets are flush-valve operated. Find the required size of supply main.

Solution: From Fig. 2 the estimated peak demand is found to be 51 gpm. From Table 1, the minimum pressure required to operate the topmost fixture is 15 psig. From Table 3 it is evident that several sizes of meters would adequately measure this flow. For a trial computation choose the 1 1/4-in. meter. From Fig. 6 the pressure drop through a 1 1/4-in. disc-type meter for a flow of 51 gpm is found to be 6.5 psi.

Then the pressure drop available for overcoming friction in pipes and fittings is $55 - (0.434 \times 50 + 15 + 6.5) = 12$ psi.

At this point it is necessary to make some estimate of the equivalent pipe length of the fittings on the direct line from the street main to the highest fixture. The exact equivalent length of the various fittings cannot now be determined since the pipe sizes of the building main, riser, and branch leading to the highest fixture are not known as yet, but a first approximation is necessary in order to make a tentative selection of pipe sizes. If the computed pipe sizes differ from those used in determining the equivalent length of pipe fittings, a recalculation will be necessary, using the computed pipe sizes for the fittings. For the purposes of this example assume that the total equivalent length of the pipe fittings is 50 ft.

Then the permissible pressure loss per 100 ft of equivalent pipe is $12 \times 100 / (50 + 50) = 8$ psi.

Assuming that the corrosive and caking properties of the water are such that Fig. 4 for fairly rough pipe is applicable, a 2-in. building main will be adequate.

The sizing of the branches of the building main, the risers, and fixture branches follows the principles outlined. For example, assume that one of the branches of the building main carries the cold water supply for 3 water closets, 2 bathtubs, and 3 lavatories. Using the permissible pressure loss of 8 psi per 100 ft, the size of branch determined from Table 2 and Figs. 1 and 4 is found to be 1 1/4 in. Items entering the computation of pipe size are given in Table 6.

Tables 7 and 8 have been used to simplify the sizing of local branch piping.

Velocity must also be considered in sizing water supply

Table 8.... Allowable Number of 1-in. Flush Valves Served by Various Sizes of Water Pipe*

Pipe Size, in.	No. of 1-in. Flush Valves
1 1/4	1
1 1/2	2-4
2	5-12
2 1/2	13-25
3	26-40
4	41-100

* Two 3/4-in. flush valves are assumed equal to one 1-in. flush valve, but can be served by a 1-in. pipe. Water pipe sizing must be tempered by consideration of demand factor, available pressure, and length of run.