700 WEST CAROLINE STREET, PAULDING, OHIO 45879 • 419/399-3015

grizzly
BRAKE PRODUCTS

PLAINTIFF'S EXHIBIT
MAR-348

April 1, 1976

Glen Butler
Area Director
Occupational Safety and Health Administration
Federal Office Building - Room 734
234 Summit Street
Toledo, Ohio 46304

Dear Mr. Butler:

REF: OSHA-1, No. 320

This is our second progress report for correction of alleged violations stemming from an inspection made on 2/4/76.

Item #1 of Citation #2 was reported corrected on the previous report.

The following is a report on newly corrected items and a progress report on the remaining items.

COMPLETED ITEMS

Citation #	Item #	Corrective Action Taken
1	2	Electrical rewiring of the motors and equipment at the Bond line was completed on 3/16/76. All work meets all applicable NEC and NFPA Codes.
1	3	Caution signs were affixed to the open tubs of asbestos on 3/10/76.
3	1	Labeling of the large metal tubs containing asbestos was completed on 3/10/76.

ITEMS REMAINING TO BE COMPLETED

Citation #	Item #	Status
1	1	An electrical contractor and an electrical supply house are currently evaluating lighting needs throughout the plant. This is to be completed by 4/15/76, after which quotes will be requested so that a purchase order may be written. This item will be completed by 8/16/76.

Sincerely,

A. P. Staszak
OSHA and EPA Compliance Director

ABS:llw

cc: R. Hemmelgarn
R. Rogers
J. Sherr
R. Treinen