PLAINTIFF'S EXHIBIT

SWB-86

May 12, 1978

Charles R. Gundersen
New England Telephone
185 Franklin Street
Room 1501
Boston, MA 02110

Dear Mr. Gundersen:

The two insulation samples from the basement and the second floor of 770 Elm Street, Manchester NH which you mailed to me were analyzed by x-ray diffraction. Both samples were similar and were found to contain chrysotile (asbestos), calcite, and gypsum. The second floor sample contained 10% to 25% chrysotile by weight. Details of the analysis can be found in Bell Laboratory's notebook #58370. If you have any further questions about this analysis please give me a call.

Sincerely,

C. P. Lichtenwalner

Copy to
R. L. Beach
N. J. DeCapua
J. M. Degen
R. W. Stone, M.D.
W. J. Schreibeis
G. M. Wilkening

003560

CONFIDENTIAL