

**Ventilation, 9**  
 air conditioning units, 639  
 dairy barn, 164  
 garage, 164  
 hospitals, 220, 229  
 natural, 157  
   - general rules, 163  
 passenger bus in summer, 853  
 railway passenger car, 850  
 ship, 859  
 symbols for drawings, 16  
 systems, 789  
 wind forces, 157

**Ventilator, ventilators**  
 control, 162  
 roof, 162  
 unit, 495, 613  
   - control, 613  
 window, 508

**Vertical blow unit heater, 498**

**Vertical openings, 155**

  - sealing of, 155

**Vibration machine, 784**

**Viscous filters, 596**

  - automatic, 597

  - impingement, 596

**Vitiation of air, 197**

**Volume**

  - control, 741

  - furnace, 328

  - specific, 9

## W

**Wall, walls**

  - heat flow through, 111, 124, 244, 270, 273

  - heat transfer coefficients, 97, 111, 140

  - infiltration through, 149, 150

  - time lag of solar radiation, 269

**Warm Air**

  - gravity heating system, 397

  - combination carrying capacity, 403

  - design procedure, 399, 404

  - furnace capacity, 360

  - installation practice, 397

  - standardized combinations, 400

  - mechanical heating systems, 406

  - automatic control, 411

  - cooling methods, 414

  - dampers, 407

  - design procedure, 409

  - ducts, 408

  - fans, 358

  - filters, 358

  - furnace, 358

  - heavy duty, 359

  - selection, 360

  - large systems, 415

  - motors, 358

  - registers and grilles, 406

  - standard combinations, 408

  - panel heating, 563

  - radiant heating, 563

  - radiators, 338

**Washer, washers, 651**  
 - air, 1, 651

**Water**

  - analysis, 885, 886

  - atmospheric cooling equipment, 658, 879

  - characteristics, 884

  - classification, 884

  - coils, 480

  - control temperature service, 880

  - cooled

  - condenser, 714

  - corrosion treatment, 888

  - formed deposits, 884

  - heater

  - coal-fired, 878

  - solar, 881

  - heating, 551, 867

  - make-up, 671

  - maximum, main temperature, 654

  - mineralized, 885

  - properties of, 36, 691

  - supply piping, 867, 869

  - arrangement, 874

  - temperature control, 880

  - thermodynamic properties of, 36

  - treating chemicals, 884, 895, 902

  - well, temperatures, 656

**Water vapor, 28, 36**

  - saturation pressure, 36

  - specific enthalpy, 4

  - specific volume, 9, 36

**Welding, 511**

  - Wet-bulb temperature (see *Temperature*), 8, 660

  - Wet return, 7, 416

**Wind, winds**

  - forces, 157

  - due to stack effect, 158

  - natural draft equipment, 663

  - selection of, velocity, 247

**Window, windows**

  - coefficients of transmission, 136

  - leakage, 149

  - solar radiation through, 274

  - ventilators, 508

**Winter**

  - air conditioning system, 789

  - comfort zone, 212

  - freezing, equipment, 671

  - Wound rotor motor, 634

  - Wrought-iron pipe, 511

  - Wrought-steel pipe, 511

## X-Y-Z

**Year-round air conditioning system, 789**

**Zone control, 790**

**Zone of evaporative regulation, 200**

**Zoning, 780**

  - control, 611

  - recooling, 789

  - reheat, 789

  - volume control, 741

## Chapter 1

### TERMINOLOGY

*Glossary of Physical and Heating, Ventilating, Refrigerating and Air Conditioning Terms Used in the Text*

**Absolute Zero:** The zero from which absolute temperature is reckoned. Approximately  $-273.2^{\circ}\text{C}$  or  $-459.8^{\circ}\text{F}$ .

**Absorbent:** A sorbent which changes physically or chemically, or both, during the sorption process.

**Absorption:** The action of a material in extracting one or more substances present in an atmosphere or mixture of gases or liquids; accompanied by physical change, chemical change, or both, of the sorbent.

**Acceleration:** The time rate of change of velocity i.e., the derivative of velocity with respect to time. In the cgs system the unit of acceleration is the centimeter per (second) (second), in the fps system the unit is the foot per (second) (second)  $a = \frac{dv}{dt}$ .

**Acceleration Due to Gravity:** The rate of gain in velocity of a freely falling body, the value of which varies with latitude and elevation. The international gravity standard has the value of 980.665 cm per (second) (second) or 32.174 ft per (second) (second) which is the actual value of this acceleration at sea level and about 45 deg latitude.

**Adiabatic:** An adjective descriptive of a process such that no heat is added to or taken from a substance or system undergoing the process.

**Adsorbent:** A sorbent which does not change physically or chemically during the sorption process.

**Adsorption:** The action, associated with surface adherence, of a material in extracting one or more substances present in an atmosphere or mixture of gases and liquids unaccompanied by physical or chemical change. Commercial adsorbent materials have enormous internal surfaces.

**Aerosol:** An assemblage of small particles, solid or liquid, suspended in air. The diameters of the particles may vary from 100 microns down to 0.01 micron or less, e.g. dust, fog, smoke.

**Air Cleaner:** A device designed for the purpose of removing air-borne impurities such as dusts, gases, vapors, fumes and smokes. (Air cleaners include air washers, air filters, electrostatic precipitators and charcoal filters.)

**Air Conditioning:** The simultaneous control of all or at least the first three of those factors affecting both the physical and chemical conditions of the atmosphere within any structure. These factors include temperature, humidity, motion, distribution, dust, bacteria, odors and toxic gases, most of which affect in greater or lesser degree human health or comfort. (See *Comfort Air Conditioning*.)

**Air, Dry:** In psychrometry, air unmixed with, or containing no, water vapor.

**Air, Saturated:** A mixture of dry air and saturated water vapor, all at the same dry-bulb temperature.

**Air, Standard:** Air with a density of 0.075 lb per cubic foot and an absolute viscosity of  $1.22 \times 10^{-5}$  lb mass per (foot) (second). This is substantially equivalent to dry air at 70 F and 29.92 in. (Hg) barometer.

**Air Washer:** An enclosure in which air is drawn or forced through a spray of water in order to cleanse, humidify, or dehumidify the air.

**Anemometer:** An instrument for measuring the velocity of a fluid.

**Aspect Ratio:** In air distribution outlets the ratio of the length of the core of a grille, face or register to the width.

In rectangular ducts the ratio of the width to the depth.

**Atmospheric Pressure:** The pressure due to the weight of the atmosphere. It is the pressure indicated by a barometer. *Standard Atmospheric Pressure* or *Standard Atmosphere* is the pressure of 76 cm of mercury having a density of 13.5951 grams per cubic centimeter, under standard gravity of 980.665 cm per (second) (second). It is equivalent to 14.696 lb per square inch or 29.921 in. of mercury at 32 F.

**Baffle:** A surface used for deflecting fluids, usually in the form of a plate or wall.

**Blast Heater:** A set of heat transfer coils or sections used to heat air which is drawn or forced through it by a fan.