

Growth and on Development, by K. D. Blackfan, C. P. Yaglou and K. McKenzie (*American Journal Diseases of Children*, 46:1175, 1933).

¹¹ Observations on the Control of Respiratory Contagion in the Cradle, by I. Rosenstern (*Aerobiology, American Association for the Advancement of Science, Symposium*, 17:242, 1942).

¹² Physical Medicine, by F. H. Krusen (W. B. Saunders Co., Philadelphia and London, 1941).

¹³ A.S.H.V.E. RESEARCH REPORT No. 1054—Fever Therapy Induced by Conditioned Air, by F. C. Houghten, M. B. Ferderber, and Carl Gutberlet (A.S.H.V.E. TRANSACTIONS, Vol. 43, 1937, p. 131). A.S.H.V.E. RESEARCH REPORT No. 1161—Fever Therapy Locally Induced by Conditioned Air, by M. B. Ferderber, F. C. Houghten and Carl Gutberlet (A.S.H.V.E. TRANSACTIONS, Vol. 46, 1940, p. 307).

¹⁴ Refrigeration for Anesthesia and Therapy, by L. W. Crossman and S. K. Safford (*The Modern Hospital*, 64:86, 1945).

¹⁵ The Effect of Low Relative Humidity and Constant Temperature on Pollen Asthma, by B. Z. Rappaport, T. Nelson, and W. H. Welker (*Journal of Allergy*, 6:111, 1935).

¹⁶ Hospital Air Conditioning, by C. P. Yaglou (*The Environment and Its Effect Upon Man, Harvard School of Public Health*, p. 244, 1939).

¹⁷ Principles and Practices of Inhalational Therapy, by A. L. Barach (J. B. Lippincott Co., Philadelphia, London, Montreal, 1944).

¹⁸ The Management of Pneumonia, by J. G. M. Bullowa (*Oxford University Press*, p. 260, 1937).

¹⁹ What Are the Right Conditions for Comfort Cooling, by Cyril Tasker (*Heating, Piping, and Air Conditioning*, Aug., 1948, p. 84).

²⁰ Odors Physiology and Control, by C. P. McCord and Wm. R. Witheridge (McGraw-Hill Book Co., New York, 1949).

BIBLIOGRAPHY

Studies in Air Hygiene, by R. B. Bourdillon, O. M. Lidwell and J. E. Lovelock with W. C. Cawston, L. Colebrook, F. P. Ellis, M. Vanden Ende, R. E. Glover, A. M. Macfarlan, A. A. Miles, W. F. Raymond, E. Schuster and J. C. Thomas (*Medical Research Council of Great Britain*, 1948. Special Report Series No. 262).

Ultraviolet Irradiation with Artificial Illumination, by Hans E. Ronge, Uppsala, Sweden, 1948, 191 pages.

L'Hygiene du Batiment per L'Ultra-violet, by P. A. Burrucand, Centre Scientific et Technique du Batiment, Paris, 1949.

Acceptance of Ultraviolet Lamps for Disinfecting Purposes, Council of Physical Therapy (*Journal American Medical Association*, 122:503-504, 1943).

Evaluation of Methods to Control Airborne Infection, by J. E. Perkins (*American Journal Public Health*, 35:891-897, 1945).

The Present Status of the Control of Airborne Infections, by Committee on Evaluation of Methods to Control Airborne Infections of the American Public Health Association (*Journal American Public Health Association*, 37:13-22, 1947).

Progress in the Control of Airborne Infections, by Sub-Committee on Air Sanitation of the American Public Health Association, read at Annual Meeting, 1949. To be published.

CHAPTER 8

AIR CONTAMINANTS

Classification of Air Contaminants; Sizes of Airborne Particles; Air Pollution by Smoke, Ash and Cinders; Smoke Abatement and Air Pollution Control; Odor Nuisance; Maximum Allowable Concentrations of Industrial Air Contaminants; Flammable Gases and Vapors; Combustible Dusts; Atmospheric Pollen; Airborne Bacteria

THE normal constituents of the earth's atmosphere are oxygen, nitrogen, carbon dioxide, water vapor, argon, small or negligible amounts of other inert gases, hydrogen, variable traces of ozone, and small quantities of microscopic and submicroscopic solid matter, sometimes called *permanent atmospheric impurities*. From the viewpoint of the air conditioning engineer, all other airborne substances may be termed *contaminants*. This term is applied preferably, however, to undesirable or chance impurities, since the occasion may arise for adding to the air controlled amounts of solid or gaseous diluents for the prevention of explosions; germicidal vapors or mists (aerosols) for bacteria control; masking substances for odor control; or a substitute for one of the normal gases, as, for example, when helium is used to replace nitrogen in atmospheres for compressed air workers or divers.

Control of the chemical quality of air is one of the functions of complete air conditioning, and some knowledge of the composition, concentration and properties of air contaminants under various circumstances is therefore essential.

Air contaminants arise from the normal processes of wear, erosion, windstorm, sea-spray evaporation, thermal disintegration, earthquake, volcanic eruption, combustion, manufacturing, transportation, agriculture, and the biochemical or biological processes of life. They are classified at various times as organic and inorganic, visible or invisible, microscopic or macroscopic, particulate or gaseous, toxic or harmless, beneficial or destructive. The following classification is based chiefly upon the origin or method of formation of air contaminants.

CLASSIFICATION OF AIR CONTAMINANTS

Dusts, Fumes, and Smokes are solid particulate air contaminants.

Dusts are solid particles projected into the air by natural forces, such as wind, volcanic eruption or earthquake, and by mechanical processes, such as crushing, grinding, milling, drilling, demolition, shovelling, conveying, screening, bagging and sweeping. Some of these forces produce dust from larger masses, while others simply disperse materials that are already pulverized. Generally, particles are not called dust unless they are smaller than about 100 microns. Dusts may be of *mineral* type, such as rock, ore, metal, sand; *vegetable*, such as grain, flour, wood, cotton, pollen; or *animal*, such as wool, hair, silk, feathers, leather.

Fumes are solid particles commonly formed by the condensation of vapors from normally solid materials such as molten metals. Metallic fumes generally occur as the oxides in air because of the highly reactive nature of finely divided matter. Fumes may also be formed by sublimation, distillation, calcination, or chemical reaction, whenever such processes create airborne particles predominately below the 1 micron size. Fumes permitted to age tend to flocculate into clumps or aggregates of larger size, thereby facilitating removal from air.

Smokes are the extremely small solid particles produced by incomplete combustion