

NOTICE: If the film image is less clear than this notice, it is due to the quality of the document being reproduced.

CONFIDENTIAL

000733

MATERIAL 8407 (Stating Dash Number 41062) August 20, 1955
CEMENT, HEAT INSULATING (PLASTIC INSULATION)
SPECIAL MATERIA OR SOUTH PHILADELPHIA ONLY
FURNISHED BY - (for 8407-1)

- (A) Baldwin-Hill Co, 500 Klapp Ave, Dayton 2, N J
- (B) Eagle Picher Sales Co, American Bldg, Cincinnati 1, Ohio
- (C) Johns-Manville, 22 E 40th St, N Y C 16

ORDER FROM SUPPLIER AS

- (For 8407-1) (A) Baldwin-Hill #1 Insulating Cement
- (B) Eagle Picher Super 66 Plastic Insulation
- (C) J-M #30 Insulating Cement

CHARACTERISTICS - (8407-1) (J-M #30) Loose fibrous heat insulating cement, composed of black mineral wool derived from slag, asbestos fiber and clay binder, applied by mixing with water, and throwing into position by hand, and troweling smooth as desired.

Serviceable to 527 C (1200 F) and is 100% reclaimable for reapplication when temperature of 649 C (1200 F) has not been exceeded.

APPLICATION - Plastic heat insulating cement for steam turbines and steam piping.

SPECIFY AS CEMENT 8407-1

Issued by Matl & Sld Engrg Dept., E Pgh, Pa
Printed in U.S.A.

DOCUMENTS PRODUCED DALLAS COUNTY CASES 3/18/92

PLAINTIFF'S
EXHIBIT