

ELECTRICAL SAFETY AND RELIABILITY AUDIT CHECK LIST
ELECTRICAL ROOMS

BUILDING NUMBER/LOCATION I.D. #: B 1512

Doors/Exits

Yes No N/A

1. Are there two means of egress from the room? ☒ ☐ ☐
2. Are the doors equipped with good working panic bars? [LPP] ☒ ☐ ☐
3. Do all doors open to the outside? ☒ ☐ ☐
4. Are the doors self closing? ☒ ☐ ☐
5. Are there warning signs posted on the doors?
(i.e. DANGER: HIGH VOLTAGE) ☒ ☐ ☐
6. Are the Exit Doors identified with Exit Lights
or Sign? ☐ ☒ ☐ *

Doors/Exits Index Score: 4

Lighting

Yes No N/A

1. Is lighting in good condition and lighting
level adequate? ☒ ☐ ☐
2. Are all lamps burning? ☒ ☐ ☐
3. Is there a good working emergency lighting
system? [LPP-356] ☒ ☐ ☐
4. Is the Exit Sign Lighting working? ☐ ☐ ☒

Lighting Index Score: 3

Environment

Yes No N/A

1. Is the air conditioning system in good working
condition? (Temperature, Humidity) ☒ ☐ ☐
2. Is the air conditioning system isolated for
switch room service only? ☒ ☐ ☐

THE DOW CHEMICAL COMPANY
ELECTRICAL TECHNOLOGY
GLOBAL

ADMINISTRATIVE GUIDELINE
G7A-0099-02
14-JUN-1996
PAGE 2 OF 5

3. Is the noise level acceptable? ☒ ☐ ☐
4. Are measures taken to keep water/ice out of the room or cable cellar effective? ☒ ☐ ☐
5. Are openings in the walls, ceilings, floor, or cable cellar properly sealed? ☒ ☐ ☐

Environment Index Score: 3

Housekeeping

Yes No N/A

1. Is the room clean and uncluttered? ☒ ☐ ☐
2. Is the floor vacuumed instead of swept with broom? (Broom stirs dust) ☒ ☐ ☐

Housekeeping Index Score: 3

Access

Yes No N/A

1. Is there adequate access and clearances for the electrical equipment? ☒ ☐ ☐
2. Is the cable cellar easily accessible? ☒ ☐ ☐

Access Index Score: 3

Drawings

Yes No N/A

1. Is SEOLD posted properly in the room? ☒ ☐ ☐
2. Are drawing accurate and up to date? ☐ ☒ ☒ *

Drawings Index Score: X

DO A 045015
CONFIDENTIAL

Labeling

Yes No N/A

1. Is the room identified with a formalized building number?
2. Is the equipment in the room adequately labeled?

☒ ☐ ☐
☒ ☐ ☐

Labeling Index Score:

3

Fire Protection

Yes No N/A

1. Is the room separated from control room with a 2 hour fire barrier wall? [LPP]
2. Is there a smoke and/or fire detection system in the room? [LPP-356]
3. Is the Smoke and/or Fire Detection System annunciated?
4. Are all wall-penetrations closed with Fire Stop materials? [LPP]
5. Is the room free of stored combustible materials?
6. Are the proper fire extinguishers located in the room?
7. Does room have fire retardant walls and doors to oil-filled transformers or process area?

☒ ☐ ☐
☒ ☐ ☐
☒ ☐ ☐
☒ ☐ ☐
☒ ☐ ☐
☒ ☐ ☐
☒ ☐ ☐

Fire Protection Index Score:

3

BATTERY/UPS SYSTEMS

Yes No N/A

1. Is there a preventive maintenance schedule for UPS systems, Battery Banks, and Battery Chargers? ___ ___ ☒
2. Is the battery rack grounded? ___ ___ ☒
3. Are the battery posts and terminals free of corrosion? ___ ___ ☒
4. Is the battery charger in good working condition? ___ ___ ☒
5. Is the battery room or location designed according to the appropriate standards? ___ ___ ☒
6. Do batteries have the proper water level? ___ ___ ☒

Battery/UPS Systems Index Score: N/A

Other

Yes No N/A

1. Is there Flash protection clothing/equipment in the room? ☒ ___ ___
2. Has all process piping been routed outside the switch room? ☒ ___ ___
3. Is there a written set of Electrical Emergency plans for various situations like loss of power, fire, or smoke in the room? [LPP] ☒ ___ ___
4. Is there room to grow? ☒ ___ ___
5. Is there a preventive maintenance schedule for the room? ☒ ___ ___
6. Are the cable raceways in the room/cable cellar in good shape? ☒ ___ ___
7. Are the cable raceways in the room/cable cellar overloaded? ☒ ___ ___
8. Are all the cable raceways in the room/cable cellar properly loaded? ☒ ___ ___

Yes No N/A

9. Are there appropriate clearing procedures and operating procedures for electrical equipment in the room? ✓
10. Is communication equipment available in the room? ✓
11. Is the steel structure of the room properly grounded? ✓
12. Is there a ground bar available in the room/cable cellar? ✓

Other Index Score: 3

Electrical Rooms Average Index Score: 4