

Bell Laboratories

600 Mountain Avenue
Murray Hill, New Jersey 07974
Phone (201) 582-3500

March 10, 1980

Mr. D. D. McArtney
New Jersey Bell Telephone Company
540 Broad Street
Room 502
Newark, New Jersey 07101

Dear Dave:

The bulk sample you mailed to Mr. W. J. Schreibeis taken from steel I beams at Oxydental Products, 6 Hoffman Street, Irvington, New Jersey, has been analyzed for asbestos. Analysis by x-ray diffraction revealed that the principal crystalline component of this sample is chrysotile asbestos.

If you have any questions about this analysis, please give me a call at (201) 582-7512.



David Rainer
Field Industrial Hygienist

MH-8685-DR-sma

Ref: 1141

Copy to

A. B. Goetze - NJB

J. P. Bisgeier, M.D.

R. L. Beach - AT&T

N. J. DeCapua

J. M. Degen

R. W. Stone, M.D.

THIS COPY FOR

W. J. Schreibeis

G. M. Wilkening

CONFIDENTIAL

003597