

## NOTES FOR TABLE 7.

- <sup>a</sup> The inside-outside temperature difference is 70-(-10) or 80 F except where otherwise noted.
- <sup>b</sup> Volume of infiltration, cfm = (no. air changes) x (floor or ceiling area) x (ceiling height).
- <sup>c</sup> From Equation 5a.
- <sup>d</sup> The ceiling heat losses are calculated by estimating the attic temperature and then calculating the loss through the ceiling using the proper temperature difference. This unheated attic is not ventilated during winter months. The attic temperature is estimated from Equation 1 to be 30.2 F when the outside temperature is -10 F and room temperature is 70 F. The temperature difference is then 70-30.2 or 39.8 deg. For the insulated residence, attic temperature becomes 4.6 F and temperature difference 70-4.6 = 65.4 deg.
- <sup>e</sup> Temperature in garage assumed to be 35 F.
- <sup>f</sup> Coefficient for wall adjoining garage calculated on basis of metal lath and plaster on both sides of studs (U = 0.39).
- <sup>g</sup> One half of value from Table 4, Chapter 11, for storm windows or weatherstripping.
- <sup>h</sup> Exposed on two sides, weatherstripped windows offset by fire-place. Use 1½.
- <sup>i</sup> Window on one side weatherstripped but double-doors are hard to close tightly. Hence, conservative value of 1½.
- <sup>j</sup> Assuming kitchen vent, door to vestibule usually open, allow full table value of 1½.
- <sup>k</sup> One-half value in Table 4, Chapter 11, increased to 1½ by nearby outside door in vestibule.
- <sup>l</sup> Full value in Table 4, Chapter 11, to allow for frequent opening of outside door.
- <sup>m</sup> Two sides exposed, large doors but large volume. Use value 1½ as given in Table 4, Chapter 11.
- <sup>n</sup> Two small unweatherstripped windows in protected location, but fireplace, indicate 1 change.
- <sup>o</sup> Heat losses from these rooms into garage are heat gains for garage.
- <sup>p</sup> Neglect heat loss to basement, as losses from boiler, piping, etc., will probably keep basement near, if not above, 70 F.
- <sup>q</sup> Upstairs hall ceiling figures with downstairs. Heat should be provided downstairs for both.
- <sup>r</sup> Linear feet of exposed edge.

TABLE 8. SUMMARY OF HEAT LOSSES OF UNINSULATED RESIDENCE (Btu Per Hour)

| ROOM OR SPACE                 | WALLS              | CEILING AND ROOF   | FLOOR | GLASS AND DOOR | INFILTRATION | TOTALS  |
|-------------------------------|--------------------|--------------------|-------|----------------|--------------|---------|
| Bedroom A                     | 5330               | 6910               | ...   | 1440           | 2180         | 15,860  |
| Bedroom B                     | 3490               | 4660               | ...   | 1440           | 1470         | 11,060  |
| Bedroom C                     | 2560               | 3540               | ...   | 970            | 1260         | 8,330   |
| Bedroom D                     | 2650               | 3020               | 960   | 720            | 950          | 8,300   |
| Bathroom 1                    | 670                | 1510               | ...   | 500            | 630          | 3,310   |
| Bathroom 2                    | 1640               | 960                | 310   | 320            | 400          | 3,630   |
| Living Room                   | 7260               | ...                | ...   | 1800           | 5400         | 14,460  |
| Dining Room                   | 3720               | ...                | ...   | 3100           | 3080         | 9,900   |
| Kitchen                       | 2850               | ...                | ...   | 950            | 2300         | 6,100   |
| Lavette                       | 3000               | ...                | ...   | 1100           | 550          | 4,650   |
| Entrance Hall                 | 870                | 2390               | ...   | 640            | 1600         | 5,500   |
| Garage                        | -1030 <sup>a</sup> | -1270 <sup>b</sup> | 1060  | 3710           | 1910         | 4,380   |
| Recreation                    | 840                | ...                | 570   | 720            | 2890         | 5,020   |
| Design Totals                 | 33,650             | 21,720             | 2,900 | 17,410         | 24,620       | 100,500 |
| Operating Totals <sup>c</sup> | 33,850             | 21,720             | 2,900 | 17,410         | 12,310       | 88,190  |
| Percentages <sup>d</sup>      | 38.4               | 24.6               | 3.3   | 19.7           | 14.0         | 100.0   |

<sup>a</sup> Wall heat loss of 2110 Btuh minus wall heat gains of 1280, 700 and 1160 Btuh. <sup>b</sup> Heat gains of 960 and 310 Btuh. <sup>c</sup> Based on ½ computed infiltration. <sup>d</sup> Based on operating totals.

TABLE 9. SUMMARY OF HEAT LOSSES OF INSULATED RESIDENCE (Btu Per Hour)

| ROOM OR SPACE                 | WALLS             | CEILING AND ROOF  | FLOOR | GLASS AND DOOR | INFILTRATION | TOTALS |
|-------------------------------|-------------------|-------------------|-------|----------------|--------------|--------|
| Bedroom A                     | 2480              | 2460              | ...   | 1440           | 2180         | 8,560  |
| Bedroom B                     | 1620              | 1660              | ...   | 1440           | 1470         | 6,190  |
| Bedroom C                     | 1190              | 1260              | ...   | 970            | 1260         | 4,680  |
| Bedroom D                     | 1230              | 1080              | 690   | 720            | 950          | 4,670  |
| Bathroom 1                    | 310               | 540               | ...   | 500            | 630          | 1,980  |
| Bathroom 2                    | 760               | 250               | 220   | 320            | 400          | 1,950  |
| Living Room                   | 3370              | ...               | ...   | 1800           | 5400         | 10,570 |
| Dining Room                   | 1730              | ...               | ...   | 3100           | 3080         | 7,910  |
| Kitchen                       | 1320              | ...               | ...   | 950            | 2300         | 4,570  |
| Lavette                       | 1390              | ...               | ...   | 1100           | 550          | 3,040  |
| Entrance Hall                 | 410               | 850               | ...   | 640            | 1600         | 3,500  |
| Garage                        | -470 <sup>a</sup> | -910 <sup>b</sup> | 1060  | 3710           | 1910         | 5,300  |
| Recreation                    | 840               | ...               | 570   | 720            | 2890         | 5,020  |
| Design Totals                 | 16,180            | 7,190             | 2,540 | 17,410         | 24,620       | 67,940 |
| Operating Totals <sup>c</sup> | 16,180            | 7,190             | 2,540 | 17,410         | 12,310       | 55,630 |
| Percentages <sup>d</sup>      | 29.1              | 12.9              | 4.6   | 31.3           | 22.1         | 100.0  |

<sup>a</sup> Wall heat loss of 980 Btuh minus wall heat gains of 590, 320 and 540 Btuh. <sup>b</sup> Heat gains 690 and 220 Btuh. <sup>c</sup> Based on ½ computed infiltration. <sup>d</sup> Based on operating totals.

actual heating installation (exclusive of heat sources) be reduced below that required to maintain at least 40 F in the building.

## Electric Motors and Machinery

Motors and the machinery which they drive, if both are located in the room, convert all of the electrical energy supplied into heat. This heat is retained in the room if the product manufactured is not removed until its temperature is the same as the room temperature.

If power is transmitted to the machinery from the outside, then only the heat equivalent of the brake horsepower supplied is used. In some mills this is the chief source of heating, and it is frequently sufficient to overheat the building even in zero weather, thus requiring cooling by ventilation the year 'round. Table 6 shows the heat output equivalent of various sources of heat in a factory. For information concerning the heat supplied by persons, refer to data given in Chapter 6, and also Table 25, Chapter 13. For appliances see Table 26, Chapter 13.

## INTERMITTENTLY HEATED BUILDINGS

In the case of intermittently heated buildings additional heat is required for raising the temperature of the air, the building materials and the material contents of the building to the specified inside temperature. The rate at which this additional heat must be supplied depends upon the heat capacity of the structure and its material contents, and upon the time in which these are to be heated.<sup>15</sup>

This additional heat may be computed and allowed for as conditions require, but inasmuch as the heating system proportioned for taking care of the heat losses will usually have a capacity about 100 percent greater than that required for average winter weather, and inasmuch as most buildings may either be continuously heated or have more time allowed for heating up during the few minimum temperature days, no allowance usually is made, except in the size of boilers or furnaces. For churches, auditoriums and other intermittently heated buildings, additional capacity should be provided.

## RESIDENCE HEAT LOSS PROBLEMS

**Example 6:** Calculate the heat loss of the residence shown in Fig. 3 located in the vicinity of Chicago. From Table 1, design outdoor conditions are -10 F and 12 mph wind velocity. Inside temperature from Table 2 is assumed to be 70 F. The attic is unheated. Assume ground temperature to be 50 F (see Fig. 3, Chapter 35) under basement and garage floors and 32 F adjoining basement walls. Estimate infiltration losses by the air change method. No wall, ceiling or roof insulation is to be considered in this problem, but all first and second floor windows, except in the garage, are to have storm sash. The building is constructed as follows (heat transmission coefficients U are parentheses):

**Walls:** Brick veneer, building paper, wood sheathing, studding, metal lath and plaster (0.28). Walls of dormer over garage, same except wood siding in place of brick veneer (0.26).

**Attic Walls:** Brick veneer, building paper, wood sheathing on studding (0.42).

**Basement Walls:** 10 in. concrete (0.10).

**Roof:** Asphalt shingles on wood sheathing on rafters (0.53).

**Ceiling (Second floor):** Metal lath and plaster (0.69).

**Windows:** Double-hung wood windows averaging 70 percent glass (0.45; from Chapter 9, Table 19, Section D, the U value for wood windows with storm sash is 0.53 x application factor; by interpolation this factor is 0.85). Steel casement sash in garage and basement (1.13; from Chapter 9, Table 19, U is 1.13 for all glass and the