

bcc: RD/RD/AGE/SS
C. L. Bradford - CERAD
T. C. Tupper - TTUPP
C. P. Duncker - CDUNC

October 21, 1966

Mr. George Pierce
Charles Pfizer Company, Vigo Plant
Terre Haute, Indiana

Dear Mr. Pierce:

The following results are reported for a sample of THERMINOL FR-2
submitted for evaluation 9/28/66:

<u>TEST</u>	<u>9/28/66 Sample</u>	<u>New FR-2 Specifications</u>
Viscosity 100°F., Centistokes	47	53 Max
Acid No. mgKOH/g	0.01	0.01 Max
Moisture PPM	35	50 Max
Nitrolier %	0.01	None

Mr. Pierce, the fluid analyzed is within specifications for new fluid,
and is recommended for continued use. May I recommend that you
send another sample for analysis about June or July 1967?

If we can be of further assistance, please contact Larry Bradford or
me in St. Louis.

Very truly yours,

✓
D. E. Roush
Technical Specialist
Heat Transfer Fluids

/ecd

DSW 435156

STLCOPCB4088217