

DATE: WEEK OF 9/22/78
THRU
9/28/78

118

AVERAGE AUCM LEVELS - BLDGS. 1, 111, 115, AND 121

G. C. READINGS

	TOTAL # SPLS.	BETWEEN 1 AND 3 PPM INCLUSIVE		BETWEEN 3 AND 100 PPM INCLUSIVE		GREATER THAN 100 PPM	
		#	%	#	%	#	%
<u>BUILDING 1</u>							
<u>ALARM READINGS</u>							
FLOOR A	1932	331	17.13	24	1.24	0	0.00
FLOOR B	1932	44	2.28	25	1.30	0	0.00
FLOOR C	1932	68	3.52	21	1.09	0	0.00
TOTAL	5796	443	7.64	70	1.21	0	0.00
3 RD FLOOR CONTROL RM.	966	2	0.21	0	0.00	0	0.00
VENT AIR ENTRY	966	7	0.73	1	0.10	0	0.00
STAIRWELL	966	5	0.52	3	0.31	0	0.00
BREATHING AIR	966	0	0.00	0	0.00	0	0.00
% UPTIME FOR WEEK = 96.1 %							
<u>BUILDING 111</u>							
<u>ALARM READINGS</u>							
FLOOR A	999	14	1.40	5	0.50	0	0.00
FLOOR B	1998	67	3.35	45	2.25	0	0.00
FLOOR C	1998	177	8.86	41	2.05	1	0.05
TOTAL	4995	258	5.17	91	1.82	1	0.02
3 RD FLOOR CONTROL RM.	999	6	0.60	3	0.30	0	0.00
VENT AIR ENTRY	999	19	1.90	9	0.90	0	0.00
BREATHING AIR	999	7	0.70	1	0.10	0	0.00
ROOF	999	4	0.40	2	0.20	0	0.00
% UPTIME FOR WEEK = 99.6 %							
<u>BUILDING 115</u>	999	109	10.91	13	1.30	0	0.00
% UPTIME FOR WEEK = 99.6 %							
<u>BUILDING 121</u>							
<u>ALARM READINGS</u>							
FLOOR A	1766	218	12.34	50	2.83	0	0.00
FLOOR B	1766	248	14.04	79	4.47	0	0.00
FLOOR C	1766	246	13.93	174	9.85	0	0.00
TOTAL	5298	712	13.44	303	5.72	0	0.00
3 RD FLOOR CONTROL RM.	883	2	0.23	2	0.23	0	0.00
VENT AIR INTAKE	883	19	2.15	6	0.67	0	0.00
BEFORE BREATHING	883	1	0.11	1	0.11	0	0.00
AIR FILTER							
AFTER BREATHING	883	3	0.34	1	0.11	0	0.00
AIR FILTER		% UPTIME FOR WEEK = 87.4 %					