

nmc National Medical Care, Inc.**ASBESTOS ACTION NOTIFICATION INFORMATION**

1. DATE OF NOTIFICATION:
May 31, 1990
2. GROUP:
Health Care Group - National Medical Care, Inc.
3. DIVISION:
Dialysis Services Division
4. FACILITY INVOLVED:
BMA Augusta
1109 Medical Center Drive, Bldg. #6
Augusta, GA 30909
5. FACILITY MANAGER:
Cone Underwood
BMA Augusta
1109 Medical Center Drive, Bldg. #4A
Augusta, GA 30909
6. PRIMARY CONTACT:
Lawrence K. Park
(617) 466-9850 ext. 467 (business)
(617) 890-6473 (Fax)
7. TYPE OF MATERIAL:
Floor tiles and mastik/textured ceiling paint.
8. LOCATION WITHIN FACILITY:
Ground Floor
Future Dialysis Treatment Area - Green Vinyl Flooring
and Mastik Floor Tile/Textured Ceiling Paint
Stock Room/Water Treatment/Reuse Area - Mastik
9. APPROXIMATE DATE OF INSTALLATION (if known):
Redone in 1985.

nmc National Medical Care, Inc.

10. APPROXIMATE QUANTITY/EXTENT OF MATERIAL:

Green Vinyl Flooring and Mastik Floor
Tile - 800 square feet
Textured Ceiling Paint - 30 square feet
Mastik - 800 square feet

11. PRESENT CONDITION: Description of inspection/testing to date:

- (a) 12 x 12 Pink Floor Tile and Mastik
 - o 2% chrysotile asbestos; 8% cellulose;
58% filter/binder; 20% quartz, 12% mastik
- (b) Textured Paint Ceiling
 - o 4% chrysotile asbestos; 96% nonfibrous materials
- (c) 12 x 12 Gray Tile and Mastik
 - o 2% chrysotile asbestos, 8% cellulose,
90% nonfibrous materials
- (d) Green Vinyl Flooring and Mastik
 - o 10% chrysotile asbestos; 15% cellulose;
75% nonfibrous materials

Testing date: 3/20/90

Please see attachment for more information.

12. Action has "not yet commenced" but is scheduled to commence upon Grace approval.

13. DESCRIPTION OF SCOPE AND COST OF ACTION TAKEN/PLANNED TO BE TAKEN

As part of the BMA Augusta relocation project for the self care unit, there is a need to do floor cutting and removal of walls.

During this process, the green vinyl floor and mastik floor tile which contains the chrysotile asbestos will need to be disturbed and the textured ceiling paint (containing chrysotile asbestos) will need to be disturbed due to the removal of a wall.

14. DATE(S) ACTION TAKEN/PLANNED TO BE TAKEN:

As soon as possible. Awaiting Grace's approval.

15. REASON(S) FOR ACTION:

Relocation of self-care unit.

nmc National Medical Care, Inc.

16. CONTRACTOR(S) INVOLVED - NAME, ADDRESS, PHONE, FUNCTION
OF EACH:

Asbestos management consultant:

(a) Marshall Clark Architects, Inc.
5 Century Drive, Suite 220
Greenville, SC 29607

Attn: Jason Smith
(803) 232-8204
Fax # 803-370-9359

Firm that tested the air samples supplied by the
architect:

(b) Enviro Sciences, Inc.
187 N. Church Street
Spartanburg, SC 29403

Contact: Mr. Andy Schauder
803-585-4900

Firm that will do the removal is:

(c) Augusta Environmental - Lic.# 90L045 expires 4/30/91
P.O. Box 1633
Augusta, GA 30903

Contact: Gisele Morris
404-724-6222