

Fig. 7.... Equivalent Length of Fittings and Intakes



EQUIVALENT LENGTH (FEET) FOR REGISTERS IN GROUP 7.

Deflection Angle A	0°	15°	22°	30°	45°
Baseboard, High or Low Sidewall Reg.	35	40	45	60	115
Floor Reg. with Box only	25				

For 2-way deflection registers, add the vertical and horizontal deflection angles together and multiply by 0.7. Select closest angle A.

Fig. 7.... Equivalent Length of Fittings and Intakes (*Concluded*)