Monsanto

FROM (NAME & LOCATION) R. McEntire - WGK

DATE October 12, 1971

cc: R. Blowers
H. Horner
H. Campbell

SUBJECT

REFERENCE

TO W. Engman
C. Buckley
J. Munoz
R. McCutchan
A. Rasmussen

COMPANY CONFIDENTIAL

The amount and type of PCB obtained in recent water samples are reported below. Results are in parts per billion (ppb) unless otherwise noted.

Log No.	Date	Sample Description	(ppb) PCB	Type
849	9/12	1-B 4 day Comp.	49	1248
			38	1254
850	9/12	2-A 4 day Comp.	14	1242
			5	1260
851	9/12	5-E 4 day Comp	16	1242
			8	1254
852	9/12	5-KI 4 day Comp	9	1242
			5	1254
853	9/15	WTP Inf.	151	1242
			142	1260
854	9/15	WTP Eff	76	1242
			66	1260
855	9/16	1-B Comp	74	1242
			64	1254
856	9/16	2-A Comp	11	1248
			7	1260
857	9/16	5-E Comp	33	1248
			14	1260
858	9/16	5-KI Comp	8	1242
			4	1254
859	9/16	PNA-831	12	1242
			9	1254
860	9/19	WTP Inf	94	1242
			24	1254
861	9/19	WTP Eff	88	1242
			39	1254
862	9/19	4-Z	21	1242
			5	1260
863	9/14	(1-C-1)	12	1242
864	9/14	3-E	2	1242
			2	1260
865	9/14	1-B	5	1242
			5	1260
866	9/16	3-B	2	1242
			2	1254
867	9/14	2-A	3	1242
			2	1254

MONS 098810

Log No.	Date	Sample Description	(ppb) PCB	Type
868	9/14	2-N	2	1242
			3	1254
869	9/14	WTP Inf	112	1242
			46	1254
870	9/14	WTP Eff	63	1242
			37	1254
871	9/19	1-B Comp	28	1248
			48	1254
872	9/19	2-A Comp	9	1242
			3	1254
873	9/19	5-E Comp	15	1242
			11	1254
874	9/19	5-KI Comp	8	1248
875	9/22	Inf	139	1242
			38	1254
876	9/22	Eff	44	1242
			18	1254
877	9/22	2A Special	721	1242
			136	1254
878	9/22	2A	10	1242
			4	1254
879	9/22	2A Comp	19	1242
			7	1254
880	9/22	1-B	21	1248
			18	1254
881	9/22	5K1	4	1242
			2	1254
882	9/22	5E	23	1242
			12	1254
883	9/23	2A	18	1242
			4	1254
884	9/23	2A Special	446	1242
			79	1254
885	9/24	SVO Mon.Tue.Wed.Comp.	88	1242
			19	1254
886	9/23	246 Column Jt 8 am	unable to run free PCB	
887	9/23	246 column jet 9:30 a.m	unable to run free PCB	
888	9/23	246 Column jet 8 am	unable to run free PCB	
890	9/26	WTP Eff	168	1242
			14	1254
891	9/26	WTP Inf	145	1242
			15	1254
892	9/26	4-Z	19	1242
893	9/26	1-B	34	1248
			19	1254
894	9/26	2-A	34	1242
			33	1260
895	9/26	5-E	2	1242
889	9/24	246 Column jet 8 am	1	1254
			unable to run free PCB	

Log No.	Date	Sample Description	(ppb) PCB	Type
896	9/26	5=KI	9	1242
			6	1254
897	9/29	WTP Inf	43	1242
			11	1254
898	9/29	WTP Eff	70	1242
			20	1254
899	9/29	1-B Comp	19	1242
			8	1254
900	9/29	1-B Special	99	1242
			103	1254
901	9/30	1-B Special	29	1248
			6	1254
902	9/30	1-B	14	1242
903	9/30	SVO	38	1242
			7	1254
904	9/30	Eff	25	1242
			6	1254
905	10/3	4-Z	28	1242
			4	1254
906	10/3	WTP Inf	25	1242
			7	1254
907	10/3	WTP Eff	35	1242
			10	1254
908	9/29	1-B	32	1248
			13	1260
909	9/29	2-A	37	1242
			12	1260
910	9/29	4-Z	29	1242
			10	1260
911	9/29	5-E	29	1242
			12	1254
912	9/29	5-KI	8	1248
			3	1254
913	10/3	1-B	27	1248
			17	1260
914	10/3	2-A	43	1242
			34	1260
915	10/3	5-E	30	1242
			9	1254
916	10/3	5-KI	14	1248
			17	1260
917	10/6	Well water	7	1242
			2	1254
918	10/6	WTP Inf	217	1242
			71	1254
919	10/6	WTP Eff	70	1242
			12	1254
920	10/6	1-B	78	1242
			17	1254
921	10/6	2-A	35	1242
			8	1254
922	10/6	5-E	40	1242
			16	1254
923	10/6	5-KI	5	1242
			2	1260

MONS 098812

Log No.	Date	Sample Description	(ppb) PCB	Type
924	10/10	Inf	185	1242
			35	1254
925	10/10	Eff	70	1242
			12	1254
92610/10	2-A Comp		36	1242
			13	1260
927	10/10	1-B Comp	26	1248
			12	1260
928	10/7	2-K	12	1242
			14	1260
929	10/10	4-Z	34	1242
			8	1254

R. McEntire

dy