

NOTICE: If the ink image above is less clear than this
notice, it is due to the quality of the document being reproduced.

CONFIDENTIAL 51

8407

MATERIAL 8407 (Stating Dash Number) C.3500 June 5, 1946
CEMENT, HEAT INSULATING (PLASTIC INSULATION)
SPECIAL MATERIAL FOR SOUTH PHILADELPHIA ONLY

PUBLISHED BY -
(For 8407-1) (A) Baldwin-Hill Co., 2000 Klapp Ave., Trenton (2), N.J.
(B) Eagle Rubber Sales Co., American Bldg., Cincinnati (1)

ORDER FROM SUPPLIER -
(For 8407-1) (A) Baldwin-Hill #1 Insulating Cement.
(B) Eagle Rubber Super 68 Elastic Insulation.

CHARACTERISTICS - 8407 is a loose fibrous heat insulating cement,
composed of black mineral wool derived from slag, asbestos fiber
and clay binder, applied by mixing with water and throwing into
position by hand, and troweling smooth as desired.
Serviceable to 1200°F and is 100% reclaimable for
reapplication when a temperature of 645°C (1200°F) has not been
exceeded.

APPLICATION - Elastic heat insulating cement for steam turbines
and steam piping.

SPECIFY IN ORDER - 8407-1

Issued by Mills & White Inc., Eng. Lab. & Sales Dept., East Pgh., Pa.
Supersedes Mat'l 8407, dated 4-27-41
Printed in U.S.A.

DOCUMENTS PRODUCED DALLAS COUNTY CASES 3/18/92

PLAINTIFF'S
EXHIBIT
WH-57