



INTERNAL
CORRESPONDENCE

FILED

PLAINTIFF'S EXHIBIT

UC-3174

UNION CARBIDE CORPORATION TECHNICAL CENTER

P.O. BOX 8361, SOUTH CHARLESTON WV 25303

To (Name) J. D. McCue

Division

Location

Area

Date April 23, 1986

Originating Dept HS&EA

Area Industrial Hygiene

Copy to
B. Brabbin
C. P. Maxwell
M. A. Patel
C. L. Ruddle
A. F. Terry

Subject Asbestos Testing

Attached are the results of the tests requested by you for Asbestos, taken from 3 different lines that have the outer coating disturbed in the basement of building 701. One sample was taken from a line directly in front of the elevator, another from a 50 pound steam line and the last from a 200 pound steam line at the main isle where it meets the isle coming from the elevator.

All of the samples in question contain Asbestos, and must be treated as such. Industrial Hygiene must be notified before any work is done and anyone involved with the work must wear a dust mask, disposable coveralls, boots, gloves and a head sock. In addition, the area must be restricted with a barricade and posted for the Asbestos hazards. Excess water must also be used to control any fibers that may become airborne.

If you have any questions or if I can be of further assistance, please call me on extension 4779.

Vance E. Stover

Attachment

VES:rab
1229P

INSULATION ASBESTEST RESULTS FORM

<u>Sample No.</u>	<u>Date</u>	<u>Sample Submitted By</u>	<u>Sample Source</u>	<u>Results Mg Test</u>	<u>Fe Test</u>	<u>Analyzed By</u>	<u>Remarks</u>
701-B-EF	4-22-86	J. D. McCue	701 Basement in front of elevator.	-	+	VES	
701-B-50# steam line	4-22-86	J. D. McCue	701 Basement in center aisle near elevator 50# steam line.	-	+	VES	Very dark red.
701-B-200# steam line	4-22-86	J. D. McCue	701 Basement in center aisle near elevator 200# steam line.	-	+	VES	

UCC 000310

1229P