



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 2

290 BROADWAY

NEW YORK, NY 10007-1866

**By Email:** [Carrol.Theodore@trafigura.com](mailto:Carrol.Theodore@trafigura.com)

Mrs. Carrol Theodore  
Country Manager Retail/B2B  
PC Puerto Rico LLC D/B/A USVI Fuel Services  
8240 Subbase, P.O. Box 303740  
St. Thomas, U.S. Virgin Islands 00803

Subject: Underground Storage Tank(s) for: Puma Veteran's Drive Service Station  
Located at: 1 Estate Demerara, St. Thomas, U.S. Virgin Islands 00802  
Facility ID Number: 201018  
ICIS Number: 3601545283

Dear Mrs. Theodore:

Please find enclosed a copy of an inspection report where Mr. Hiep Tran of the U.S. Environmental Protection Agency, Region 2 (EPA) conducted an Underground Storage Tank (UST) Inspection on June 12, 2023, in accordance with the Resource Conservation and Recovery Act and Hazardous and Solid Waste Amendments of 1984 ("HSWA"), 42 U.S.C. § 6901 *et seq.* (collectively referred to as "RCRA" or the "Act"). Puma Veteran's Drive Service Station owns and/or operates the Underground Storage Tank(s) located at the above-mentioned facility. A "facility" as that term is defined in 40 C.F.R. § 280 is subject to the requirements of RCRA Subtitle I regulations.

This letter should not be construed as a compliance determination by the EPA of Puma Veteran's Drive Service Station with the UST regulations. However, if areas of concerns were identified, please begin rectifying them as soon as possible and make sure to keep records in accordance with the regulations.

Subsequently, my enforcement staff will review the information in our program records and from the inspection determine if further actions are necessary. Once any compliance issues are identified EPA will correspond with you in writing.

If any factual disputes are identified, or you have any questions, please contact Hiep Tran by email at: [tran.hiep@epa.gov](mailto:tran.hiep@epa.gov) or by phone at 212-637-4280.

Thank you for your cooperation.

Sincerely,

GAETANO  
LAVIGNA

Digitally signed by  
GAETANO LAVIGNA  
Date: 2023.08.03  
08:17:40 -04'00'

Gaetano LaVigna, Senior Advisor  
UST Compliance Team  
Enforcement and Compliance Assurance Division  
US EPA Region 2

Enclosure

cc: Eng. Brenda Toraño  
HSE Manager  
Puerto Rico Energy  
Box 11961  
San Juan, Puerto Rico 00922  
Email: [Brenda.Torano@energy-latam.com](mailto:Brenda.Torano@energy-latam.com)

Austin F. Callwood  
Director of Environmental Protection  
Department of Planning and Natural Resources  
4611 Tutu Park Mall, Suite 300  
St. Thomas, VI 00802  
Email: [austin.callwood@vi.gov](mailto:austin.callwood@vi.gov)



VI. Tank Information	Tank No.	1	2	3			
Tank presently in use		yes	yes	yes			
If not, date last used (see Section XII)		—	—	—			
If empty, verify 1" or less left (see Section XII)		—	—	—			
Capacity of Tank (gal)		12K	12K	6K			
Substance Stored		Ray	Prox	Diesel			
Compatibility Records Available? (Compatibility Demonstrated?)							
M/Y Tank installed/Upgraded		12/12	→				
<u>Tank Construction:</u> Bare Steel, Sti-P3, Retrofitted sacrificial anode, Impressed Current, Composite, FRP, Interior lining, Vaulted		DW	permatank				
Secondary Containment?		DW	→				
Spill Prevention [§ 280.20(c)(1)(i), § 280.21(d)]		spill bucket					
Double Walled? Y/N		DW	→	→			tested on 6/22/22
If Yes, Last Monthly Check?							submitted via email
If No, Last Triennial Containment Integrity Test?		N/A	→	→			on 6/27/23
Overfill Prevention (specify type) [§ 280.20(c)(1)(ii), § 280.21(d)]		H/A	no light, sound only				
Last Triennial Inspection?							
<u>Special Configuration:</u>		—	—	—			
Compartmentalized, Manifolder,							
Field Constructed,							
Airport Hydrant System							
VII. Piping Information							
<u>Piping Type:</u> Pressure, Suction		Pressure					
<u>Piping Construction:</u> Bare Steel, Sacrificial Anode, Impressed Current, Flex, FRP, Double-walled (DW), Non-corrodible piping		DW	Nu P	sem-Resid			
<u>Under Dispenser Containment ("UDC")? Y/N</u> If Yes, installation date?		yes	→				
Date of last visual inspection/periodic monitoring Part of Line RD? Y/N		12/12					
If above Y, UDC Double Walled? Y/N							
If DW, Last Monthly Check of Annular Space? If non-DW or no monthly check of DW, last 3-Yr Containment Integrity Test?		6/23/2022	→				

201018

Section Continues to Page 3

**VII. Piping Information**

(Continued)

Tank No.

1 2 3

Secondary Containment Sump Used for

Release Detection? Y/N

Yes →

If Yes, Is Containment Sump Single/Double Walled? (SW/DW)

For SW, or DW w/o monthly check of annular space, last 3-YR integrity check/DW sumps with monthly monitoring - Last check of Annular space?

tested 6/23/2022 →

Tank and Piping Notes:

Premium and Regular were not working - see printout

Tank No.

1 2 3

**VIII. Corrosion**

Protection (§ 280.31)

N/A

Integrity Assessment conducted prior to upgrade

Interior Lining

Interior lining inspected

Is lining sole protection? Y/N

Impressed Current

CP Test Records

60-day Rectifier inspection records

Sacrificial Anode:

CP Test Records

CP Notes: (Include notes of any Interior Lining inspection)

**IX. Release Detection (§ 280.43-Subpart D)**

N/A

Tank RD Methods

ATG

CGLD

X → ✓

Interstitial Monitoring

✓

X ✓

Groundwater Monitoring\*

Vapor Monitoring\*

Inventory Control w/ TTT

Manual Tank Gauging

Manual Tank Gauging w/ TTT

SIR

12 Months Monitoring Records (§ 280.41(a), § 280.45(b))

Must Make Available Last 12 Months For Compliance

As of 6/12/23 Premium = No method of Release Detect - see printout.

\*Site assessment/installation documentation?

N/A →

tested on 6/23/22 - submitted on 6/27/23  
RD Equipment Last Tested? (see printout)

N/A →



SITE DRAWING


DATE: 6/12/2023 TIME ON SITE: 2:30 pm TIME OFF SITE: 16:35

WEATHER: Partly cloudy / Dry

ENVIRONMENTALLY SENSITIVE AREA: Y  N

If "Yes", please describe:

Lat = 18.33920  
Long = -64.94175






Dispensers  
with  
sensors



sensor

NO liquid  
class



Diesel →



Dry



Dispensers  
1/2  
3/4

No bypass tubing for  
release detector

Pictures

209018

HVS

**X. Repairs** [§ 280.33 – Subpart C]

N/A

Repaired tanks and piping are tightness tested within 30 days of repair completion

Y  N  Unknown

CP systems are tested/inspected within 6 months of repair of any cathodically protected UST system

Y  N  Unknown

Records of repairs are maintained

Y  N  Unknown

**“Overfill/Spill/Secondary Containment systems are tested/inspected within 30 days of repair”**

**XI. Temporary Closure** [§ 280.70 – Subpart G]

N/A

CP continues to be maintained

Y  N  Unknown

UST system contains product and release detection is performed

Y  N  Unknown

Cap and secure all lines, pumps, manways

Y  N  Unknown

**XII. Release History** [§ 280.50 – Subpart E]

N/A

To your knowledge, are there any public or private Drinking Water Wells in the vicinity? Yes / No

Evidence of release or spills at facility

Evidence of release in the surrounding area to the facility

Greater than 25 gallons (estimate)

Releases reported to implementing agency; if so, date(s) \_\_\_\_\_ [§ 280.53]

Release confirmed; when and how \_\_\_\_\_

Initial abatement measures and site characterization

Free product removal

Soil or ground water contamination

Corrective action plan submitted

Remediation ongoing

Remediation completed, no further action; date(s) \_\_\_\_\_

Unusual Operating Conditions

Interstitial Monitoring alarms

**Notes:**

Jan 2023 - May 31, 2023 - completed every month?  
Recently(?)

**XIII. Walkthrough Inspections** [§ 280.36 – Subpart C]

**Owner and operators must conduct walkthrough inspections of the following:**

Must have monthly records Y  N

Spill Prevention Equipment – must be checked for damage, remove liquid or debris, and check fill cap.

Y  N

DW spill prevention equipment with interstitial monitoring – must check for leak in interstitial area.

Y  N  N/A

Release detection equipment – must check to ensure operating with no alarms and review records of release detection testing.

Y  N

Must have annually records Y  N  6/27/22 - submitted on 6.27.23

Containment sumps – must check for damage, leaks, remove liquid or debris.

Y  N

DW sumps with interstitial monitoring – must be checked for leak in interstitial area.

Y  N  N/A

Hand held release detection equipment – must check tank gauge sticks or groundwater bailer.

Y  N

**\* Owners and operators of UST system(s) must maintain records of operation and maintenance walkthrough inspections for one year.**



THE UNITED STATES ENVIRONMENTAL PROTECTION AGENCY (EPA)  
 REGION 2 UST PROGRAM  
 Underground Storage Tank Team  
 New York, NY 10007-1866

Facility Name Puma Veteran's Drive Service station  
 Address 1 Estate Demerara St. Thomas, VI 00802  
 UST Reg # 201018

**Inspector Observation Report**  
*Inspection of Underground Storage Tanks (USTs)*

No areas of concern observed at the conclusion of this inspection.

The above named facility was inspected by a duly authorized representative of EPA Region 2, and the following are the inspector's observations and/or recommended corrective action(s):

Areas of Concern Observed:

Regulatory Citation	Area of Concern
§ 280.35(a)(1)	Potential to meet the requirements for periodic testing of spill prevention equipment or containment sumps
§ 280.35(a)(2)	Potential to periodically inspect overflow prevention equipment
§ 280.36(b)	Potential to either conduct periodic walkthrough inspections every thirty days or to conduct annual walkthrough inspections
§ 280.40(a)(2)	Potential failure to annually test release detection components,

Actions Taken:

Field Citation; # \_\_\_\_\_  Additional information required  On-site request/Due date \_\_\_\_\_

Comments/Recommendations:

280.41(a) - Potential failure to monitor tanks every 30 days, if appropriate. → Premium was not working  
 280.41(b)(1)(i)(B) - Potential failure to monitoring of pressurized piping  
 280.241(b) - Potential failure to designate each individual who meets definition of Class C operator  
 280.245(a) - potential failure to maintain a list of designated operators

Title of UST Owner/Operator Representative: Rum ASE Coordinator  
 Name of UST Owner/Operator Representative: Najia S. Davila  
 (Please print)  
Najia S. Davila  
 (Signature)  
 Other Participants: [Signature]  
[Signature]

Name of EPA Inspector/representative:  
Hiep Tran  
 (Please print)  
[Signature]  
 (Signature)  
 (Credential Number)  
 Date of Inspection 6/14/23 Time 16:30 AM/PM

Documents Not Available During the On-Site Inspection  
Please Provide As Soon As Possible

Location: Puma Veteran's Drive

Facility ID Number: 201018

- Tank Registration Certificate
- Operator Training Records (Individuals training or retraining) operator Class C
- Demonstrate Financial Responsibility
- Automatic Line Leak Detector Test Records – Annual
- Line Leak Test Records – Annual
- Evidence of Spill Prevention
- Evidence of Overfill Prevention
- Tank Release Detection Records
- Vapor Monitoring Records – Monthly (12 Most Recent Months)
- Under Dispenser Containment (Visual inspection or electronic monitoring)
- Site Assessment to Demonstrate Monitor Wells Properly Installed/Located
- Documentation of Compatibility for UST Systems
- Corrosion Protection Inspection Records
- Documentation of Periodic Walk-through Inspection
- Walkthrough Inspection Records – Monthly and Annually
- Other (specify) \_\_\_\_\_

Additional Recommendations: \* Some records were submitted after UST inspection.

- no regular liquid sensors

- no monitoring method for premium tank

- no records for triennial testing of spill bucket, containment sumps

- no triennial inspection of overfill prevention <sup>no</sup> record

- no <sup>monthly</sup> walkthrough inspection records - before January 2023

- no record of annual walkthrough inspection

- no annual test of release detection components - AIG sensors and probes, etc.

- no designated Class C operator

- no list of operators

- received monthly walkthrough inspection from 1/26/23 to 5/31/23 - Done monthly(?)

**Required Fields to be used for ICIS Only**

Compliance Monitoring

Activity: UST Inspection

Inspection Conclusion Data Sheet

1) Did you observe deficiencies (areas of concern during the on-site inspection)?

Deficiencies observed: (Put an X for each observed deficiency)

Potential failure to complete or submit a notification, report, certification, or manifest

Potential failure to follow or develop a required management practice or procedure

Potential failure to maintain a record or failure to disclose a document

Potential failure to maintain/inspect/repair meters, sensors, and recording equipment

Potential failure to report regulated events, such as spills, accidents, etc.

2) If you observed deficiencies, did you communicate the deficiencies to the Facility during the inspection?  Yes /  No

3) Did you observe the Facility take any actions during the inspection to address the deficiencies noted?  Yes /  No

If yes, what actions were taken? *contractor attempted to figure out the release detection method for Premium tank*

4) Did you provide general Compliance Assistance in accordance with the policy on the role of the EPA Inspector in providing Compliance Assistance during Inspections?  Yes /  No

5) Did you provide site-specific Compliance Assistance in accordance with the policy on the role of the EPA Inspector in providing Compliance Assistance during the inspection?  Yes /  No

This report was reviewed and deemed complete by: Reviewer

Signature

Date

Gaetano La Vigna

GAETANO LAVIGNA

Digitally signed by GAETANO LAVIGNA  
Date: 2023.08.03 08:17:08 -04'00'

701018

3

Release Prevention Compliance Measures Matrix

Regulatory Subject Area	Measure #	SOC Measure / Federal Citation	In Compliance?			
			N/A	Y	N	
I. Spill Prevention	1	Spill prevention device is present and functional. [280.20(c)(1)(i), 280.21(d)]		X		
	2	Overfill prevention device is present and operational. [280.20(c)(1)(ii), 280.21(d)] <input type="checkbox"/> Automatic shutoff is operational (ie., device not tampered with or inoperable) [280.20(c)(1)(ii)(A), 280.21(d)] <input checked="" type="checkbox"/> Alarm is operational. [280.20(c)(1)(ii)(B), 280.21(d)] <input checked="" type="checkbox"/> Alarm is audible or visible to delivery driver. [280.20(c)(1)(ii)(B), 280.21(d)] <input type="checkbox"/> Ball float is operational. [280.20(c)(1)(ii)(B), 280.21(d)]		X		
III a. Operation and Maintenance	3	Repaired tanks and piping were tightness tested within 30 days of repair completion (not required w/internal inspections or if monthly monitoring is in use). [280.33(d)]				X
III b. Operation and Maintenance of Corrosion Protection	4	CP systems were tested/inspected within 6 months of repair of any cathodically protected UST system. [280.33(e)]				X
	5	Corrosion protection system is properly operated and maintained to provide continuous protection. [280.31(a)(b), 280.70(a)] <input type="checkbox"/> UST system (Choose one) <input type="checkbox"/> UST in operation <input type="checkbox"/> UST in temporary closure <input type="checkbox"/> CP System is properly operated and maintained <input type="checkbox"/> CP system is performing adequately based on results of testing. [280.31(b)]; - or - <input type="checkbox"/> CP system tested within required period and operator is conducting or has completed appropriate repair in response to test results reflecting CP system not providing adequate protection.				X

201018 6/12/23 1 of 2

### Release Detection Compliance Measures Matrix

*Instructions - To Determine Compliance Status of Measures #1-7, Work Through the Worksheet "Commonly Used Release Detection Methods" Below.*

Regulatory Subject Area	Measure #	SOC Measure/ Federal Citation	In Compliance?		
			N/A	Y	N
I. Release Detection Method Presence and Performance Requirements	1	Release detection method is present. [280.40(a)] <i>Premium tank</i>			X
	2	Release detection system is operating properly (i.e., able to detect a release from any portion of the system that routinely contains product). [280.40(a)(1)]			X
	3	Release detection system meets the performance standards at 280.43 or 280.44. [280.40(a)(3)] <i>Need to verify givens</i>			X
	4	Implementing agency has been notified of suspected release as required. [280.40(b)] <input type="checkbox"/> Non-passing results reported and resolved in accordance with implementing agency's directions. [280.40(b)]			
II. Release Detection Testing	5	Tanks and piping are monitored monthly for releases and records are available (must have records for the two most recent consecutive months and for 8 months of the last 12 months). [280.41(a), and 280.45(b)]		X	
III. Hazardous Substance UST Systems	6	Hazardous substance UST system leak detection meets the requirements (i.e., either secondarily contained or otherwise approved by the implementing agency). [280.42(b)]	X		
IV. Temporary Closure	7	Release detection requirements are complied with (i.e., method present, operational, releases investigated and reported as required) for UST systems containing product. [280.70(a)]	X		

### Worksheet - Commonly Used Release Detection Methods

Tank (Choose one)	Pressurized Pipe (Choose Two)	Non-exempt Suction Pipe (Choose one)	Release Detection Method
<input type="checkbox"/>			<p>A. Inventory Control with Tank Tightness Testing (T.T.T)</p> <ul style="list-style-type: none"> <li><input type="checkbox"/> Inventory control is conducted properly.</li> <li><input type="checkbox"/> T.T.T. performed as required (See "D" below).</li> <li><input type="checkbox"/> Inventory volume measurements for inputs, withdrawals, and remaining amounts are recorded each operating day and reconciled as required. [280.43(a)(1), 280.43(a)(3)]</li> <li><input type="checkbox"/> Equipment is capable of 1/8-inch measurement. [280.43(a)(2)]</li> <li><input type="checkbox"/> Product dispensing is metered and recorded within local standards for meter calibration to required accuracy. [280.43(a)(5)]</li> <li><input type="checkbox"/> Water is monitored at least monthly. [280.43(a)(6)]</li> </ul>

*201018  
6/12/23*

Release Prevention Compliance Measures Matrix

Regulatory Subject Area	Measure #	SOC Measure / Federal Citation	In Compliance?		
			N/A	Y	N
III b. Operation and Maintenance of Corrosion Protection (Continued)	6	UST systems with impressed current cathodic protection are inspected every 60 days. [280.31(c)]		X	
	7	Lined tanks are inspected periodically and lining is in compliance. [280.21(b)(1)(ii)]		X	
IV. Tank and Piping Corrosion Protection	8	Buried metal tank and piping (which includes fittings, connections, etc.) is corrosion protected. [280.20(a), 280.20(b), 280.21(b), 280.21(c)]		X	
		<input type="checkbox"/> Buried metal piping components (such as swing joints, flex-connector, etc.) are isolated from the soil or cathodically protected. For new USTs - tanks and piping installed after 12/22/88 [280.20(a), 280.20(b)]: <input type="checkbox"/> Steel tank or piping is coated with suitable dielectric material and cathodically protected. [280.20(a)(2), 280.20(b)(2)] <input type="checkbox"/> Tank is fiberglass, clad, or jacketed and piping is fiberglass or flexible plastic. [280.20(a)(1), 280.20(a)(3), 280.20(a)(5), 280.20(b)(1), 280.20(b)(4)] <input type="checkbox"/> Records are available to document that CP is not necessary. [280.20(a)(4)(ii), 280.20(b)(3)(ii)] For existing USTs - tanks and piping installed on or before 12/22/88 [280.21(b), 280.21(c)]: <input type="checkbox"/> Tank and piping meet new UST requirements [280.21(a)(1)] <input type="checkbox"/> Steel tank is internally lined. [280.21 (b)] <input type="checkbox"/> Metal tank and piping are cathodically protected. [280.21(b)(2), 280.21(c)]			

Notes: N/A - Indicates that the measure is not applicable.  
 Any mark in the "N" (No) column means that the facility is not in Significant Operational Compliance (SOC) with Release Prevention Compliance Measures. In order for a compliance measure to be in SOC, all applicable check-box items must be in compliance.

201018 6/12/23

Release Detection Compliance Measures Matrix

Worksheet (Continued) - Commonly Used Release Detection Methods

Tank (Class name)	Pressurized Pipe (Class Type)	Non-exempt Suction Pipe (Class Type)	Release Detection Method
<input checked="" type="checkbox"/>			<p><b>B. Automatic Tank Gauge (ATG)</b></p> <ul style="list-style-type: none"> <li><input type="checkbox"/> ATG is set up properly. [280.40(a)(2)]</li> <li><input type="checkbox"/> ATG can detect a 0.2 gal/hr leak rate from any portion of the tank routinely containing product. [280.43(d)(1)] <input type="checkbox"/></li> </ul> <p>ATG is checking portion of tank that routinely contains product. [280.40(a)(1)]</p>
<input type="checkbox"/>			<p><b>C. Manual Tank Gauging (MTG)</b></p> <ul style="list-style-type: none"> <li><input type="checkbox"/> Tank size is appropriate for using MTG. [280.43(b)(5)]</li> </ul> <p>Method is being conducted correctly. [280.43(b)(4)]</p> <ul style="list-style-type: none"> <li><input type="checkbox"/> Tanks 1001 gals (as per EPA memo) and greater restricted to use with T.T.F. (See "D" below) <input type="checkbox"/></li> <li><input type="checkbox"/> No liquid was added to or taken out of the tank during the test. [280.43(b)(1)] <input type="checkbox"/></li> </ul> <p>Equipment is capable of 1/8-inch measurement. [280.43(b)(3)]</p>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<p><b>D. Tightness Testing (Safe Suction piping does not require testing)</b></p> <ul style="list-style-type: none"> <li><input type="checkbox"/> Testing method is capable of detecting a 0.1 gal/hr leak rate from any portion of tank routinely containing product. [280.43(c)]</li> <li><input type="checkbox"/> Tightness testing is conducted within specified time frames for method:                             <ul style="list-style-type: none"> <li><input type="checkbox"/> Tanks - every 5 years [280.41(a)(1)]</li> <li><input type="checkbox"/> Pressurized Piping - annually [280.41(b)(1)(ii)]</li> <li><input type="checkbox"/> Non-exempt suction piping - every 3 years [280.41(b)(2)]</li> </ul> </li> <li><input type="checkbox"/> Tightness testing is conducted following manufacturer's instructions. [280.40(a)(3)]</li> </ul>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<p><b>E. Ground Water or Vapor Monitoring</b></p> <ul style="list-style-type: none"> <li><input type="checkbox"/> Ground water in the monitoring well is never more than 20 feet from the ground surface. [280.43(f)(2)] <input type="checkbox"/></li> </ul> <p>Vapor monitoring well is not affected by high ground water. [280.43(e)(3)]</p> <ul style="list-style-type: none"> <li><input type="checkbox"/> Site assessment has been done for vapor or ground water monitoring. [280.43(c)(6), 280.43(f)(7)] <input type="checkbox"/></li> </ul> <p>Wells are properly designed and positioned. [280.43(e)(6), 280.43(f)(7)]</p>
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<p><b>F. Interstitial Monitoring</b> <i>Penum tank is no and Reg sensor is</i></p> <ul style="list-style-type: none"> <li><input type="checkbox"/> Secondary containment can be used to detect a release [280.43(g)(1), 280.43(e)(2)] <i>no</i></li> <li><input type="checkbox"/> Sensor properly positioned. [280.40(a)(2)]</li> </ul>

2010/18 6/12/23  
2 of 3

Release Detection Compliance Measures Matrix

Worksheet (Continued) - Commonly Used Release Detection Methods			
Tank (Choose one)	Pressurized Pipe (Choose Two)	Non-exempt Suction Pipe (Choose one)	Release Detection Method
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<p><b>G. Automatic Line Leak Detector (ALLD)</b></p> <p><input type="checkbox"/> ALLD is present and operational. [280.44(a)]</p> <p><input type="checkbox"/> Annual function test of the ALLD has been conducted and records are available. [280.44(a)]</p> <p><b>H. Other Methods [e.g., Statistical Inventory Reconciliation (S.I.R.)]</b></p> <p><input type="checkbox"/> The method can detect a 0.2 gal/hr leak rate or a release of 150 gal within a month and meet the 95/5 requirement [280.43(h)(1)], or</p> <p><input type="checkbox"/> The implementing agency has approved the method as being as effective as tank tightness testing, automatic tank gauging, vapor monitoring, ground water monitoring, or interstitial monitoring and the operator complies with any conditions imposed by agency. [280.43(h)(2)]</p> <p><input type="checkbox"/> S.I.R. - Results are received within time frame established by implementing agency. [280.41(a) &amp; 280.43(h)]</p>

Notes: N/A - Indicates that the measure is not applicable.

Any mark in the "N" (No) column means that the facility is not in Significant Operational Compliance (SOC) with Release Detection Compliance Measures.

In order for a compliance measure to be in SOC, all applicable check-box items must be in compliance.

201018  
6/12/23