

TECH. CTR. REVIEW - 1/91

#1

31-JAN-1991 12:29:02.92

NEWMAIL

- 9. WILL EVALUATE NEED FOR N2 PURGES ON LUBE OIL RESERVOIRS.
- 18. WILL CHECK ON ANALYZER LAG TIME AS OPPOSED TO SAMPLE LAG.
- 19. HAVE REDUNDANT OXYGEN ANALYZERS; CONTROL LOGIC MUST BE ARRANGED SUCH THAT HIGH OXYGEN TRIP CANNOT BE BYPASSED.
- 21. NOTE ON PROBLEM WITH 8" PRD SUPPORT.
- 22. QUESTION ON CONTAINMENT CAPACITY FOR HOLDING POND.
- 23. INVESTIGATING EFFECT OF PRD BURST ON C2.
- B. OXIDE STRIPPING AND COMPRESSION
- 6. INCLUDE LOSS OF SUB 9
- 8. LOOKING AT INCLUDING SEAL PURGE GAS DELTA P IN TRIP SYSTEM.

Press RETURN for more...

MAIL>

#1

31-JAN-1991 12:29:02.92

NEWMAIL

- 9. EVALUATING N2 PURGE ON LUBE OIL RESERVOIR.
- 14. EVALUATING CLOSED LOOP SAMPLING.
- 18. NOTE THAT FIRE WATER WILL NOT REACH T-8-1 TOP MANWAY.
- 19. SNUFFING STEAM IS NOT USED. QUESTION ON THIS. SOME SNUFFING MEDIUM SHOULD BE USED. SOME PLANTS USE NITROGEN.
- 37. SCREWED PIPING IS NOT ALLOWED.
- C. OXIDE PURIFICATION AND STORAGE
- 8. PLAN IS TO STRIP INSULATION FROM BOTH PURIFICATION TOWERS, CONDUCT THOROUGH INSPECTION, AND REINSULATE WITH FOAMGLASS. 1992 SCHEDULE.
- 29. A LIST HAS BEEN MADE AND AFFECTED PIPING IN THE FIELD

Press RETURN for more...

MAIL>

#1

31-JAN-1991 12:29:02.92

NEWMAIL

HAS BEEN SPRAY PAINTED. CORRECTIONS PLANNED FOR 1992 SHUTDOWN.

- 37. EVALUATING GRAPHOIL GHE TYPE GASKETS.
- D. OXIDE LOADING AND SHIPPING
- 3. LIQUID AND VAPOR SAMPLES ARE ANALYZED.
- 6. LIQUID AND VAPOR EBV'S TRIP. LOADING PUMP TRIPS.

DO A 135806
CONFIDENTIAL

- 7. MONOGGLES ALSO.
- 9. HAD TYPE DETECTORS ALSO.
- 15. VAPOR NOW GOES TO SCRUBBER.
- 29. MAXIMUM TIME ON-TRACK 1 WEEK. NO RECHECKS.

Press RETURN for more...

MAIL>

#1

31-JAN-1991 12:29:02.92

NEWMAIL

- 30. NEED TO RE-EVALUATE PROCEDURES TO MINIMIZE RISK OF EXCEEDING VACUUM RATING OF CARS.
- E. LABORATORY
- 3. EVALUATING CLOSED LOOP SAMPLING.
- 5. CAUTION ON PROBLEM WITH INADEQUATE FLOW TO SEWER AND POTENTIAL FOR BACKING UP.
- 14. NEED TO ELIMINATE STORAGE OF SAMPLES AT TEMPERATURES ABOVE FLASH POINT.
- F. UTILITIES
- 6. POWER ALSO.
- 9. NOTE THAT USE OF BACK ENTRANCE PROBABLY COULD BE DISCONTINUED. IF NOT IT SHOULD BE MARKED PROPERLY.

Press RETURN for more...

MAIL>

#1

31-JAN-1991 12:29:02.92

NEWMAIL

- 23. RECOMMEND THOROUGH CHECK FOR VESSELS THAT HAVE POTENTIAL FOR FLAMMABLE HEAD SPACE AND TAKE APPROPRIATE PRECAUTIONS.
- 36. DOUBLE CHECK ROAD CROSSING BOP ELEVATION.

GLYCOL PLANT

B. OXIDE PROCESSING

- 1. CHECK ON BACK-FLOW PROTECTION FOR EO TO MIX TUBE. WE DON'T WANT TO DEPEND ON CHECK VALVES ONLY.

MAIL>

DO A 135807
CONFIDENTIAL