

Purpose: NPDES SSO Inspection Trip Report

Facility: Cahokia Heights, Illinois

NPDES ID Number (No NPDES Permit): ILN000019

Dates of Inspection: August 25, 2021

Illinois EPA Inspectors: None

EPA Inspectors:

Dean Maraldo, EPA Region 5; (312) 353-2098; maraldo.dean@epa.gov

Joan Rogers, EPA Region 5; (312) 886-2785; rogers.joan@epa.gov

Ted Flatebo, EPA Region 5; (312) 886-9402; flatebo.ted@epa.gov

City of Cahokia Heights Representatives: None

Inspection Trip Report Prepared by:

Joan Rogers, EPA Region 5 Inspector

EPA Inspector Signature: Maraldo, Dean
Digitally signed by Maraldo, Dean
Date: 2021.09.14 07:08:53 -05'00'

EPA Inspector Signature: JOAN ROGERS
Digitally signed by JOAN ROGERS
Date: 2021.09.13 21:35:09 -05'00'

EPA Inspector Signature: Flatebo, Theodore
Digitally signed by Flatebo, Theodore
Date: 2021.09.14 07:36:43 -05'00'

Approver Name & Title:

Ryan Bahr, Chief, Compliance Section 2

Approval Signature and Date: RYAN BAHR
Digitally signed by RYAN BAHR
Date: 2021.09.14 08:10:15 -05'00'

TABLE OF CONTENTS

I. Introduction..... 3
II. Inspection Activity Summary 3

working in the wet well in the street to make repairs. The City reported an SSO at North 63rd Street and Pittsburgh Drive on Friday, August 20, 2021. Mr. Rory Morgan opened the manhole downstream from the wet well and did not observe flow. He stated that the lift station repair had been made the day before, but it was not working on the day of the EPA inspection.

EPA drove to the manhole at North 63rd Street and Pittsburgh Drive and observed water on the ground around the manhole at 11:18 A.M., but it was not surcharging.

Location #5: Cleanout on North 82nd Street

EPA inspectors arrived at the cleanout overflow location on North 82nd Street at 11:23 A.M. The cleanout was not discharging.

Location #6: North 82nd Street and Belleview Avenue Lift Station

EPA inspectors arrived at the lift station at North 82nd Street and Belleview Avenue at 11:24 A.M. This is lift station #10 on the Commonfields of Cahokia lift station list. The lift station was not overflowing.

EPA inspectors then drove back to the intersection of North 63rd Street and Laura Avenue and informed Mr. Traiteur that we were leaving the city to drive home. EPA exited the area at 11:32 A.M.