

OWENS-CORNING FIBERGLAS CORPORATION

INTRA-COMPANY CORRESPONDENCE

Newark, Ohio

Attention: F. Van Voorhis - Newark

December 31, 1947

Subject: DUST COUNT OF THE INSULATION
CEMENT OPERATION

cc: A. L. Simson
C. W. Smickor
A. J. Morrison
Mr. Campbell
File

Attached is a memo written by W. C. Fashner of the Works Laboratory, who made dust counts in our insulation cement department. His findings reveal that there is a serious health hazard in this area, particularly around the packing, buck and scales.

The writer requests that Plant Engineering Department either install more adequate dust collecting hood or initiate a request to General Engineering to design such equipment.

W. C. Jones
General Engineering Department

WCF/plk

PLAINTIFF'S
EXHIBIT

7535-0

PLAINTIFF'S
EXHIBIT

WV-02912

02 203 1275