

**DATA FOR TURBINE BLANKETS
INSULATION FOR HORIZONTAL FLANGES**


KW RATING	625-750	1000-2500	3000-6000	7500	10000-12500
BLANKET LENGTH	35"	40"	42"	45"	52"
GROUP NUMBER	1	2	3	4	5

NOTE: UNLESS OTHERWISE SPECIFIED, EACH TURBINE WILL BE SUPPLIED WITH FOUR (4) BLANKETS 12" WIDE x 2" THICK WITH LENGTHS ORDERED TO ABOVE GROUP NUMBERS.

BLANKETS TO HAVE BOXED ENDS, MADE FROM V.S.-2710-98% ASBESTOS CLOTH, MONEL WIRE INSERTED, FILLED WITH AMOSITE ASBESTOS FIBRE, AND TO HAVE MONEL LACING HOOKS AT EDGES OF ONE FACE ON APPROXIMATELY 5" CENTERS.

SC-ETM-0036

ET-000024



**JOHNS-MANVILLE INSULATION
USED BY
ELLIOTT COMPANY**

S-647431

d.e.m.

