CONFIDENTIAL

-.62. BA

(File 46601BA) March 5, 1962
MATERIAL 46601BA
PIPE INSULATION
FURNISHED BY - (For Steam)
(A)Baldwin-Ehret-Hill,Inc,1153 Brewing Ave, Trenton 2, N J
(B)Johns-Manville, 22E 40th St, N Y 1[illegible]
(C)Owens-Corning Fiberglas Corp,Nat'l Bank Bldg, Toledo, Ohio
(For Sunnyvale)
(D)Fibreboard Paper Prod Corp,Pabco Insulation Div,San Francisco 19, Cal

ORDER FROM SUPPLIER AS
(A)(Pipe Sizes 1-1/2" & less)Enduro Hi-Temp Pipe Insulation
(Pipe Sizes Over 1-1/2")Enduro Hi Temp & Thermasil Pipe Insulation.
(B)(Pipe Sizes 1-1/2" & less)Superex-M Pipe Insulation
(Pipe Sizes Over 1-1/2")Superex-M & Thermobestos Pipe Insulation
(C)(Pipe Sizes 1-1/2" & less)Kaylo 20 Pipe Insulation
(Pipe Sizes Over 1-1/2")Kaylo 20 & Kaylo Pipe Insulation
(D)Prasco 15C High Temperature Pipe Insulation*; or Pabco Precision Molded Caltemp Pipe Insulation*
*NOTE: Stating size of pipe and insulation thickness.

Printed in U.S.A. (Over)

DOCUMENTS PRODUCED DALLAS COUNTY CASES 3/18/92

DOCUMENTS PRODUCED DALLAS COUNTY CASES 3/18/92

PLAINTIFF'S EXHIBIT
WH-78

F

NOTICE: If the film image below is less clear than this notice, this due to the quality of the document being filmed.

CONFIDENTIAL

CHARACTERISTICS - (Previous 7310)(Users:PH...) High temperature silicate heat insulation molded to shape to fit standard pipe sizes.

APPLICATION - Heat insulation for steam pipes for temperatures up to 1600 F.

SPECIFY AS - PIPE INS 4660[illegible]

Issued by Std Dept, Matl Research Lab, E Pgh, Pa.

DOCUMENTS PRODUCED DALLAS COUNTY CASES 3/18/92

DOCUMENTS PRODUCED DALLAS COUNTY CASES 3/18/92