

*Sample*  
*no 8.3*

Copies:  
Mr. Harrison.....  
Mr. E. J. .....  
Mr. Joseph .....  
Mr. S. .....  
Project Eng. ....  
USRA .....  
Field Auditor.....  
Architects .....  
Mr. Zabriskie .....  
Mr. Gallico .....  
File (MWD).....

December 2, 1933

A. F. Construction Corp.  
5 East 141st Street  
New York City

Re: South Jamaica Project, N.Y. 6-4

Gentlemen:

Attention Mr. Ravitch

Replying to your letter of December 1st, in which you say that you are enclosing formula of Sherwin-Williams Company Paint, for use on steel windows by your subcontractor J. E. Thorn Co., the enclosure you submitted was a letter stating why Sherwin-Williams recommended Lithopane but did not include any formula.

We do not agree with Sherwin-Williams contention in the use of Lithopane for exterior paint and would refer you to the Specification which calls for two shop coats, each coat baked on separately, first coat to be red lead and oil, second coat gray lead and oil, quality, composition and formula as approved by the Authority.

Very truly yours,

GEORGE HADLEY  
Asst. Chief Engineer

GG:LW

0007-LGA-000001316

0007-LGA-000001316

N 4379