PLAINTIFF'S EXHIBIT 04199.00
PLAINTIFF'S EXHIBIT WV-009611

U.S. DEPARTMENT OF LABOR
BUREAU OF LABOR STANDARDS

NOTICE OF

SAFETY AND HEALTH VIOLATIONS

NAME OF FIRM				CONTRACTOR NUMBER
Pittsburg Corning Corporation				
STREET ADDRESS	CITY	COUNTY	STATE	ZIP
Box 3057 - Tyler, Texas	Owentown	Smith	Texas	75701

OFFICIALS CONTACTED - NAME AND TITLE	PLANT SURVEY MADE WITH	COMPLIANCE DATE
Charles E. Van Horne, Wks. Manager	Mr. Van Horne	
	REPORT FURNISHED TO: James H. Bierer, President	May 8,1969
	USDL SAFETY ENGINEER: M. Padilla, Industrial Hygienist	DATE OF SURVEY 2/13/69

A SURVEY OF YOUR FACILITIES HAS REVEALED CONDITIONS WHICH DO NOT COMPLY WITH USDL SAFETY AND HEALTH REQUIREMENTS UNDER THE PUBLIC LAW CHECKED.

THE CONDITIONS ARE LISTED BELOW WITH REFERENCE TO CODES AND STANDARDS WHICH HAVE BEEN ADOPTED AS THE DEPARTMENT'S SAFETY AND HEALTH REQUIREMENTS.

THESE UNSATISFACTORY CONDITIONS MUST BE CORRECTED. PLEASE ADVISE REGIONAL DIRECTOR Wendell R. Blair ON OR BEFORE May 8, 1969 AS TO THE CORRECTIVE ACTION TAKEN.

PUBLIC LAW - 74-846 WALSH-HEALEY PUBLIC CONTRACTS ACT	X
PUBLIC LAW 89-286 MC NAMARA - O'HARA SERVICE CONTRACTS ACT	
PUBLIC LAW - 89-209 ARTS AND HUMANITIES ACT	
PUBLIC LAW 89-333 VOCATIONAL REHABILITATION ACT	

NO.	CODE-STANDARD REFERENCE	CORRECTIONS REQUIRED
		UNSATISFACTORY CONDITIONS NOTED ON INDUSTRIAL HYGIENE SURVEY OF 2/13/69
		Process Area
1.	50-204.264	No certified first aiders. Ex: Recommend that several employees be trained so that each shift will have qualified personnel to take care of emergencies.
2.	50-204.275, Ind. Vent. ACGIH 5-93	Local exhaust ventilation not according to standards. Ex: Local exhaust ventilation system was tested with the following findings: a. Grinder hood, 25-50 fpm at face. b. Feeder at material point of entry, 50 fpm. c. Scrap feeder at material point of entry, 50 fpm. d. Sawing ducts 500 fpm at face. Recommend that employer make a study of present local exhaust ventilation with professional advice, to come up to standard. It is believed that present system is below the required capacity.
		(1) ACCORDING TO PAR. 50-204.275, IF AN EMPLOYEE IS WORKING IN AN APPROVED RESPIRATOR IN AN EMERGENCY THIS CO. IS NOT IN VIOLATION. OUR EMPLOYEES USE RESPIRATORS IN ALL DUST AREAS
		(2) I HAVE NO REFERENCE IN MY COPY OF THE WALSH-HEALEY PUBLIC CONTRACTS ACT (SECTION 1) OF SUGGESTED SECTION VELOCITIES AS SITED