

Mary,
Pls cc for JK C. nre ✓
TK, Jim.

Jim V Tickle ~~2/25~~
419

RECEIVED

MAR 6 1986

MAINTENANCE DEPT.

March 4, 1986

PLAINTIFF'S EXHIBIT

UC-2112


TO: J. R. Dement
S. Rossi

COPY: D. B. Howard
F. L. McCarty

SUBJECT: Tank Insulation in 1986

The 1986 budget for Polyols included about \$600M for tank insulation and weatherproofing work. Two of the tanks were actually started in 1985 because of the need to remove damaged asbestos insulation.

Now that Construction has been pulled out of the plant, how will these remaining tanks be done? Since there is a sizable amount of work, we need to get a good start as soon as the mild weather arrives in April.


D. H. Ott

DHO/cgb

A Priority Insulation Needs

Tank No	Last Inspection	Condition		Comments	Est. Cost \$ Repairs	Plan 1986	1988
		Paint	Insulation				
261/262	1976	Poor	Poor		27,000		
255/256	1974	Poor	Poor	Weatherproofing gone	27,000		
595	1974	Poor	Poor	Top insulation very poor	Mats 80,000 Kaylo 47,000		
596	1979	Poor	Poor	Top insulation very poor	Mats 80,000 Kaylo 47,000		
543/644	1974	Poor	Poor	Partially patched - some insulation may be salvageable; but weatherproofing is gone.	21,000		
545/646	1974	Poor	Poor	Weatherproofing all gone, insulation exposed	21,000	Done	
511/612	1974	Poor	Poor	Asbestos	27,000	Done	
561/662	1974	Poor	Poor	Painting scheduled for 1986. Should either be stripped or reinsulated prior to painting.	25,000		
513/614	1974	Poor	Poor	Asbestos	27,000		
547/648	1974	Poor	Poor	Scheduled for painting in 1985 - insulation should be repaired prior to painting.	27,000		
549/650	1974	Poor	Poor		27,000		
580/8481	1983	Poor	Poor		37,000		
582/8483	1979	Poor	Fair	Rust and bulges in insulation. A row of insulation between removed to let moisture out.	37,000		

557 M

487

Acc # 7 Super Tank
Acc # 3 PX