

REQUEST FOR CHANGE - TRIAL OF MATERIAL OR STANDARD PARTS
(Circle Either Change or Trial)

5K-98



NO. 401

REQUESTED BY H. Pelton DATE 11-17-78

ITEM Pipe insulation (28.04 22XX) WHERE USED Throughout plant. 10 sizes are stocked in the warehouse.

PRESENT: Unibestos 750

PROPOSED: J-M Thermo 12.

REASON FOR CHANGE: Unibestos 750 contains asbestos and may no longer be used.

COST: Present _____ Proposed _____

ADDITIONAL "FIRST" COST (Patterns, Molds, etc.) _____

COST ADVANTAGE: Supplier has been furnishing Thermo-12 for some time. No cost change.

TRIAL EVALUATION RESULTS (Must Complete if Trial Made): Service Repair Department reports Thermo 12 satisfactory - equal to Unibestos 750. Thermo 12 also used by Contractors. /s/ Hogan Pelton 2-9-79 Thermo-12 has been in service 4 years & is satisfactory - A. Sushane

APPROVED: TRIAL APPROVAL & DATE

Dept. Head	_____
Maint. Engineer	_____
Maint. Supt.	_____
Plant Engr.	_____
Engrg. Supt.	_____
Plant Mgr.	_____

CHANGE APPROVAL & DATE

<u>Jim Gordon</u>	<u>11/17/78</u>
<u>G. L. [unclear]</u>	<u>11-17-78</u>
<u>George</u>	<u>11-17-78</u>
<u>[unclear]</u>	<u>11/22/78</u>

REQUEST FOR CHANGE - TRIAL OF MATERIAL OR STANDARD PARTS
(Circle Either Change or Trial)

NO. 398

SENT FOR STATUS
908195-8805-1181, 1-2-84
8-8-84

REQUESTED BY G. Liberty

DATE 11-22-78

ITEM Digester feed pump liquor head gasket WHERE USED loc. 30

PRESENT: Lemons type W, 900# rating.

PROPOSED: Flexitallic type special R, 1500# rating, Grafoil filler.

REASON FOR CHANGE: Present gasket will not hold up in service.

It is proposed that the Flexitallic gasket be tried in an effort to obtain a longer operating life.

COST: Present \$17.20 ea. Proposed \$87.93 ea. (single gasket)

ADDITIONAL "FIRST" COST (Patterns, Molds, etc.) \$12.00 set up.

COST ADVANTAGE: Considerable labor saving can be realized from longer gasket life. Gasket replacement requires approximately 64 manhours.

TRIAL EVALUATION RESULTS (Must Complete if Trial Made): Cancelled 8-30-84
per JJB

APPROVED:	TRIAL APPROVAL & DATE	CHANGE APPROVAL & DATE
Dept. Head	<u>H. Hainbauer by H02 11/27/79</u>	
Maint. Engineer	<u>D. H. 11-22-78</u>	
Maint. Supt.	<u>D. L. 11-27-78</u>	
Plant Engr.	<u>J. B. 11-27-78</u>	
Engrg. Supt.		
Plant Mgr.		

REQUEST FOR CHANGE - TRIAL OF MATERIAL OR STANDARD PARTS
(Circle Either Change or Trial)

NO. 399

SENT FOR STATUS
5-8-80, 5-8-81, 7-2-82
9-8-84

REQUESTED BY G. Liberty

DATE 11-22-78

ITEM Digester feed pump liquor head gasket

WHERE USED Fac. 30

PRESENT: Lemons type W, 900 # rating.

PROPOSED: Flexitallic type special R, 1500 # rating, asbestos filler.

REASON FOR CHANGE: Present gasket will not hold up in service.

It is proposed that the Flexitallic gaskets be tried in an effort to obtain a longer operating life.

COST: Present \$11.20 ea. Proposed \$13.96 ea. (single gasket).

ADDITIONAL "FIRST" COST (Patterns, Molds, etc.) \$10.00 set up.

COST ADVANTAGE: Material cost is comparable to present gasket.

Considerable labor saving can be realized from longer gasket life. Gasket replacement requires approximately 64 manhours.

TRIAL EVALUATION RESULTS (Must Complete if Trial Made):

Cancelled 8-30-84 per JTB

APPROVED:

TRIAL APPROVAL & DATE

CHANGE APPROVAL & DATE

Dept. Head

H. Haisbecker by HDP 11/29/78

Maint. Engineer

J. P. H. 11-22-78

Maint. Supt.

D. G. G. 11-21-78

Plant Engr.

J. D. J. 11/28/78

Engrg. Supt.

Plant Mgr.