Data Summary

Aroclor 1242 dissipation factor measurements at 60 cycles, using 3 cells, removing after 30 mins. reading, replacing with another cell, until all 3 cells have been measured

Dissipation factor after 30 mins, at 100°C, 60 cycles

| | Test Cell # 6 | Test Cell # 7 | Test Cell #8 |
|---|---|---|---|
| Aroclor 1242, lot KH-1156 | .00762 | .00496 | .00540 |

(Test Data Page OR 77539)

0080304

TOWOLDMON0057049