



INDUSTRIES

PPG INDUSTRIES, INC. INDUSTRIAL CHEMICAL DIVISION P. O. BOX 1000 LAKE CHARLES, LA. 70602

April 20, 1983

Mr. Dick Whittington, Administrator
United States EPA, Region VI
1201 Elm Street
Dallas, TX 75270

Re: Permit No. LA0000761
Discharge Monitoring Report

Dear Mr. Whittington:

Enclosed are the Discharge Monitoring Reports for January, February, and March, 1983. Excursions during the quarter were reported to your office as they occurred.

Treatment systems performed well during the report period. In summary, there were no excursions reported for the major pollutants (chlorinated hydrocarbons, mercury, and lead), representing a 100% overall compliance level. The level of pH (6.0-9.0) compliance at continuously-monitored Outfall 001 averaged 98.4% for the first quarter. Attached are further explanations for the excursions that occurred during this quarter.

Should you have any questions regarding this report, please call J. E. Wyche at (318) 491-4830.

Respectfully,

William J. Peard
Manager, Environmental Control

/fk

cc: Mr. J. Dale Givens
DNR, Water Pollution Control Division

SL 046685

PH CONTROL (OUTFALL 001). There were twelve excursions this quarter, including eight outside the 4-11 range, reported as follows:

January 6, 1983 @ 9:25 p.m. for 2 hrs. 5 min. - pH +0.5. An operational upset caused an overload situation on the pH control system. As a result, inadequate pH neutralization took place.

January 8, 1983 @ 8:30 a.m. for 16 min. - [Max. pH 11.3]. An operational upset due to a maintenance problem resulted in the release of a high pH material to pH control; the capacity of pH control was exceeded.

January 9, 1983 @ 8:42 p.m. for 1 hr. 19 min. - pH +0.2. Unable to find a reason for this excursion.

January 14, 1983 @ 9:27 a.m. for 1 hr. 23 min - pH +1.0 [Max. pH 11.1]. Due to several leaks developing in a process equipment line, high pH material entered the pH neutralization system; the neutralization capacity of pH control was exceeded. The unit was brought down until the leaks were repaired. New piping is to be installed at the next planned outage at the end of the month.

February 7, 1983 @ 7:30 p.m. for 2 hrs. 45 min. - pH +0.7 [Max. pH 11.9]. Prompt attention was not given to the pH neutralization system by the operator during an upset condition.

February 17, 1983 @ 5:04 a.m. for 20 min. - [Min. pH 3.4]. Neutralization capacity of pH control was exceeded when a surge of low pH material entered the system.

February 18, 1983 @ 7:52 p.m. for 1 hr. 39 min. - pH +1.2 [Max. pH 11.3]. Inadequate neutralization took place as a result of an excessive amount of high pH material entering the system from an undetermined source.

February 27, 1983 @ 9:06 p.m. for 1 hr. 17 min. - pH +0.4. The pH control system failed to adequately neutralize a surge of high pH material during the routine caustic regeneration of the Deion Unit.

March 3, 1983 @ 9:25 p.m. for 3 hrs. 12 min. - pH +1.5 [Max. pH 12.3]. The violation was the result of overloading of the pH neutralization system due to an operational instrumentation malfunction. The instrument was repaired.

March 11, 1983 @ 9:27 a.m. for 32 min. - [Min. pH 2.7]. As a result of operator error, a surge of low pH material entered the pH control system exceeding neutralization capacity. The operators involved have been counseled.

March 14, 1983 @ 4:27 a.m. for 1 hr. 8 min. - pH +0.5. The pH control system failed to adequately neutralize a surge of high pH material during the caustic regeneration of the Deion Unit.

March 20, 1983 @ 1:59 p.m. for 15 min. - [Min. pH 2.8]. Capacity of pH control was exceeded during the acid regeneration of the Deion Unit. Modifications are being studied to enhance adequate neutralization during the regeneration procedure.

The following measures have been taken to prevent reoccurrence of these excursions:

1. Regeneration of the deionized water unit at Mercury Cells was directly involved in five excursions. Procedures have been modified to more closely control and monitor discharge of regeneration chemicals to assure discharge at a rate which does not exceed pH control capability at the plant outfall.
2. Two excursions were due to overflows of process collection tanks at Plant A Caustic. Modifications have been made to control instrumentation and level alarms are being installed to remedy these situations.
3. One excursion was due to a leak in a process line at Plant A Caustic. This line has been replaced.

ATTACHMENT II

pH CONTROL (Outfall 005). There was one excursion this quarter reported as follows:

January 14, 1983 - pH +1.3. Due to plugged drain lines, process water overflowed into Outfall 005. Operations personnel responded immediately to unplug the drain. Standard operating procedures have been revised to insure that these drains are routinely monitored in the future to detect and correct any plugging problems.

ATTACHMENT III

TOTAL ORGANIC CARBON (OUTFALL 018/118). The maximum limit of 2600 lbs/day was exceeded once during the quarter and reported as follows:

March 3, 1983. The exact cause of the violation has not been determined. Investigation by plant personnel failed to determine the reason for this violation.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME G. C. STRICKLER - PPG INDUSTRIES
 ADDRESS PPG STRICKLER - WORKS MANAGER
P O BOX 1000
LAKE CHARLES LA 70602
 FACILITY PPG 140
 LOCATION LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

(2-16) LA0000761 (17-19) 001
 PERMIT NUMBER DISCHARGE NUMBER

F - FINAL LIMITS
 FINAL OUTFALL

Form Approved
 OMB No. 2000-0015

MONITORING PERIOD
 FROM YEAR MO DAY TO YEAR MO DAY
83 01 01 83 01 31
 (20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. FAHREH. UNIT 00011 1 0	SAMPLE MEASUREMENT	*****	*****	*****	*****	70	74		NA	CONT	RECORD
EFFLUENT GROSS VALUE FLOW RATE	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	DEG. F		CONTINUOUS	RECORD
00058 1 0	SAMPLE MEASUREMENT	188742	225500		*****	*****	*****	*****	NA	CONT	RECORD
EFFLUENT GROSS VALUE PH	PERMIT REQUIREMENT	*****	*****	GPM	*****	*****	*****	*****		CONTINUOUS	RECORD
00400 1 0	SAMPLE MEASUREMENT	*****	721	*****	4.3*	*****	11.3		L= 0 H= 4	CONT	RECORD
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	446	MIN/NO	6.0 MINIMUM	*****	9.0 MAXIMUM	SU		CONTINUOUS	RECORD
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G. C. STRICKLER
 WORKS MANAGER

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC 1001 AND

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER
B. Long

TELEPHONE

318 1491-4500

DATE

SL 046690

83 01 31

PERMITTEE NAME/ADDRESS (Include Facility Name/Location)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
EPA No. 2000-0015

NAME PPG INDUSTRIES INC.
ADDRESS G.C. STRICKLER - WORKS MANAGER
P.O. BOX 1000
LAKE CHARLES LA 70602
FACILITY PPG IND.
LOCATION LAKE CHARLES LA 70602

LA00000761

PERMIT NUMBER

005

DISCHARGE NUMBER

F - FINAL LIMITS
SURFACE RUNOFF

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY
83	01	01	83	01	31
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
TEMPERATURE, WATER DEG. FAHRENHEIT 00011 1 0	SAMPLE MEASUREMENT	*****	*****	*****	*****	81	86	NA	3/7	GRAB
EFFLUENT GROSS VALUE FLOW RATE	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	DEG.F	THREE WEEK	GRAB
00058 1 0	SAMPLE MEASUREMENT	513	680	GPM	*****	*****	*****	NA	3/7	GF
EFFLUENT GROSS VALUE PH	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	THREE WEEK	GRAB	
00400 1 0	SAMPLE MEASUREMENT	*****	*****	*****	7.1	*****	10.3	LF 0 HF 1	3/7	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	6.0 MINIMUM	*****	9.0 MAXIMUM	SU	THREE WEEK	GRAB
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G. C. STRICKLER
WORKS MANAGER

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY KNOWLEDGE OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318
AREA
CODE

491-4500
NUMBER

83 01 31
YEAR M DAY

DO NOT SIGNIFY THE PRESENCE OF SUSPENDED SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.

For pH -- see letter of 4/19/83, Attachment II

SL 046691

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME **PPG INDUSTRIES INC.**
 ADDRESS **P.O. BOX 1000**
LAKE CHARLES LA 70602
 FACILITY **PPG IND.**
 LOCATION **LAKE CHARLES LA 70602**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

(2-16)
LA0000761
 PERMIT NUMBER

(17-19)
010
 DISCHARGE NUMBER

Approved
 B No. 2000-0015
 F - FINAL LIMITS
 AREA B UNCONTAMINATED CTBD

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
83	01	01	83	01	31
(26-31)	(12-31)	(24-31)	(26-31)	(12-31)	(16-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)				(4 Card Only) QUALITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS		MINIMUM	AVERAGE	MAXIMUM			
FLOW RATE	SAMPLE MEASUREMENT	384	619	GPM	*****	*****	*****	*****	HA	CONT	RECORD
00058 1 0	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****			
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	0.06	0.37	LBS/DY	*****	*****	*****	*****	O	3/7	24
CHROMIUM, TOTAL (AS CR)	PERMIT REQUIREMENT	DAILY AV	DAILY MX		*****	*****	*****	*****			
01034 1 0	SAMPLE MEASUREMENT	*	*	LBS/DY	*****	*****	*****	*****		THREE	COMP24
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	DAILY AV	DAILY MX		*****	*****	*****	*****			
CHLORINATED HYDRO- CARBONS, GENERAL	SAMPLE MEASUREMENT			LBS/DY	*****	*****	*****	*****		THREE	COMP24
74052 1 0	PERMIT REQUIREMENT	DAILY AV	DAILY MX		*****	*****	*****	*****			
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY KNOWLEDGE OF THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
 OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318 491-4500

83 01 31

AREA CODE

NUMBER

YEAR

MO

DAY

TYPE OR PRINTED

ON THE BASIS OF THE INFORMATION SUBMITTED, THE DISCHARGE IS IN COMPLIANCE WITH PERMITS 010 & 018.

See Outfall 018

SL 046692

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
EPA No. 2000-0015

NAME **PPG INDUSTRIES INC.**
ADDRESS **P.O. BOX 1000**
LAKE CHARLES LA 70602
FACILITY **PPG IND.**
LOCATION **LAKE CHARLES LA 70602**

LA0000761
PERMIT NUMBER

111
DISCHARGE NUMBER

F - FINAL LIMITS
MERCURY TRACE SEWER

MONITORING PERIOD								
FROM			TO					
YEAR	MO	DAY	YEAR	MO	DAY			
83	01	01	83	01	31			
(10-31)	(12-31)	(14-31)	(10-31)	(12-31)	(10-31)			

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (58-63)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE	SAMPLE MEASUREMENT	***** 294	***** 390	*****	*****	*****	*****	*****	IIA	CONT.	RECORD
00058 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	*****		CONTINUOUS	RECORD
MERCURY, TOTAL (AS HG)	SAMPLE MEASUREMENT	*	*		*****	*****	*****	*****			
71900 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	0.21 DAILY AV	0.42 DAILY MX	LBS/DY	*****	*****	*****	*****		THREE WEEK	CONT. 24
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

A. C. STRICKLER
WORKS MANAGER

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREON AND BASED ON MY BELIEF OF THE INFORMATION SUBMITTED I AM RESPONSIBLE FOR OBTAINING THE INFORMATION AND I HAVE THE SIGNATURE INFORMATION IN THE APPROPRIATE AND CORRECT PLACE. I AM AWARE THAT THE FALSE SIGNATURE OF ANY PERSON ON THIS REPORT IS A VIOLATION OF THE ACT AND 33 USC 1321b. (Penalties under this act may include fines up to \$10,000 and/or maximum imprisonment of 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318 491-4500
NUMBER

83 01 31
YEAR MO DAY

REVIEW THE INFORMATION ON VIOLATIONS AND 111.
See Outfall 011

SL 046693

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
EPA No. 2000-0015

NAME PPG INDUSTRIES INC.
ADDRESS C.C. STRICKLER - WORKS MANAGER
P O BOX 1000
LAKE CHARLES LA 70602
FACILITY PPG IND.
LOCATION LAKE CHARLES LA 70602

LA0000761
PERMIT NUMBER

011
DISCHARGE NUMBER

F - FINAL LIMITS
MERCURY CELLS SEWER

MONITORING PERIOD								
YEAR	MO	DAY	TO	YEAR	MO	DAY		
83	01	01	TO	83	01	31		
(10-11)	(12-11)	(14-11)		(16-11)	(14-11)	(16-11)		

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE	SAMPLE MEASUREMENT	199	250		*****	*****	*****	*****	HA	CONT	RECORD
00058 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	GPM	*****	*****	*****	*****		CONTINUOUS	RECORD
MERCURY, TOTAL* (AS HG)	SAMPLE MEASUREMENT	0.03	0.077		*****	*****	*****	*****	0	3/7	24
71900 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	.21 DAILY AV	.42 DAILY MX	LBS/DY	*****	*****	*****	*****		THREE WEEK	COMP 2
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY KNOWLEDGE OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1363. (Penalties under this statute may include fines up to \$10,000 and/or maximum imprisonment of 5 years and 6 months.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

TYPED OR PRINTED

EXPLANATION OF ANY VIOLATIONS (SEE PPG DWG 20A-1-1577-P-6, STREAMS 5, 6):

THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.

*Sum of Outfall 011 + 111

SL 046694

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NATIONAL POLLUTANT DISCHARGE & ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
EPA No. 2000-0015

NAME **PPG INDUSTRIES INC.**
ADDRESS **G.C. STRICKLER - WORKS MANAGER**
P.O. BOX 1000
LAKE CHARLES LA 70602
FACILITY **PPG IND.**
LOCATION **LAKE CHARLES LA 70602**

LA00000761

PERMIT NUMBER

011/017/019

DISCHARGE NUMBER

F - FINAL LIMITS
SUM OF 011,017,019, FLOW & TSS

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY
83	01	01	83	01	31
(12-21)	(12-23)	(12-24)	(12-27)	(12-29)	(12-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE	SAMPLE MEASUREMENT	237	316	GPM	*****	*****	*****	*****	NA	CONT	RECORD
00058 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****		CONTINUOUS	RECORD
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	249	515	LBS/DY	*****	*****	*****	*****	0	3/7	24
00530 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	1118	2236		*****	*****	*****	*****		THREE WEEK	COMPE 24
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G.C. STRICKLER
WORKS MANAGER

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1318. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318 491-4500 83 01 31

AREA CODE NUMBER YEAR M DAY

SL 046695

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) DISCHARGE MONITORING REPORT (DMR)

Form Approved 8 No. 2000-0015

NAME **PPG INDUSTRIES INC.**
 ADDRESS **C. C. STRICKLER - WORKS MANAGER**
P O BOX 1000
LAKE CHARLES LA 70602
 FACILITY **PPG IND.**
 LOCATION **LAKE CHARLES LA 70602**

LA0000761
 PERMIT NUMBER

012
 DISCHARGE NUMBER

F - FINAL LIMITS
 HG CELL COOLING TWR BLOWDOWN

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
83	01	01	83	01	31
(16-17)	(12-13)	(14-15)	(16-17)	(12-13)	(14-15)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-43)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE	SAMPLE MEASUREMENT				*****	*****	*****	*****	NA	7/7	24 HT
00058 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	GPM	*****	*****	*****	*****		THREE WEEK	CALCT
MERCURY, TOTAL (AS HG)	SAMPLE MEASUREMENT				*****	*****	*****	*****	NA	3/7	24
71900 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	LBS/DY	*****	*****	*****	*****		THREE WEEK	COMP2
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER G. C. STRICKLER WORKS MANAGER TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 16 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)	TELEPHONE		DATE		
		318 491-4500		83	01	31
	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):
 THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.
 MERCURY SAMPLE TYPE LINEAR OR TIME COMPOSITE

SL 046696

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
EPA No. 2000-0015

NAME PPG INDUSTRIES INC.
ADDRESS G.C. STRICKLER - WORKS MANAGER
P O BOX 1000
LAKE CHARLES LA 70602
FACILITY PPG IND.
LOCATION LAKE CHARLES LA 70602

LA0000761
PERMIT NUMBER

013
DISCHARGE NUMBER

F - FINAL LIMITS

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
83	01	01	83	01	31
(10-11)	(12-13)	(14-15)	(16-17)	(18-19)	(20-31)

FROM

TO

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE	SAMPLE MEASUREMENT	12649	15440	GPM	*****	*****	*****	*****	11A	CONT	CALC
00058 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****			
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)	TELEPHONE		DATE		
		318	491-4500	83	01	31

G. C. STRICKLER
WORKS MANAGER
TYPED OR PRINTED

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

AREA CODE NUMBER YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SL 046697

PERMITTEE NAME/ADDRESS (include
Facility Name/Location if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
OMB No. 2000-001

NAME **PPG INDUSTRIES INC**
ADDRESS **G.C. Strickler - WORKS MANAGER**
P O BOX 1000
LAKE CHARLES LA 70602 **R**
FACILITY
LOCATION

(12-16)
LA000076
PERMIT NUMBER

(17-19)
015/016
DISCHARGE NUMBER

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
83	01	01	83	01	31
(12-21)	(12-22)	(12-23)	(12-21)	(12-22)	(12-23)

NOTE: Read Instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-63)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	130417	151056	GPM	*****	*****	*****	*****	NA	CONT	RECORD
	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****			
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G. C. STRICKLER
Works Manager

TYPED & PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC 1001 AND 23 USC 11219. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

318 401-4500

DATE

83 01 31

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SL 046698

PERMITTEE NAME (Include Facility Name/Location if different)

NAME G. C. STRICKLER PPG INDUSTRIES INC.

ADDRESS G.C. STRICKLER - WORKS MANAGER

P O BOX 1000

LAKE CHARLES LA 70602

FACILITY PPG IND.

LOCATION LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

LA0000761

PERMIT NUMBER

017

DISCHARGE NUMBER

F - FINAL LIMITS

LEAD TREATMENT DISCHARGE

Approved

No. 2000-0015

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	83	01	01		83	01	31
	(12-11)	(12-24)	(12-25)		(12-17)	(12-19)	(12-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE	SAMPLE MEASUREMENT	38	66		*****	*****	*****	*****	NA	CONT	RECORD
00058 1 0	PERMIT REQUIREMENT	*****	*****	GPM	*****	*****	*****	*****		CONTINUOUS	RECORD
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	7	13		*****	*****	*****	*****	NA	3/7	24 HC
SOLIDS, TOTAL	PERMIT REQUIREMENT	*****	*****	LBS/DY	*****	*****	*****	*****		THREE WEEK	COMP 24
SUSPENDED	SAMPLE MEASUREMENT	0.12	0.29		*****	*****	*****	*****	0	3/7	24 HC
00530 1 0	PERMIT REQUIREMENT	5.1	10.1	LBS/DY	*****	*****	*****	*****		THREE WEEK	COMP 24
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT										
LEAD, TOTAL	PERMIT REQUIREMENT										
(AS PB)	SAMPLE MEASUREMENT										
01051 1 0	PERMIT REQUIREMENT										
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G. C. STRICKLER
WORKS MANAGER

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

318 491-4500

AREA CODE NUMBER

DATE

83 01 31

YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

EXEMPTED FROM 201-1577-1583 STREAM 16.

HERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.

SL 046699

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
EPA No. 2000-0015

NAME **G. C. STRICKLER PPG INDUSTRIES INC.**
ADDRESS **PPG INDUSTRIES - WORKS MANAGER**
P O BOX 1000
LAKE CHARLES LA 70602
FACILITY **PPG IND.**
LOCATION **LAKE CHARLES LA 70602**

LA00000761
PERMIT NUMBER

018
DISCHARGE NUMBER

F - FINAL LIMITS
PROCESS WASTEWATER

MONITORING PERIOD								
YEAR			MO			DAY		
FROM			TO					
83			01			01		
(10-11)			(12-11)			(24-11)		

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
FLOW RATE	SAMPLE MEASUREMENT	3873	4624	GPM	*****	*****	*****	*****	NA	RECORD
00058 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****	CONT.	RECORD
BOD, 5-DAY (20 DEG. C)	SAMPLE MEASUREMENT	260	560	LBS/DY	*****	*****	*****	*****	1/7	24 HC
00310 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	774 DAILY AV	1298 DAILY MX		*****	*****	*****	*****	WEEKLY	COMP2
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	2603*	*****	LBS/DY	*****	*****	*****	*****	3/7	24 HC
00530 R 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	3100	*****		*****	*****	*****	*****	SEE PERMIT	
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	2047	5294	LBS/DY	*****	*****	*****	*****	3/7	24 HC
00530 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	4500 DAILY AV	8700 DAILY MX		*****	*****	*****	*****	THREE WEEK	COMP2
TOTAL ORGANIC CARBON (TOC)	SAMPLE MEASUREMENT	976	2359	LBS/DY	*****	*****	*****	*****	3/7	24 HC
00680 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	1300 DAILY AV	2600 DAILY MX		*****	*****	*****	*****	THREE WEEK	COMP2
CHLORINATED HYDRO- CARBONS, GENERAL	SAMPLE MEASUREMENT	113	222	LBS/DY	*****	*****	*****	*****	3/7	24 HC
4052 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	684 DAILY AV	1368 DAILY MX		*****	*****	*****	*****	THREE WEEK	COMP2
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G. C. STRICKLER
WORKS MANAGER

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

B. R. R.
SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

318 491-4500
AREA CODE NUMBER

DATE

83 01 31
YEAR MO DAY

IDENTIFY AND EXPLAIN ANY VIOLATIONS (Reference all attachments here) **018 AND 010.**

*Last twelve (12) months average

SL 046700

PERMITTEE NAME ADDRESS (Include Facility Name/Location if different)

NAME G. C. STRICKLER PPG INDUSTRIES INC.
 ADDRESS G.C. STRICKLER - WORKS MANAGER
P O BOX 1000
LAKE CHARLES LA 70602
 FACILITY PPG IND.
 LOCATION LAKE CHARLES LA 70602

NATIONAL POLLUTANT CHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

(2-16) LA0000761
 PERMIT NUMBER

(17-19) 021
 DISCHARGE NUMBER

F - FINAL LIMITS
 COOLING WATER

Form Approved
 OMB No. 2000-0015

MONITORING PERIOD								
FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY	
	83	01	01		83	01	31	
	(16-17)	(12-13)	(14-15)		(16-17)	(12-13)	(14-15)	

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-43)			(5 Card Only) QUALITY OR CONCENTRATION (46-51)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS					
TEMPERATURE, WATER DEG. FAHRENHEIT 00011 1 0	SAMPLE MEASUREMENT	*****	*****	*****	*****	67	83	DEG.F	NA	CONT	RECORD		
EFFLUENT GROSS VALUE FLOW RATE	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****			CONTI	RECORD		
00058 1 0	SAMPLE MEASUREMENT	21076	28550	GPM	*****	*****	*****	*****	NA	CONT	RECORD		
EFFLUENT GROSS VALUE PH	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****	*****	CONTI	RECORD		
00400 1 0	SAMPLE MEASUREMENT	*****	*****	*****	4.4	*****	10.2	SU	NA	CONT	RECORD		
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	***** MINIMUM	*****	***** MAXIMUM			CONTI	RECORD		
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G. C. STRICKLER
 WORKS MANAGER

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
 OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318 491-4500 83 01 31
 AREA CODE NUMBER YEAR MO DAY

NOTE: STATE HERE ANY VIOLATIONS (Reference all attachments here) OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.

SL 046701

PERMITTEE NAME ADDRESS (Include Facility Name (Location if different))

NAME G. C. STRICKLER PPG INDUSTRIES INC.

ADDRESS G. C. STRICKLER - WORKS MANAGER

P O BOX 1000

LAKE CHARLES LA 70602

FACILITY PPG IND.

LOCATION LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

LA00000761

024

PERMIT NUMBER

DISCHARGE NUMBER

F - FINAL LIMITS
SURFACE DRAINAGE - PRODN STRG

Form Approved
OMB No. 2000-0015

MONITORING PERIOD

YEAR	MO	DAY	TO	YEAR	MO	DAY
83	01	01	TO	83	01	31
(10-21)	(12-11)	(14-15)		(16-27)	(18-29)	(10-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
PH	SAMPLE MEASUREMENT	*****	*****	*****	6.5	*****	9.6		0	5/7*	GRAB
00400 1 0	PERMIT REQUIREMENT	*****	*****	*****	6.0	*****	11.0	SU		WEEK -	GRAB
EFFLUENT GROSS VALUE					MINIMUM		MAXIMUM			DAYS	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G. C. STRICKLER
WORKS MANAGER

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 1001 AND 33 U.S.C. 1321b. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318 491-4500

83 01 31

AREA
CODE

NUMBER

YEAR

MO

DAY

INDICATE ANY VIOLATIONS OF PERMIT CONDITIONS (Reference all attachments here)

*When flowing

Flow indicated five (5) times during month

SL 046702

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME G. C. STRICKLER PPG INDUSTRIES INC.
 ADDRESS G.C. STRICKLER - WORKS MANAGER
P O BOX 1000
LAKE CHARLES LA 70602
 FACILITY PPG IND.
 LOCATION LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

LA0000761
 PERMIT NUMBER

025
 DISCHARGE NUMBER

F - FINAL LIMITS
 STORM DRAINAGE 1500 T/D CHIRN

Approved
 B No. 2000-0015

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
83	01	01	83	01	31
(12-11)	(12-14)	(12-25)	(12-17)	(12-19)	(12-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE 10058 1 0 EFFLUENT GROSS VALUE PH	SAMPLE MEASUREMENT	<100	112	GPM	*****	*****	*****	*****	HA	5/7*	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****			
10400 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	8.5	*****	11.3	*****	HA	5/7*	GR
	PERMIT REQUIREMENT	*****	*****	*****	***** MINIMUM	*****	***** MAXIMUM	***** SD			
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G. C. STRICKLER
 WORKS MANAGER

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

318 491-4500

AREA CODE

NUMBER

DATE

83 01 31

YEAR MO DAY

STATEMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.

MONITOR WHILE FLOWING ALL PARAMETERS.

*When flowing

SL 046703

PERMITTEE NAME (Include Facility Name/Location if different)

NAME G. E. STRICKLER PPG INDUSTRIES INC.
 ADDRESS G. C. STRICKLER - WORKS MANAGER
P O BOX 1000
LAKE CHARLES LA 70602
 FACILITY PPG IND.
 LOCATION LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) MONITORING REPORT (DMR)

(2-16) LA00000761 PERMIT NUMBER
 (17-19) 026 DISCHARGE NUMBER

F - FINAL LIMITS
 STORM DRAINAGE

Approved
 DMB No. 2000-0015

MONITORING PERIOD								
YEAR			MO			DAY		
FROM	83	01	01	TO	83	01	31	
	(10-11)	(12-14)	(14-14)		(16-17)	(18-19)	(19-31)	

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE 00058 1 0 EFFLUENT GROSS VALUE PH	SAMPLE MEASUREMENT	50	506	GPM	*****	*****	*****	*****	NA	5/7*	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****		WEEK = DAYS	GRAB
00400 1 0 EFFLUENT GROSS VALUE PH	SAMPLE MEASUREMENT	*****	*****	*****	4.7	*****	9.7	SU	NA	5/7*	G
	PERMIT REQUIREMENT	*****	*****		***** MINIMUM	*****	***** MAXIMUM			WEEK = DAYS	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G. C. STRICKLER
 WORKS MANAGER

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
 OFFICER OR AUTHORIZED AGENT

TELEPHONE

318 491-4500

AREA
 CODE

NUMBER

DATE

83 01 31

YEAR MO DAY

IDENTIFY AND EXPLAIN ANY VIOLATIONS (Reference all attachments here)

*When flowing

SL 046704

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME G.F. STRICKLER PPG INDUSTRIES Inc.
 ADDRESS G.C. STRICKLER - WORKS MANAGER
P.O. BOX 1000
LAKE CHARLES LA 70602
 FACILITY PPG ID.
 LOCATION LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

(2-16)
 LA0000761
 PERMIT NUMBER

(17-19)
 001
 DISCHARGE NUMBER

F - FINAL LIMITS
 FINAL OUTFALL

Approved
 No. 2000-0015

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
83	02	01		83	02	28
(10-11)	(12-11)	(14-15)		(16-17)	(18-19)	(10-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
TEMPERATURE, WATER DEG. FAHRENHEIT 00011 1 0	SAMPLE MEASUREMENT	*****	*****	*****	*****	73	82		NA	CONT RECORD
EFFLUENT GROSS VALUE FLOW RATE	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	DEG.F		CONT RECORD
00058 1 0	SAMPLE MEASUREMENT	156232	178500		*****	*****	*****	*****	NA	CONT RECORD
EFFLUENT GROSS VALUE PH	PERMIT REQUIREMENT	*****	*****	GPM	*****	*****	*****	*****		CONT RECORD
00400 1 0	SAMPLE MEASUREMENT	*****	873	*****	3.4	*****	11.9		31 H=3	CONT RECORD
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	446	MIN/NO	6.0 MINIMUM	*****	9.0 MAXIMUM	SU		CONT RECORD
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G.F. STRICKLER
 WORKS MANAGER
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
 OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318 491-4500 83 02 28
 AREA CODE NUMBER YEAR MO DAY

REMARKS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.
 or pH -- see letter of 4/19/83, Attachment I

SL 046705

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME **G. C. STRICKLER** **PPG INDUSTRIES INC.**
 ADDRESS **P.O. BOX 1000**
LAKE CHARLES **LA 70602**
 FACILITY **PPG IND.**
 LOCATION **LAKE CHARLES** **LA 70602**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

LA0000761
 PERMIT NUMBER

005
 DISCHARGE NUMBER

F - FINAL LIMITS
 SURFACE RUNOFF

Form Approved
 No. 2000-0015

MONITORING PERIOD

FROM YEAR 83 MO 02 DAY 01 TO YEAR 83 MO 02 DAY 28
 (12-11) (12-12) (12-13) (13-17) (13-18) (13-19)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. FAHRENHEIT 0011 1 0 EFFLUENT GROSS VALUE LOW RATE	SAMPLE MEASUREMENT	*****	*****	*****	*****	83	95	DEG. F	NA	3/7	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****			THREE WEEK	GRAB
0058 1 0 EFFLUENT GROSS VALUE H	SAMPLE MEASUREMENT	524	1600	GPM	*****	*****	*****	*****	NA	3/7	GR
	PERMIT REQUIREMENT	*****	*****	GPM	*****	*****	*****	*****		THREE WEEK	GRAB
0400 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	7.1	*****	7.5	SU	0 0	3/7	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	MINIMUM 6.0	*****	MAXIMUM 9.0			THREE WEEK	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G. C. STRICKLER
WORKS MANAGER
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 23 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or minimum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
 OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318 491-4500
 AREA CODE NUMBER

83 02 28
 YEAR MO DAY

NOTE: SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.

SL 046706

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME G. C. STRICKLER PPG INDUSTRIES INC.
 ADDRESS G. C. STRICKLER - WORKS MANAGER
P O BOX 1000
LAKE CHARLES LA 70602
 FACILITY PPG IND.
 LOCATION LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

(2-16)
 LA0000761
 PERMIT NUMBER

(17-19)
 010
 DISCHARGE NUMBER

F - FINAL LIMITS
 AREA B UNCONTAMINATED CTBD

Form Approved
 No. 2000-0015

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
83	02	01		83	02	28
(16-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

NOTE: Read Instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
LOW RATE	SAMPLE MEASUREMENT	304	619	GPM	*****	*****	*****	*****	NA	CONT	RECORD
00058 1 0	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****		CONTI	RECORD
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	0.05	0.25	LBS/DY	*****	*****	*****	*****	0	3/7	24 -
CHROMIUM, TOTAL (AS CR)	PERMIT REQUIREMENT	DAILY AV 8	DAILY MX 16		*****	*****	*****	*****		THREE	COMP 24
01034 1 0	SAMPLE MEASUREMENT	*	*	LBS/DY	*****	*****	*****	*****			
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	DAILY AV 684	DAILY MX 1368		*****	*****	*****	*****		THREE	COMP 24
CHLORINATED HYDRO- CARBONS, GENERAL	SAMPLE MEASUREMENT										
4052 1 0	PERMIT REQUIREMENT										
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G. C. STRICKLER
 WORKS MANAGER
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
 OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318 491-4500 83 02 28
 AREA CODE NUMBER YEAR MO DAY

UNCONTAMINATED HYDROCARBONS (Reference all attachments here) LIMIT IS SUM OF 010 & 018.

* SEE OUT FALL 018

SL 046707

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME G.C. STRICKLER PPG INDUSTRIES INC.
 ADDRESS G.C. STRICKLER WORKS MANAGER
P O BOX 1000
LAKE CHARLES LA 70602
 FACILITY PPG IND.
 LOCATION LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

LA0000761
 PERMIT NUMBER

011
 DISCHARGE NUMBER

F - FINAL LIMITS
 MERCURY CELLS SEWER

Form Approved
 No. 2000-0015

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
83	02	01	83	02	28
(12-17)	(12-18)	(12-19)	(12-27)	(12-28)	(12-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
LOW RATE	SAMPLE MEASUREMENT	1169	228	GPM	*****	*****	*****	*****	NA	CONT	RECORD
00058 1 0	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****		CONT	RECORD
EFFLUENT GROSS VALUE											
MERCURY, TOTAL*	SAMPLE MEASUREMENT	0.02	0.03	LBS/DY	*****	*****	*****	*****	0	3/7	24
(AS HG)	PERMIT REQUIREMENT	.21	.42		*****	*****	*****	*****		THREE	COMP24
1900 1 0		DAILY AV	DAILY MX							WEEK	
EFFLUENT GROSS VALUE											
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G.C. STRICKLER
 WORKS MANAGER

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
 OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318 491-4500

83 02 28

AMOUNT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 HERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.
 *SUM OF OUTFALL OIL + III

SL 046708

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME G. C. STRICKLER PPG INDUSTRIES INC.
 ADDRESS G.C. STRICKLER WORKS MANAGER
P O BOX 1000
LAKE CHARLES LA 70602
 FACILITY PPG IND.
 LOCATION LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

F - FINAL LIMITS
 MERCURY TRACE SEWER

Approved
 No. 2000-0015

LA0000761

PERMIT NUMBER

111

DISCHARGE NUMBER

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	83	02	01		83	02	28
	(16-17)	(12-13)	(14-15)		(16-17)	(12-13)	(14-15)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
LOW RATE	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	*****	*****		
0058 1 0	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	*****		
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*	*		*****	*****	*****	*****		
MERCURY, TOTAL (AS HG)	PERMIT REQUIREMENT	0.21	0.42	LBS/DY	*****	*****	*****	*****		
1900 1 0	SAMPLE MEASUREMENT	DAILY AV	DAILY MX						THREE	COMP 24
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT								WEEK	
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

G. C. STRICKLER
 WORKS MANAGER

TYPED OR PRINTED

B. P. P.

318 491-4500 83 02 28
 AREA CODE NUMBER YEAR MO DAY

REMARKS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* SEE OUTFALL OIL

SL 046709

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME G.E. STRICKLER PPG INDUSTRIES Inc.
 ADDRESS C.O. STRICKLER WORKS MANAGER
P O BOX 1000
LAKE CHARLES LA 70602
 FACILITY PPG TMD
 LOCATION LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

LA0000761
 PERMIT NUMBER

011/017/019
 DISCHARGE NUMBER

F - FINAL LIMITS
 SUM OF 011,017,019, FLOW & TSS

Approved
 No. 2000-0015

MONITORING PERIOD

FROM YEAR 83 MO 02 DAY 01 TO YEAR 83 MO 02 DAY 28
 (12-31) (12-31) (12-31) (12-31) (12-31) (12-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-51)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE 00058 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	215	289	GPM	*****	*****	*****	*****	NA	CONT	RECORDED
	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****			
SOLIDS, TOTAL SUSPENDED 00530 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	109	181	LBS/DY	*****	*****	*****	*****	0	3/1	24
	PERMIT REQUIREMENT	1118	2236		*****	*****	*****	*****			
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G.E. STRICKLER
 WORKS MANAGER

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

313 491-4500

DATE

83 02 28

33 IS THE SUM OF 011,017 AND 019.

SL 046710

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME G.C. STRICKLER PPG INDUSTRIES Inc.
 ADDRESS G.C. STRICKLER - WORKS MANAGER
P O BOX 1000
LAKE CHARLES LA 70602
 FACILITY PPG IND.
 LOCATION LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

LA0000761
 PERMIT NUMBER

012
 DISCHARGE NUMBER

F - FINAL LIMITS
 HG CELL COOLING TWR BLOWDOWN

Approved
 No. 2000-0015

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
83	02	01		83	02	28
(10-11)	(11-11)	(12-11)		(12-11)	(11-11)	(10-11)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-51)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
LOW RATE	SAMPLE MEASUREMENT				*****	*****	*****	*****	NA	1/7	24 HR
0058 1 0	PERMIT REQUIREMENT	*****	*****	GPM	*****	*****	*****	*****		THREE	CALCULATED
EFFLUENT GROSS VALUE										WEEK	
MERCURY, TOTAL	SAMPLE MEASUREMENT				*****	*****	*****	*****	NA	3/7	24 H
(AS HG)	PERMIT REQUIREMENT	*****	*****	LBS/DY	*****	*****	*****	*****		THREE	COMPOSITE
1900 1 0										WEEK	
EFFLUENT GROSS VALUE											
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NO DISCHARGE

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G.C. STRICKLER
 WORKS MANAGER

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
 OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318 491-4500

83 02 28

IN THE EVENT OF ANY VIOLATION OF ANY OTHER STREAM(S).

SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.

SAMPLE TYPE LINEAR OR TIME COMPOSITE

SL 046711

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME G.C. STRICKLER PPG INDUSTRIES INC.
 ADDRESS G.C. STRICKLER - WORKS MANAGER
P.O. BOX 1000
LAKE CHARLES LA 70602
 FACILITY PPG IND.
 LOCATION LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

LA0000761
 PERMIT NUMBER

013
 DISCHARGE NUMBER

F - FINAL LIMITS

Form Approved
 No. 2000-0015

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
83	02	01	83	02	28
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE 00058 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	12771	15440	GPM	*****	*****	*****	*****	NA	CONT	CALC
	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****			
	SAMPLE MEASUREMENT									CONT	CALC
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT									CONT	CALC
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT									CONT	CALC
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT									CONT	CALC
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT									CONT	CALC
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT									CONT	CALC
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT									CONT	CALC
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT									CONT	CALC
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G.C. STRICKLER
 WORKS MANAGER

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1315. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

318 491-4600

DATE

83 02 28

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SL 046712

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
EPA No. 2000-001

NAME PPG INDUSTRIES INC
ADDRESS G.C. Strickler - WORKS MANAGER
P O BOX 1000
LAKE CHARLES LA 70602 R
FACILITY
LOCATION

LA0000761
PERMIT NUMBER

015/016
DISCHARGE NUMBER

MONITORING PERIOD								
YEAR	MO	DAY		YEAR	MO	DAY		
83	02	01	TH	83	02	28		
(12-31)	(12-31)	(12-31)		(12-31)	(12-31)	(12-31)		

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (58-65)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	107412	128399	GPM	*****	*****	*****	*****		NA CONT	RECORD
	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****			
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G. C. STRICKLER
Works Manager

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 1001 AND 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

318 491-4500

AREA
CODE

NUMBER

DATE

83 02 28

YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SL 046713

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME G. C. STRICKLER - PPG INDUSTRIES INC.
 ADDRESS G. C. STRICKLER - WORKS MANAGER
P O BOX 1000
LAKE CHARLES LA 70602
 FACILITY PPG IND.
 LOCATION LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

(2-16) LA0000761 (17-19) 017
 PERMIT NUMBER DISCHARGE NUMBER

F - FINAL LIMITS
 LEAD TREATMENT DISCHARGE

Approved
 No. 2000-0015

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
83	02	01	83	02	28
(12-11)	(12-12)	(24-25)	(12-17)	(12-18)	(12-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
LOW RATE	SAMPLE MEASUREMENT	46	108	GPM	*****	*****	*****	*****	NA	CONT	RECORD
0058 1 0	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****		CONTINUOUS	RECORD
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	5	13	LBS/DY	*****	*****	*****	*****	NA	3/7	24
SOLIDS, TOTAL	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****		THREE WEEK	COMP 24
SUSPENDED	SAMPLE MEASUREMENT	0.10	0.21	LBS/DY	*****	*****	*****	*****	0	3/7	24 HC
0530 1 0	PERMIT REQUIREMENT	5.1	10.1		*****	*****	*****	*****		THREE WEEK	COMP 24
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT										
LEAD, TOTAL	PERMIT REQUIREMENT										
(AS Pb)	SAMPLE MEASUREMENT										
1051 1 0	PERMIT REQUIREMENT										
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G. C. STRICKLER
 WORKS MANAGER

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 16 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318 491-4500

83 02 28

HERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.

SL 046711

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME G.E. STRICKLER PPG INDUSTRIES INC.
 ADDRESS G.E. STRICKLER WORKS MANAGER
P O BOX 1000
LAKE CHARLES LA 70602
 FACILITY PPG IND.
 LOCATION LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

LA0000761
 PERMIT NUMBER

018
 DISCHARGE NUMBER

F - FINAL LIMITS
 PROCESS WASTEWATER

Approved
 No. 2000-0015

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
83	02	01	83	02	28
(12-21)	(12-21)	(12-21)	(12-21)	(12-21)	(12-21)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
LOW RATE	SAMPLE MEASUREMENT	5378	6088	GPM	*****	*****	*****	*****	NA	CONT	RECORD
0058 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****		CONT	RECORD
OD, 5-DAY (20 DEG. C)	SAMPLE MEASUREMENT	170	201	LBS/DY	*****	*****	*****	*****	0	1/7	25 =
0310 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	774 DAILY AV	1298 DAILY MX		*****	*****	*****	*****		WEEKLY	COMP24
SOLIDS, TOTAL UNSPENDED	SAMPLE MEASUREMENT	2554 *	*****	LBS/DY	*****	*****	*****	*****	0	3/7	24HC
0530 R 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	3100	*****		*****	*****	*****	*****		SEE PERMIT	
SOLIDS, TOTAL UNSPENDED	SAMPLE MEASUREMENT	1492	2030	LBS/DY	*****	*****	*****	*****	0	3/7	24HC
0530 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	4500 DAILY AV	8700 DAILY MX		*****	*****	*****	*****		THREE/ WEEK	COMP24
TOTAL ORGANIC CARBON (TOC)	SAMPLE MEASUREMENT	808	1059	LBS/DY	*****	*****	*****	*****	0	3/7	24HC
0680 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	1300 DAILY AV	2600 DAILY MX		*****	*****	*****	*****		THREE/ WEEK	COMP24
CHLORINATED HYDRO- CARBONS, GENERAL	SAMPLE MEASUREMENT	154	581	LBS/DY	*****	*****	*****	*****	0	3/7	25 =
4052 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	684 DAILY AV	1368 DAILY MX		*****	*****	*****	*****		THREE/ WEEK	COMP24
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G.E. STRICKLER
 WORKS MANAGER

TYPED & PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 1001 AND 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

B. [Signature]

TELEPHONE

318 491-4500

AREA CODE

NUMBER

DATE

83 02 28

YEAR M DAY

IDENTIFIED VIOLATIONS (Reference all attachments here) IS THE SUM OF 01R AND 010.

*Last 12 months average

5L 046, 714A

PERMITTEE NAME ADDRESS (Include Facility Name/Location if different)

NAME G.C. STRICKLER PPG INDUSTRIES INC.
 ADDRESS CC STRICKLER - WORKS MANAGER
P O BOX 1000
LAKE CHARLES LA 70602
 FACILITY PPG IND.
 LOCATION LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) MONITORING REPORT (DMR)

LA0000761
 PERMIT NUMBER

021
 DISCHARGE NUMBER

F - FINAL LIMITS
 COOLING WATER

Approved
 B No. 2000-0015

MONITORING PERIOD						
FROM			TO			
YEAR	MO	DAY	YEAR	MO	DAY	
83	02	01	83	02	28	
(20 21)	(22 23)	(24 25)	(26 27)	(28 29)	(30 31)	

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
TEMPERATURE, WATER DEG. FAHRENHEIT 00011 1 0	SAMPLE MEASUREMENT	*****	*****	*****	*****	72	88		NA	CONT RECORD
EFFLUENT GROSS VALUE FLOW RATE	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	DEG. F		CONTINUOUS RECORD
00058 1 0	SAMPLE MEASUREMENT	19604	27300		*****	*****	*****	*****	NA	CONT RE 30
EFFLUENT GROSS VALUE PH	PERMIT REQUIREMENT	*****	*****	GPM	*****	*****	*****	*****		CONTINUOUS RECORD
00400 1 0	SAMPLE MEASUREMENT	*****	*****	*****	6.0	*****	9.9		NA	CONT RECORD
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	MINIMUM	*****	MAXIMUM	SI		CONTINUOUS RECORD
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G.C. STRICKLER
 WORKS MANAGER

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318 491-4600 83 02 28
 AREA CODE NUMBER YEAR M DAY

HERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.

SL 046715

PERMITTEE NAME (Include Facility Name/Location if different)

NAME G. E. STRICKLER PPG INDUSTRIES INC.
 ADDRESS G. E. STRICKLER - WORKS MANAGER
P O BOX 1000
LAKE CHARLES LA 70602
 FACILITY PPG IND.
 LOCATION LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

(2-16) LA0000761 (17-19) 024
 PERMIT NUMBER DISCHARGE NUMBER

F - FINAL LIMITS
 SURFACE DRAINAGE - PRODN STRG

Approved
 DMB No. 2000-0015

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
83	02	01	83	02	28
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
PH	SAMPLE MEASUREMENT	*****	*****	*****	7.5	*****	9.7		50		
00400 1 0	PERMIT REQUIREMENT	*****	*****	*****	6.0	*****	11.0	SU	40	5/7*	Grab
EFFLUENT GROSS VALUE					MINIMUM		MAXIMUM			WEEK -	GRAB
										DAYS	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 1001 AND 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

B. Ray
 SIGNATURE OF PRINCIPAL EXECUTIVE
 OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

TYPED OR PRINTED

WHEN AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* WHEN FLOWING

Flow indicated six (6) times during month

AREA
 CODE NUMBER YEAR MO DAY

SL 046716

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
OMB No. 2000-0015

NAME **G.C. STRICKLER** **PPG INDUSTRIES INC.**
ADDRESS **P.O. BOX 1000**
LAKE CHARLES **LA 70602**
FACILITY **PPG IND.**
LOCATION **LAKE CHARLES** **LA 70602**

(2-16) **LA00000761**
PERMIT NUMBER
(17-19) **025**
DISCHARGE NUMBER

F - FINAL LIMITS
STORM DRAINAGE 1500 TPD CHLOR

MONITORING PERIOD
FROM YEAR **83** MO **02** DAY **01** TO YEAR **83** MO **02** DAY **28**
(10-11) (12-13) (14-15) (16-17) (18-19) (20-21)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
LOW RATE	SAMPLE MEASUREMENT	<100	238	GPM	*****	*****	*****	*****	NA	5/7*	GRAB
00058 1. 0	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****		DAILY	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	6.4	*****	9.5		NA	5/7*	GI 3
PH	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	SU		DAILY	GRAB
00400 1. 0	SAMPLE MEASUREMENT				MINIMUM		MAXIMUM				
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G.C. STRICKLER
WORKS MANAGER

TYPED OR PRINTED

EXPLAINING EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS,
INITIATOR WHILE FLOWING ALL PARAMETERS,
WHEN FLOWING

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318 / 491-4500 83 02 28
NUMBER YEAR MO DAY

SL 046717

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME G. E. SICKLER
 ADDRESS WORKS MANAGER
P O BOX 1000
LAKE CHARLES LA 70602
 FACILITY PPG IND.
 LOCATION LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

(2-16)
LA0000761
 PERMIT NUMBER

(17-19)
026
 DISCHARGE NUMBER

F - FINAL LIMITS
 STORM DRAINAGE

Form Approved
 EPA No. 2000-0015

MONITORING PERIOD						
FROM			TO			
YEAR	MO	DAY	YEAR	MO	DAY	
83	02	01	83	02	28	
(10-11)	(12-13)	(14-15)	(16-17)	(18-19)	(20-31)	

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				N EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
LOW RATE	SAMPLE MEASUREMENT	79	506	GPM	*****	*****	*****	*****	NA	5/7*	GRAB
00058 1 0	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****		WEEK -	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	*****	*****		DAYS	
PH	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	*****			
00400 1 0	SAMPLE MEASUREMENT	*****	*****	*****	6.3	*****	8.3	*****	NA	5/7*	G. B
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	*****		WEEK -	GRAB
	SAMPLE MEASUREMENT				MINIMUM		MAXIMUM			DAYS	
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 U.S.C. § 1001 AND 33 USC § 1318. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

B. Powell

SIGNATURE OF PRINCIPAL EXECUTIVE
 OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

TYPED OR PRINTED

AREA
 CODE

NUMBER

YEAR

MO

DAY

WHEN FLOWING

WHEN FLOWING

SL 046718

PERMITTEE NAME (Include Facility Name/Location if different)

NAME G. C. Strickler WORKS MANAGER
 ADDRESS LA 7-602
 CITY LA 7-602
 STATE LA 7-602
 FACILITY LA 7-602
 LOCATION LA 7-602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

LA0000761
 PERMIT NUMBER

001
 DISCHARGE NUMBER

F - FINAL LIMITS
 FINAL OUTFALL

Form Approved
 MB No. 2000-0015

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
83	03	01	83	03	31
(12-11)	(12-13)	(12-15)	(12-17)	(12-19)	(12-21)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (46-51)			(4 Card Only) QUALITY OR CONCENTRATION (46-53)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. FAHRENHEIT 00011 1 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	80	88		NA	CONT	RECORD
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	DEG. F		CONT	RECORD
FLOW RATE 00058 1 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	183145	197500	GPM	*****	*****	*****	*****	NA	CONT	RECORD
	PERMIT REQUIREMENT	*****	*****	GPM	*****	*****	*****	*****		CONT	RECORD
pH 00400 1 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	537	*****	2.7	*****	12.3	L= 2 H= 2	2	CONT	RECORD
	PERMIT REQUIREMENT	*****	446	MIN/MO	6.0 MINIMUM	*****	9.0 MAXIMUM	SD		CONT	RECORD
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 19 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)	Bill Paul SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
G. C. Strickler Works Manager			318	491-4500	83	03	31
TYPED OR PRINTED			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.

For pH -- See letter of 4/19/83, Attachment I

SL 046719

PERMITTEE NAME (Include Facility Name/Location if different)

NAME G. C. Strickler PPG INDUSTRIES INC.
 ADDRESS G.C. Strickler - Works A AGEP
LAKE CHARLES LA 70602
 FACILITY PPG INC.
 LOCATION LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

(2-16)
 LA0001761
 PERMIT NUMBER

(17-19)
 005
 DISCHARGE NUMBER

F - FINAL LIMITS
 SURFACE RUNOFF

Form Approved
 MB No. 2000-0015

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
83	03	01	83	03	31
(10-31)	(12-31)	(14-15)	(16-31)	(12-31)	(10-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
TEMPERATURE, WATER DEG. FAHRENHEIT 00011 1 0 EFFLUENT GROSS VALUE FLOW RATE	SAMPLE MEASUREMENT	*****	*****	*****	*****	82	86		NA	3/7 GRAB
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	DEG.F		THREE/ GRAB WEEK
00058 1 0 EFFLUENT GROSS VALUE PH	SAMPLE MEASUREMENT	489	680		*****	*****	*****	*****	NA	3/7 C 3
	PERMIT REQUIREMENT	*****	*****	GPM	*****	*****	*****	*****		THREE/ GRAB WEEK
00400 1 0 EFFLUENT GROSS VALUE PH	SAMPLE MEASUREMENT	*****	*****	*****	7.2	*****	7.4	L=0 H=0	3/7	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	6.0 MINIMUM	*****	9.0 MAXIMUM	SU		THREE/ GRAB WEEK
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
G. C. Strickler
Works Manager
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT
Burt Pany

TELEPHONE
 318 491-4500
 AREA CODE NUMBER
 DATE
 83 03 31
 YEAR M DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 LOCAL DRAINAGE DISTRICTS OF PLANTS SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.

SL 046720

PERMITTEE NAME (Include Facility Name/Location if different)

NAME G. C. Strickler PPG Industries Inc
ADDRESS G. C. Strickler - Works Manager

DATE 01 MAY 1983

FACILITY PPG ITP

LOCATION LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

LA 10 0761
PERMIT NUMBER

010
DISCHARGE NUMBER

F - FINAL LIMITS
AREA W UNCONTAMINATED CTED

Form Approved
MB No. 2000-0015

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
83	03	01	83	03	31
(16-17)	(21-23)	(24-31)	(16-17)	(21-23)	(24-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE	SAMPLE MEASUREMENT	357	795		*****	*****	*****	*****	NA	CONT	RECORD
00058 1 0	PERMIT REQUIREMENT	*****	*****	GPM	*****	*****	*****	*****		CONTI	RECORD
EFFLUENT GROSS VALUE										HOUS	
CHROMIUM, TOTAL (AS CR)	SAMPLE MEASUREMENT	0.005	0.02		*****	*****	*****	*****	0	3/7	2 AC
01034 1 0	PERMIT REQUIREMENT	8	16	LBS/DY	*****	*****	*****	*****		THREE	COMP2
EFFLUENT GROSS VALUE		DAILY AV	DAILY MX							WEEK	
CHLORINATED HYDRO- CARBONS, GENERAL	SAMPLE MEASUREMENT	*	*		*****	*****	*****	*****			
74052 1 0	PERMIT REQUIREMENT	684	1368	LBS/DY	*****	*****	*****	*****		THREE	COMP2
EFFLUENT GROSS VALUE		DAILY AV	DAILY MX							WEEK	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G. C. Strickler
Works Manager

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 per day or imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318 491-4500

83 03 31

AREA
CODE

NUMBER

YEAR

MO

DAY

OTHER INFORMATION (If any, include in separate attachments)

*See Outfall 018

SL 046721

PERMITTEE NAME (Include Facility Name/Location if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2000-001

NAME G. C. Strickler PPG Industries Inc.
ADDRESS PPG 1000
LAKE CHARLES LA 70602
FACILITY PPG 1000
LOCATION LAKE CHARLES LA 70602

LAKE CHARLES
PERMIT NUMBER

011
DISCHARGE NUMBER

F - FINAL LIMITS
MERCURY CELLS SEWER

MONITORING PERIOD
FROM YEAR 83 MO 03 DAY 01 TO YEAR 83 MO 03 DAY 31
(12-31) (12-31) (12-31) (12-31) (12-31) (12-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
FLOW RATE	SAMPLE MEASUREMENT	150	190	GPM	*****	*****	*****	*****	NA	CONT
0005R 1 0	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****		RECORD
EFFLUENT GROSS VALUE										
MERCURY, TOTAL *	SAMPLE MEASUREMENT	0.03	0.17	LBS/DY	*****	*****	*****	*****	0	3/7
(AS HG)	PERMIT REQUIREMENT	.21	.42		*****	*****	*****	*****		2 IC
71900 1 0		DAILY AV	DAILY MX							
EFFLUENT GROSS VALUE										
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G. C. Strickler
Works Manager

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318 | 491-4500

83 | 03 | 31

AREA
CODE

NUMBER

YEAR

MO

DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (SEE PPG DWG 20A-1-1577-P-6, STREAMS 5,6).
THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.

*Sum of Outfall 011 + 111

SL 046722

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME G. C. Strickler PPG Industries Inc.
 ADDRESS G. C. Strickler WORKS MANAGER
P O BOX 1000
LAKE CHARLES LA 70602
 FACILITY PPG IND.
 LOCATION LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

LA0000761
 PERMIT NUMBER

111
 DISCHARGE NUMBER

F - FINAL LIMITS
 MERCURY TRACE SEWER

Form Approved
 MB No. 2000-0011

MONITORING PERIOD

FROM YEAR 83 MO 03 DAY 01 TO YEAR 83 MO 03 DAY 31
 (10-31) (12-31) (12-31) (10-31) (12-31) (12-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (34-35)			(4 Card Only) QUALITY OR CONCENTRATION (34-35)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
FLOW RATE	SAMPLE MEASUREMENT	***** 391	***** 450	*****	*****	*****	*****	*****	NA	CONT RECORD
00058 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	*****		CONTI RECORD
MERCURY, TOTAL (AS HG)	SAMPLE MEASUREMENT	*	*		*****	*****	*****	*****		
71900 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	0.21 DAILY AV	0.42 DAILY MX	LBS/DY	*****	*****	*****	*****	THREE/CO MP2 WEEK	
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G. C. Strickler
 Works Manager

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT, SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
 OFFICER OR AUTHORIZED AGENT

TELEPHONE

318 491-4500

AREA
 CODE

NUMBER

DATE

83 03 31

YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

*See Outfall 011

SL 046723

PERMITTEE NAME (Include Facility Name if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2000-001

NAME G. C. Strickler PPG INDUSTRIES Inc.

ADDRESS PPG INDUSTRIES Inc. WORKS MANAGER

P.O. BOX 1000

LAKE CHARLES LA 70602

FACILITY PPG IND.

LOCATION LAKE CHARLES LA 70602

LA0000761
PERMIT NUMBER

011/017/019
DISCHARGE NUMBER

F - FINAL LIMITS
SUM OF 011,017,019, FLOW & TSS

MONITORING PERIOD							
FROM			TO				
YEAR	MO	DAY	YEAR	MO	DAY		
83	03	01	83	03	31		
(28-31)	(32-34)	(24-26)	(28-31)	(32-34)	(24-26)		

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE	SAMPLE MEASUREMENT	179	226	GPM	*****	*****	*****	*****	NA	CONT	RECORD
00058 1 0	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****		CONT	RECORD
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	90	215	LBS/DY	*****	*****	*****	*****	0	3/7	2 C
SOLIDS, TOTAL	PERMIT REQUIREMENT	1118	2236		*****	*****	*****	*****		THREE	COMP
SUSPENDED	SAMPLE MEASUREMENT										
00530 1 0	PERMIT REQUIREMENT										
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G. C. Strickler
Works Manager

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1310. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

318 | 491-4500

DATE

83 | 03 | 31

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SL 046724

PERMITTEE NAME ADDRESS (Include Facility Name/Location if different)

NAME G. C. Strickler PPG INDUSTRIES INC.
 ADDRESS G. C. Strickler - WORKS MANAGER
LAKE CHARLES LA 70602
 FACILITY PPG F.D.
 LOCATION LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-18)

F - FINAL LIMITS
 HG CELL COOLING TWR PLENDOR

Form Approved
 OMB No. 2000-001

140000761
 PERMIT NUMBER

012
 DISCHARGE NUMBER

MONITORING PERIOD

FROM YEAR MO DAY TO YEAR MO DAY
 83 03 01 83 03 31
 (28-29) (32-34) (34-35) (28-29) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (34-41)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE	SAMPLE MEASUREMENT				*****	*****	*****	*****	NA	7/7	24 HT
00058 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	GPM	*****	*****	*****	*****		THREE WEEK	CALC
MERCURY, TOTAL (AS HG)	SAMPLE MEASUREMENT				*****	*****	*****	*****	NA	3/7	2 JC
71900 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	LBS/DY	*****	*****	*****	*****		THREE WEEK	COMP
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G. C. Strickler
 Works Manager

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY KNOWLEDGE OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1316. (Impersonating under these statutes may include fines up to \$10,000 and/or imprisonment for up to 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

318 491-4500

DATE

83 03 31

HERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.
 MERCURY SAMPLE TYPE LINEAR OR TIME COMPOSITE

SL 046725

PERMITTEE NAME ADDRESS (Include Facility Name/Location if different)

NAME G. B. Strickler PPG INDUSTRIES Inc.
 ADDRESS G. C. Strickler WORKS MANAGER
P O BOX 1400
LAKE CHARLES LA 70602
 FACILITY PPG IND.
 LOCATION LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

F - FINAL LIMITS

Form Approved
 OMB No. 2000 001

LA0000761

013

PERMIT NUMBER

DISCHARGE NUMBER

MONITORING PERIOD

FROM			TO		
YEAR	MO	DAY	YEAR	MO	DAY
83	03	01	83	03	31
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE	SAMPLE MEASUREMENT	12434	15440		*****	*****	*****	*****		NA	CALC
00058	PERMIT REQUIREMENT	*****	*****	GPM	*****	*****	*****	*****		CONT	CALC
EFFLUENT GROSS VALUE											
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

MANUFACTURE PRINCIPAL EXECUTIVE OFFICER

G. B. Strickler

WORKS MANAGER

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY KNOWLEDGE OF THE INFORMATION I BELIEVE THE INFORMATION IS TRUE AND ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

[Signature]

TELEPHONE

318 491-4500

DATE

83 03 31

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SL 046726

PERMITTEE NAME ADDRESS (Include Facility Name / Location if different)

NAME PPG INDUSTRIES INC
 ADDRESS G.C. Strickler - WORKS MANAGER
P O BOX 1000
LAKE CHARLES LA 70602 R
 FACILITY _____
 LOCATION _____

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

LA0000761

PERMIT NUMBER

015/016

DISCHARGE NUMBER

MONITORING PERIOD

YEAR	MO	DAY	TH	YEAR	MO	DAY
83	03	01	TH	83	03	31
(12-21)	(12-24)	(12-31)	RU	(12-21)	(12-24)	(12-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPL TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	116407	124738	GPM	*****	*****	*****	*****	NA	CONT	RECORD
	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****		CONTINUOUS	CALCULATED
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G. C. STRICKLER
 Works Manager

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY KNOWLEDGE OF THE INFORMATION I BELIEVE THE INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 U.S.C. § 1001 AND 25 U.S.C. § 1321b. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SI NATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

318 491-4500

AREA CODE

NUMBER

DATE

83 03 31

YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SL 046727

EMPLOYEE NAME (Include
City Name/Location if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2000-0015

NAME G. C. Strickler PPG INDUSTRIES INC.
ADDRESS G.C. Strickler WORKS MANAGER
P.O. BOX 1500
LAKE CHARLES LA 70602
FACILITY PPG IND.
LOCATION LAKE CHARLES LA 70602

(2-16)
LA00000761
PERMIT NUMBER

(17-19)
017
DISCHARGE NUMBER

F - FINAL LIMITS
LEAD TREATMENT DISCHARGE

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
83	03	01	83	03	31
(10-11)	(12-13)	(14-15)	(16-17)	(18-19)	(20-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (58-65)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
FLOW RATE	SAMPLE MEASUREMENT	29	42	GPM	*****	*****	*****	*****	NA	CONT
00058 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****		CONTINUOUS
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	3	10	LBS/DY	*****	*****	*****	*****	NA	3/7 24 HC
00530 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****		THREE WEEK
LEAD, TOTAL (AS PB)	SAMPLE MEASUREMENT	0.05	0.10	LBS/DY	*****	*****	*****	*****	0	3/7 24 HC
01051 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	5.1 DAILY AV	10.1 DAILY MX		*****	*****	*****	*****		THREE WEEK
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREON AND BASED ON MY KNOWLEDGE OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 22 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

G. C. Strickler
Works Manager

318 491-4500

83 03 31

TYPED OR PRINTED

AREA CODE NUMBER

YEAR MO DAY

STATEMENT AND EXPLANATION OF ANY VIOLATIONS (See instructions and attachments here)

THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.

SL 04672F

PERMITTEE NAME (Include Facility Name/Location if different)

NAME G. C. STRICKLER PPG INDUSTRIES INC.

ADDRESS B.C. STRICKLER WORKS MANAGER

P.O. BOX 1000

LAKE CHARLES

LA 70602

FACILITY PPG IND.

LOCATION LAKE CHARLES

LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

LA0000761

PERMIT NUMBER

018

DISCHARGE NUMBER

P - FINAL LIMITS
PROCESS WASTEWATER

Form Approved
OMB No. 2000-001

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	83	03	01		83	03	31
	(12-31)	(12-31)	(12-31)		(12-31)	(12-31)	(12-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE	SAMPLE MEASUREMENT	5050	5611	GPM	*****	*****	*****	*****	NA	CONT	RECORD
00058 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****		CONTI	PCORP
900, 5-DAY (20 DEG. C)	SAMPLE MEASUREMENT	262	335	LBS/DY	*****	*****	*****	*****	0	1/7	2 IC
00310 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	774	1298		*****	*****	*****	*****		WEEKLY	COMP2
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	2395*	*****	LBS/DY	*****	*****	*****	*****	0	3/7	24 HC
00530 2 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	3100	*****		*****	*****	*****	*****		SEE PERMIT	
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	1435	2145	LBS/DY	*****	*****	*****	*****	0	3/7	24 HC
00530 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	4500	8700		*****	*****	*****	*****		THREE WEEK	COMP2
TOTAL ORGANIC CARBON (TOC)	SAMPLE MEASUREMENT	1267	2710	LBS/DY	*****	*****	*****	*****	1	3/7	24 HC
00680 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	1300	2600		*****	*****	*****	*****		THREE WEEK	COMP2
CHLORINATED HYDRO- CARBONS, GENERAL	SAMPLE MEASUREMENT	270	818	LBS/DY	*****	*****	*****	*****	0		
74052 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	684	1368		*****	*****	*****	*****		THREE WEEK	COMP2
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

G. C. Strickler
Works Manager

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY KNOWLEDGE OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1362. (Providing under these statutes may include fines up to \$10,000 and/or imprisonment for up to 5 years and 6 months.)

Eric Paul
SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

318 491-4500

DATE

83 03 31

*Last 12 Months Average

For TOC -- see letter of 4/19/83, Attachment III

SL 046729

PERMITTEE NAME (Include Facility Name/Location if different)

NAME G. C. Strickler PPG Industries Inc.
 ADDRESS G.C. Strickler - Works Manager
P.O. BOX 1000
LAKE CHARLES LA 70602
 FACILITY PPG IND.
 LOCATION LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

(2-16)
 LA0000761
 PERMIT NUMBER

(17-19)
 021
 DISCHARGE NUMBER

F - FINAL LIMITS
 COOLING WATER

Form Approved
 MB No. 2000 0011

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
83	03	01	83	03	31
(18-19)	(21-23)	(24-25)	(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. FAHRENHEIT 00011 1 0	SAMPLE MEASUREMENT	*****	*****	*****	*****	83	94		NA	CONT	RECORD
EFFLUENT GROSS VALUE FLOW RATE	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	DEG. F		CONTINUOUS	RECORD
00058 1 0	SAMPLE MEASUREMENT	12014	15750		*****	*****	*****	*****	NA	CONT	RECORD
EFFLUENT GROSS VALUE PH	PERMIT REQUIREMENT	*****	*****	GPM	*****	*****	*****	*****		CONTINUOUS	RECORD
00400 1 0	SAMPLE MEASUREMENT	*****	*****	*****	6.0	*****	9.7		NA	CONT	RECORD
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	SU		CONTINUOUS	RECORD
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE			
G. C. Strickler Works Manager			318 491-4500	83	03	31	
TYPED OR PRINTED			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):
 THERE WAS NO ESCAPE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.

SL 046730

SL 046731

PERMITTEE NAME (Include Facility Name/Location if different)

NAME G. C. Strickler PPG INDUSTRIES Inc.
 ADDRESS G.C. Strickler WORKS MANAGER
P.O. BOX 1000
LAKE CHARLES LA 70602
 FACILITY PPG IND.
 LOCATION LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

(2-16) LA0000761
 PERMIT NUMBER
 (17-19) 025
 DISCHARGE NUMBER

Form Approved OMB No. 2000-0011
 F - FINAL LIMITS
 STORM DRAINAGE 1500 T/D CHLOR

MONITORING PERIOD
 FROM YEAR MO DAY TO YEAR MO DAY
 (20-21) 83 03 01 (22-23) 83 03 31
 (24-25) (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE	SAMPLE MEASUREMENT	<100	<100		*****	*****	*****	*****	NA	5/7*	GRAB
00058 1 0	PERMIT REQUIREMENT	*****	*****	GPM	*****	*****	*****	*****		DAILY	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	7.6	*****	11.0		NA	5/7*	G
PH	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	SU		DAILY	GRAB
00400 1 0	SAMPLE MEASUREMENT				MINIMUM		MAXIMUM				
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE			
G. C. Strickler Works Manager			318 491-4500	83	03	31	
TYPED OR PRINTED			AREA CODE	NUMBER	YEAR	M	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SEE PPG 17-6 2000-1577-1108.
 THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.
 MONITOR WHILE FLOWING ALL PARAMETERS.
 *When Flowing

SL 046732

PERMITTEE NAME (Include Facility Name/Location if different)

NAME G. C. Strickler PPG INDUSTRIES Inc.
 ADDRESS 6 C. Strickler WORKS MANAGER
PO BOX 1800
LAKE CHARLES LA 70602
 FACILITY PPG IND.
 LOCATION LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

(2-16) (17-18)
 LA0000761 026
 PERMIT NUMBER DISCHARGE NUMBER

F - FINAL LIMITS
 STORM DRAINAGE

Form Approved
 OMB No. 2000-0011

MONITORING PERIOD
 FROM YEAR MO DAY TO YEAR MO DAY
 83 03 01 83 03 31
 (10-11) (12-11) (14-13) (16-17) (18-19) (10-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-43)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE	SAMPLE MEASUREMENT	24	64	GPM	*****	*****	*****	*****	NA	5/7*	GRAB
00058 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****		WEEK-DAYS	GRAB
PH	SAMPLE MEASUREMENT	*****	*****	*****	4.1	*****	8.3	SU	NA	5/7*	GRAB
00400 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****		MINIMUM	*****	MAXIMUM			WEEK-DAYS	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREON AND BASED ON MY KNOWLEDGE OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE		
G. C. Strickler Works Manager TYPED OR PRINTED			318 491-4500	83	03	31

EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

*When Flowing

SL 046733