



7000154

AREA CODE 206/VI 2-5726

Ev 45

ZONOLITE

VERMICULITE-NORTHWEST, INC.

P.O. BOX A
102 C STREET SOUTHWEST
AUBURN, WASHINGTON 98002

A SUBSIDIARY OF W. R. GRACE & CO.

January 24, 1972

EXH. 45 DATE 1-26-84
WITNESS CH. VER
Sutton Cannon
Court ReporterCrawford Co.
6900 S. W. Haines Rd.
Rm 1 Plaza S. W.
Portland, Oregon 97222

Atten: Logan Clark

Dear Mr. Clark:

We are writing in regards to our inspection of the Portland City Hall, made with you on January 4, 1972. Our findings were that there was a noticable amount of Mono-Kote on the recessed areas of the East side of the building. There were only occasional spots on the rest of the building. We also noted spots of other materials at various locations of the building.

We suggest the use of a stiff brush to remove the Mono-Kote from the building surfaces. We believe most of this can be removed with a dry brush, but if needed it could be scrubbed with water.

Zonolite Mono-Kote is composed primarily of Gypsun and Vermiculite, but does not contain Lime.

Yours truly,

Robert S. Randall
W. R. Grace & Co.

RSR:pb

We hope the information given here will be helpful. It is based on our best knowledge, and we believe it to be true and accurate. Please read all statements, recommendations or suggestions herein in conjunction with our conditions of sale which apply to all goods supplied by us. We assume no responsibility for the use of these statements, recommendations or suggestions, nor do we intend them as a recommendation for any use which would infringe any patent or copyright.