PLAINTIFF'S EXHIBIT
CT-640

How to Connect

CERTAIN-TEED®
FLUID-TITE®
A-C Pipe
to other pipe, fittings and valves.

How To Connect FLUID-TITE® pipe with CERTA-SPACER® Band, To Other Pipe, Fittings And Valves

How To Connect F.T. Pipe ↓ To →		PIPE			FITTING & VALVE HUBS										
	FLUID-TITE CERTA-SPACER	FLUID-TITE	Johns-Manville & Flintkote	Simplex	Class "D" Poured	Mech. Joint	C. I. Pipe Slip Joint	A-C Common Groove Cl. 100	A-C Common Groove Cl. 150-200	Johns-Manville & Flintkote Cl. 100	Johns-Manville & Flintkote Cl. 150-200	FLUID-TITE (w/o CERTA-SPACER) Cl. 100	FLUID-TITE (w/CERTA-SPACER) Cl. 150-200	Roll-On Cl. 100	Roll-On Cl. 150-200
															
3"	CLASS 100 150/200	Direct Direct	Direct Direct	Direct Direct	PAD 2 FM	PAD 2 PAD 3	PAD 2 PAD 3	Direct No	PAD 5 Direct	Direct No	PAD 5 Direct	Direct No	PAD 5 Direct	Direct No	PAD 5 Direct
4"	CLASS 100 150/200	Direct Direct	Direct Direct	Direct Direct	PAD 2 FM	PAD 2 FM	PAD 2 FM	Direct No	PAD 5 Direct	Direct No	PAD 5 Direct	Direct No	PAD 5 Direct	Direct No	PAD 5 Direct
6"	CLASS 100 150/200	PAD 11* Direct	Direct Direct	PAD 11* Direct	FM FM	FM FM	FM FM	Direct No	Direct Direct	Direct No	Direct Direct	PAD 11* No	Direct Direct	PAD 11* No	Direct Direct
8"	CLASS 100 150/200	PAD 11* Direct	Direct Direct	PAD 11* Direct	PAD 2 FM	PAD 2 PAD 3	PAD 2 PAD 3	Direct No	Direct Direct	Direct No	Direct Direct	PAD 11* No	Direct Direct	PAD 11* No	Direct Direct
10"	CLASS 100 150/200	Direct Direct	PAD 11 Direct	Direct Direct	PAD 2 PAD 3	PAD 2 PAD 3	PAD 2 PAD 3	PAD 11 No	PAD 5 Direct	PAD 11 No	PAD 5 Direct	Direct No	PAD 5 Direct	Direct No	PAD 5 Direct
12"	CLASS 100 150/200	Direct Direct	PAD 11 Direct	Direct Direct	PAD 2 PAD 3	PAD 2 PAD 3	PAD 2 PAD 3	PAD 11 No	PAD 5 Direct	PAD 11 No	PAD 5 Direct	Direct No	PAD 5 Direct	Direct No	PAD 5 Direct
14"	CLASS 100 150/200	Direct Direct	Direct Direct	* Direct	PAD 2 PAD 3	PAD 2 PAD 3	PAD 2 PAD 3	Direct No	PAD 5 Direct	Direct No	PAD 5 Direct	Direct No	PAD 5 Direct	* No	PAD 5 Direct
16"	CLASS 100 150/200	Direct Direct	Direct Direct	* Direct	PAD 2 PAD 3	PAD 2 PAD 3	PAD 2 PAD 3	Direct No	PAD 5 Direct	Direct No	PAD 5 Direct	Direct No	PAD 5 Direct	* No	* Direct
18"	CLASS 100 150	Direct Direct	Direct † Direct †	Direct *	PAD 2 PAD 3	PAD 2 PAD 3	PAD 2 PAD 3	Direct † No	PAD 5 † Direct †	Direct † No	PAD 5 † Direct †	Direct No	PAD 5 Direct	Direct No	PAD 5 *
20"	CLASS 100 150	Direct Direct	Direct † Direct †	Direct *	PAD 2 PAD 3	PAD 2 PAD 3	PAD 2 PAD 3	Direct † No	PAD 5 † Direct †	Direct † No	PAD 5 † Direct †	Direct No	PAD 5 Direct	Direct No	* *
24"	CLASS 100 150	Direct Direct	Direct † Direct †	Direct *	PAD 2 PAD 3	PAD 2 PAD 3	PAD 2 PAD 3	Direct † No	PAD 5 † Direct †	Direct † No	PAD 5 † Direct †	Direct No	PAD 5 Direct	Direct No	* *
		Use old F.T. gasket in F.T. Cplg.	Use F.T. gasket or J-M gasket in J-M cplg. †Use special CPC Fittings Gasket	Use Simplex gasket in Simplex cplg. and F.M. pc.				Use F.T. or J-M gasket - remove CERTA-SPACER. †Use special CPC Fittings Gasket	Use F.T. or J-M gasket - remove CERTA-SPACER. †Use special CPC Fittings Gasket	Use F.T. or J-M gasket - remove CERTA-SPACER †Use special CPC Fittings Gasket	Use F.T. or J-M gasket - remove CERTA-SPACER. †Use special CPC Fittings Gasket	Use only Old F.T. gasket	Use only Old F.T. gasket	Use Simplex gasket w/Fully-Machined Piece.	Use Simplex gasket w/Fully-Machined Piece.

*1. All connections marked with an asterisk (*) are available on special order only.
2. Where "No" is indicated – CL 150 pipe should not be used in CL 100 fittings.

CTD030963

DISTRICT OFFICES

ATLANTA PIPE DISTRICT
Suite 254
3272 Peachtree Road, N. E.
Atlanta, Georgia 30305
Area Code 404 Telephone: 237-6331, 6332

CLEVELAND PIPE DISTRICT
Suite 110, One Commerce Park Square
23200 Chagrin Boulevard
(Beachwood)
Cleveland, Ohio 44122
Area Code 216 Telephone: 464-8060

DENVER PIPE DISTRICT
Suite 4G, Bankers Union Life Building
2401 E. Second Avenue
P. O. Box 6285
Denver, Colorado 80206
Area Code 303 Telephone: 388-5751

HOUSTON PIPE DISTRICT
Texas Gas Building Suite 275
2472 Bolsover Road
P. O. Box 25185
Houston, Texas 77005
Area Code 713 Telephone: JAckson 6-1Q37, 3717

LOS ANGELES PIPE DISTRICT
California Federal Savings Bldg., Suite 242
1695 Crescent Avenue
Anaheim, California 92801
Area Code 714 Telephone: 774-3900
From Los Angeles: 213-625-1915

Phoenix Branch Office
Suite 206
3625 No. 16th Street
Phoenix, Arizona 85016
Area Code 602 Telephone: 274-3642

PHILADELPHIA PIPE DISTRICT
Maple & Wissahickon Avenues
Ambler, Pennsylvania 19002
Area Code 215 Telephone: 646-9350

SAN FRANCISCO PIPE DISTRICT
Second Floor Marina Building
77 Jack London Square
Oakland, California 94607
Area Code 415 Telephone: 444-4022

ST. LOUIS PIPE DISTRICT
Suite 110
12015 Manchester Road
(Des Peres)
St. Louis, Missouri 63131
Area Code 314 Telephone: YOrktown 6-3010

PIPE FACTORIES AT AMBLER, PA.; ST. LOUIS, MO.; SANTA CLARA & RIVERSIDE, CALIF.; HILLSBORO, TEXAS

PIPE DIVISION

CERTAINTEED

CERTAIN-TEED PRODUCTS CORPORATION, Ambler, Pennsylvania 19002

Certain-teed, FLUID-TITE and CERTA-SPACER are registered trademarks of Certain-teed Products Corp., Ardmore, Pa.

CTD030964

FORM NO. AP120 (8-67)

Printed in U.S.A.