


Part A Response

Part A – to be submitted within 24 hours of the incident

Permit Number	BU5453IY
Name Of Operator	AGC Chemicals Europe Ltd
Location Of Installation	Hillhouse International, Thornton Cleveleys, Lancashire
Time and date of the detection	02/06/2023

(b) Notification requirements for the breach of a limit	
To be notified within 24 hours of detection unless otherwise specified below	
Emission point reference/source	W1 Discharge to River Wyre.
Parameter(s)	Suspended solids
Limit	150 mg/l (daily)
Measured value and uncertainty	252.80 mg/l
Date and time of monitoring (week ending)	02/06/2023
Measures taken, or intended to be taken to stop the emission	Investigation ongoing into likely cause and operation of the effluent treatment plant on 02/06/2023 and 03/06/2023. Suspended solid results: • 02/06/2023 = 252.80 mg/l • 03/06/2023 = 140.00 mg/l • 04/06/2023 = 52.80 mg/l

Name*	
Post	
Signature	
Date	05/06/2023

*authorised to sign on behalf of AGC Chemicals Europe