

WRITTEN BY: FSN
APPROVED BY: *SWP*
DATE: 10/8/84 *SWP*
1-179

SOP # 5603-010.SOP
(LOSS OF SGR #4)

OPERATOR'S NAME: _____ DATE _____

CHECK	ACTION STEPS (Capital letters) and Comments (Small letters)
_____	1. SHUT DOWN LP-EDC REACTOR AND LIGHT STILL, FLOAT THE CHLORINE VAPORIZER. a. The affected equipment in the EDC area are: 1. Light still condenser fans No. 1, 2, 3, 4, 5, and 6. _____ 2. PUT HEAVIES STILL ON TOTAL REFLUX.

SL 003688

CONFIDENTIAL:
Subject to Protective Order
of 14th Judicial District Court
No. 91-1145

WRITTEN BY: FSN
APPROVED BY: *19140*
DATE: *10/8/89* *revised*
1-17-91

SOP # 5603-011.SOP
(LOSS OF SGR #5)

OPERATOR'S NAME: _____ DATE _____

CHECK	ACTION STEPS (Capital letters) and Comments (Small letters)
_____	1. SHUT DOWN LP-EDC REACTOR AND THE CHLORINE VAPORIZER WILL HAVE TO BE SHUT DOWN. a. The affected equipment in the EDC area are: 1. Cooling tower pumps, fans and 175 PSIG steam desuperheater pumps are lost causing all units to be shut down. _____ 2. PUT LIGHTS AND HEAVIES STILL ON RECYCLE.

SL 003689

CONFIDENTIAL:
Subject to Protective Order
of 14th Judicial District Court
No. 91-1145