

Bulk Sample Analysis - Asbestos
Case 43106-2



Bell Laboratories

600 Mountain Avenue
Murray Hill, New Jersey 07974
Phone (201) 582-3000

PLAINTIFF'S EXHIBIT

SWB-113

February 29, 1980

Mr. Lucius Williams
Supervisor - Safety
AT&T Long Lines - Bedminster

The six bulk samples submitted to me from 440 Hamilton Avenue, White Plains, New York, have been analyzed for asbestos. The results are as follows:

<u>Sampling Location</u>	<u>Results</u>
100C Office	Major crystalline component is chrysotile asbestos
600C Stockroom	< 5% chrysotile
600C Boiler room	Major crystalline component is chrysotile asbestos
600C Shop	Major crystalline component is chrysotile asbestos
1100C EDAS	No indication of asbestos

All samples were evaluated using both x-ray diffraction and dispersion staining optical microscopy. X-ray diffraction showed no asbestos for the sample labeled stockroom. Dispersion staining optical microscopy revealed that this sample contained birefringent fibers with the optical and morphological characteristics of asbestos. This sample does contain asbestos, but less than 5%.

If you have any questions about the above analysis, please give me a call at (201) 582-7512.

MH-8635-DR-AM

David Rainer
Field Industrial Hygienist

Ref:1140

Copy to
See next page

CONFIDENTIAL

003594

Mr. L. Williams - 2

Copy to
G. W. Barnard - AT&T LL

R. L. Beach - AT&T

N. J. DeCapua

J. M. Degen ← THIS COPY F.R.H.

R. W. Stone, M.D.

W. J. Schreibeis

G. M. Wilkening

003595

CONFIDENTIAL