Monsanto

FROM (NAME & LOCATION) R. McEntire - WGK

DATE August 2, 1971

CC: R. Blowers
H. Horner
H. Campbell

SUBJECT

REFERENCE

TO : W. C. Engman
C. Buckley
J. Munoz
R. McCutchan
A. Rasmussen

COMPANY CONFIDENTIAL

The amount and type of PCB obtained in samples from the Aroclor Incinerator are reported below. Results are in parts per billion (ppb) unless otherwise noted.

Log No.	Date	Sample Description	PCB (ppb)	Type
88	7-1	Main sewer	10	1242
			4	1260
89	7-1	Basin	21	1242
			7	1260
90	7-4	Main Sewer	8	1242
			3	1260
91	7-4	Basin	1987	1242
			563	1260
92	7-8	Inc. Main	5	1242
			2	1260
93	7-11	Main	6	1242
94	7-11	Basin	39	1242
			13	1254
95	7-12	PCB Drum Eff	122	1242
96	7-12	PCBSVO Comp	32	1242
97	7-15	Inc. Overflow	580	1242
			193	1254
98	7-15	Inc. Main	1	1242
			1	1254
99	7-18	Inc Main	3	1248
			2	1260
100	7-18	Inc. Overflow	102	1242
			52	1254
101		H_2O Layer, MONX 819	275 ppm	1242
			154 ppm	1260
102		Floating Mat'l Aroclor sump	786 ppm	1242
			204 ppm	1260
103	7-25	Main	3	1242
			2	1260
104	7-25	Basin	125	1242
			55	1260
105	7-29	Basin	140	1242
			64	1260
106	7-29	Main	10	1242

DSW 295419

R.Mc Entire

IN-10 REV 11 65 dy