

Monsanto

FROM (NAME & LOCATION) B. J. Sanders - 3R16, Texas City

DATE : February 15, 1985 cc. G. W. Bostick
SUBJECT : First Quarter Safety & R. D. Coleman
Housekeeping Inspection T. Holder
REFERENCE : H. M. Lacy
J. McPhail
J. D. Richards
TO : V. Fields H. E. Robinson
J. T. Shipley SHAC

The First Quarter Safety and Housekeeping inspection for Oxo/Esters was conducted by the Inspection Team of George Bostick, Jack Richards, Tommy Holder, Harry Robinson and B. J. Sanders on 1/29/85.

The overall condition of the units was good even though a lot of S/D and Capital Projects work was in progress.

The following items need attention:

SAFETY

Oxo (48)

1. All fire extinguishers were marked 6/20/84. Need updating.
2. Yellow rubber hoses were used on steamerette hose reels - should be changed to the black Plicord Steel steam hose.
3. Grinder wheels in Maintenance Shop looked bad - need to be replaced.

Esters (56)

1. West side, third floor - steam hose connection needs replacing.
2. East side, second floor - ladder in use; not secured at top.

HOUSEKEEPING

Oxo (48)

1. Scattered materials in pipefitter's area.
2. Insulation material (loose) left over from earlier job.
3. Scaffold rack under fin fan needs to be straightened.
4. Area outside Maintenance shop needs cleaning up.

Esters (56)

General trash and clutter on all levels.

LAM001559

SC

000362

OTHER COMMENTS

1. Oxo/Esters does excellent job of locating trash containers throughout the area. Should be done all over T.C. plant.
2. Buckets were used to keep sampling areas clean.

Please respond in writing to Doug Barfoot or J. McPhail by March 4, 1985.


B. J. Sanders
for the Inspection Team

:bks