

Monthly Report for March 1-23-85
Effluent - New control valve has just been received. All
MSDGC samples except 1st in compliance.

Maintenance Problems - Completed South Ball Mill, except
for alignment. Factory man to come in and help with this.

Completed rotating magnetic electrical hook-ups.

Rebuild ACM mill.

Blender gear and shaft.

P+S dryer gas valve, pan, container etc.

Rebuild carbonate packer.

* 2 Boilers off line for inspection.

Job Order - Litharge weighting system - Parts ordered
will close out after bill is paid.

Oil & Gas Burner for Kiln - P.O. out for installation.

Purchase and Install Vertical Separator - Factory to send
missing electrical parts. Expect to complete early April.

Purchase IBM Micro Computer - J. Daley will order
ext. m. parts.

Rebuild Plant Air Compressor - Complete. Waiting for bills.

Pixer 26 - Job order has been rewritten. All quotes received.

New Slurry Dwyer - Samples sent. Results expected 3/26/84.

Cummins Slurry Air pump - Job order approval expected by 4/2/84.

J. Anderson completed 1 week vacation.

3/6 City of Chicago inspected all pressure vessels & boilers.
No Problems

C. Hykin & R. Johnson attended 1/2 day boiler water treatment seminar

R. Johnson