PLAINTIFF'S EXHIBIT
MON-1498

BL-10
MCC 950970

Monsanto

FROM (NAME & LOCATION) R. V. Sharp - Texas City, Purchasing, PER (Ext. 3211)

DATE January 28, 1985

SUBJECT 1st Quarter Safety & Housekeeping Inspection - Dept. 15/16

REFERENCE

TO : R. C. Willis SMD

cc SHAC
R. L. Hammond 0-12
G. A. Orum 2PD
J. T. Payne SS-18
Don Lonsford SS-9
D. D. Kos OA-9
R. A. Forsthoffer O-5

The 1st Quarter Safety & Housekeeping Inspection for Department 15/16 was conducted by the inspection team of R. L. Hammond, Don Lonsford, George Orum, Thurman Payne, and Rick Sharp on January 24. The department was given a "good" rating.

The following items were noted:

Safety

1. Excellent safety awareness by personnel.
2. Cover off electrical panel box in room on west side of control house.
3. Asphalt pad does not butt up to concrete drive next to 15S1-2 (tripping).
4. Fire extinguisher not inspected (Dept. 15 Stripper Area).
5. No safety chain on chain operator above 15P3-1.
6. Misuse of barricade tape south of 14D4.
7. Department had not had their 1985 kick-off session.
8. Ladder on top deck needs inspecting (Dept. 16).

Housekeeping

1. Cabinet door under bulletin board will not close. (control house)
2. Spare rugs need to be stored out of way. (control house)
3. Dept. 15/16 generally cluttered - needs pick-up.
4. N_2 sign on second deck of 15 Stripper.
5. Pump guard is loose on 15P2-2.
6. Broken eyebath sign east side of reactor - (15 Reaction Area)
7. Pigeon droppings - housekeeping/sanitation problem.
8. Removable insulation needs to be re-installed - (15E26).
9. TBC storage area used for brooms, maps, etc. - not for TBC storage.
10. Dept. 16 - hoses need racking.

Please respond to this inspection in writing to Ray Forsthoffer with a copy to Doug Barfoot by 3/4/85.

R. V. Sharp

RVS:wy