

Company: BFGOODRICH
Facility: HENRY

Page: 1

Session: 1 08-10-92

Revision: 0 10-26-92

System: 4 DRINKING WATER MANAGEMENT

Category: RECOMMENDATIONS

Dwg#:

QUESTION	A	REMARKS	RECOMMENDATIONS	BY	COMMENTS
2. THERE IS NO DOCUMENTATION THAT POTABLE WATER SYSTEM IS "LEAD FREE".	P		2. GENERATE DOCUMENTATION	DMK	2. 11/92: NO RECORDS ARE AVAILABLE TO DETERMINE IF "LEAD FREE" SOLDER AND FLUX HAS BEEN USED IN THE POTABLE WATER SYSTEM SINCE JUNE 19, 1986. A MONITORING PROCEDURE WILL BE ESTABLISHED FOR LEAD IN THE POTABLE WATER. NOTICE WILL BE POSTED FOR POSSIBLE LEAD CONTAMINATION IN DRINKING WATER. PROCEDURES WILL BE ESTABLISHED TO INSURE THAT "LEAD FREE" PIPES, SOLDER, AND FLUX ARE USED IN ALL FUTURE CHANGES TO THE DRINKING WATER SYSTEM. (DMK) 12/31/92.
					3. 2/93: PLANT HAS INITIATED A SAMPLING PROGRAM OF THE DISTRIBUTION SYSTEM AND IS CURRENTLY WAITING ON ANALYSES. NO NOTICE WILL BE POSTED UNTIL RESULTS HAVE BEEN OBTAINED. POLICY HAS BEEN WRITTEN TO PROHIBIT USE OF LEAD BEARING MATERIALS. ANALYSES WILL BE COMPLETED BY END OF FEBRUARY (DGF) 3/15/93.
					4. 5/93: SAMPLES ARE STILL IN PROCESS OF ANALYSES.
3. THERE WAS NO NOTIFICATION	P		3. POST NOTIFICATION	DMK	5. SEE ITEM 2 ABOVE.

NGC 12498

Company: BFGOODRICH
Facility: HENRY

Page: 2

Session: 1 08-10-92

Revision: 0 10-26-92

System: 4 DRINKING WATER MANAGEMENT

Category: RECOMMENDATIONS

Dwg#:

QUESTION	A	REMARKS	RECOMMENDATIONS	BY	COMMENTS
POSTED INFORMING PERSONNEL OF THE LEAD CONTENT IN THE DRINKING WATER.					
4. THE FACILITY HAS NOT DEMONSTRATED THAT THE WATER SYSTEM IS "LEAD FREE".	P		4. ADDRESS	DMK	6. SEE ITEM 2 ABOVE.
5. NON-POTABLE WATER SYSTEM IS NOT LABELED	C		5. LABEL	DMK	7. 11/92: A FLOW DIAGRAM OF THE POTABLE WATER SYSTEM WILL BE DEVELOPED BY 8/31/93. LABELING IS PRESENTLY BEING DONE TO PREVENT INADVERTENT CONSUMPTION OF NON-POTABLE WATER. (DMK) 8/31/93.
					8. 2/93: UNDERGROUND DRAWINGS HAVE BEEN COMPLETED; ABOVE GROUND DRAWINGS ARE PRESENTLY BEING WORKED ON. 1ST QUARTER AUDIT IN 1993 WILL INCLUDE REVIEW OF LABELING OF ALL NON-POTABLE WATER SYSTEMS.
					9. 5/93: ALL ABOVE GROUND DRINKING WATER LINE DRAWINGS HAVE BEEN COMPLETED. (COMPLETE) 5/93.

NGC 12499

Company: BFGOODRICH
 Facility: HENRY

Page: 3

Session: 1 08-10-92 Revision: 0 10-26-92
 System: 8 INDUSTRIAL HYGIENE MANAGEMENT
 Category: RECOMMENDATIONS

Dwg#:

QUESTION	A	REMARKS	RECOMMENDATIONS	BY	COMMENTS
3. THERE IS NOT A FORMAL HEAT STRESS PROGRAM.	C		3. ADDRESS	DEG	4. A PLANT SAFETY POLICY WILL BE ISSUED IDENTIFYING THE CURRENT TRAINING PROGRAM PLUS ADDITIONAL ADMINISTRATIVE AND EQUIPMENT CONTROLS. (DEG) 6/1/93.
			OK		5. 5/93: HEAT STRESS POLICY HAS BEEN DRAFTED AND WILL BE ISSUED IN JUNE AND ANNUAL AWARENESS HEAT STRESS TRAINING HAS BEEN COMPLETED FOR ALL PLANT PEOPLE DURING THE MAY SAFETY MEETINGS BY THE PLANT NURSE. (COMPLETE).

NGC 12500

Company: BFGOODRICH
Facility: HENRY

Page: 1

Session: 1 08-10-92

Revision: 0 10-26-92

System: 1 MANAGEMENT OF CHANGE

Category: RECOMMENDATIONS

Dwg#:

QUESTION	A	REMARKS	RECOMMENDATIONS	BY	COMMENTS
1. WWTP V-NOTCH WEIR WAS NOT CALIBRATED.	-		1. CALIBRATE	WJG	1. 11/92: THE V-NOTCH WEIR IS TO BE CHECKED IN ACCORDANCE WITH CHAPTER 6 OF THE EPS'S NPDES COMPLIANCE INSPECTION MANUAL. THIS WILL BE PERFORMED ON AN ANNUAL BASIS. A CALIBRATION CHECK WILL BE PERFORMED MONTHLY ON THE SECONDARY MEASURING DEVICES AND THE COMPUTER READOUT TO INSURE RELIABLE DATA. (SDJ/WJG) 12/1/92.
					2. 2/93: IN DECEMBER 1992, THE V-NOTCH WEIR WAS CALIBRATED. THE REFERENCE FOR INFORMATION ON CALIBRATING PRIMARY DEVICES IS THE NPDES COMPLIANCE INSPECTION MANUAL. THIS REFERENCE COMBINED WITH VERBAL INTERPRETATION PROVIDED BY KEN NEUMANN OF IEPA SUPPLIED ALL THE INFORMATION NECESSARY TO CONDUCT INSTANTANEOUS RATE CHECKS. SEE IOC 12/16/92 FROM SCOTT JOHNSON TO DAVE GIFFIN. COMPLETE
2. THE RADIATION SAFETY OFFICER HAS NOT BEEN TRAINED AND THE PERMIT HAS NOT BEEN UPDATED.	-		2. TRAIN OFFICER	DEG	3. 11/92: TRAINING HAS BEEN SCHEDULED FOR D.E. GIFFIN THE WEEK OF NOV 9TH TO

Company: BFGOODRICH
Facility: HENRY

Page: 2

Session: 1 08-10-92

Revision: 0 10-26-92

System: 1 MANAGEMENT OF CHANGE

Category: RECOMMENDATIONS

Dwg#:

QUESTION	A	REMARKS	RECOMMENDATIONS	BY	COMMENTS
					ATTEND THE TN RADIATION SCHOOL. ONCE CERTIFICATION HAS BEEN OBTAINED THE PLANT LICENSE WILL THEN BE AMENDED. (DEG)
					4. 2/93: DAVE GIFFIN WAS CERTIFIED BY TEXAS NUCLEAR ON 11/13/92 TO QUALIFY AS RADIATION OFFICER. THE ILLINOIS DEPARTMENT OF NUCLEAR SAFETY WAS INFORMED IN JANUARY (1/20/93) OF THIS TRAINING AND REQUESTED TO UPDATE THE PERMIT ACCORDINGLY. PROJECT COMPLETE.
					5. SDJ IS SCHEDULED FOR RADIATION TRAINING ON 7/18-23.
3. ENVIRONMENTAL PROJECT? (IMPACT) ASSESSMENTS WERE NOT COMPLETED.	-		3. PROVIDE ASSESSMENTS	DMK	6. 11/92: ALL EA'S, AR'S, AND GPO'S NOW HAVE ENVIRONMENTAL IMPACT ASSESSMENTS INCLUDED TO INSURE THAT ENVIRONMENTAL CONCERNS ARE ADDRESSED. COMPLETE 9/1/92
4. SCAFFOLDING WAS NOT INSPECTED QUARTERLY.	-		4. INSPECT	DEG	7. A PM MAINTENANCE WORK ORDER HAS BEEN GENERATED TO INSPECT THE SCAFFOLDING ON A QUARTERLY BASIS. THE PLANT PRESENTLY AND IN THE PAST INSPECTS PRIOR TO EACH USE OF THE SCAFFOLDING WHICH IS MORE

Company: BFGOODRICH
 Facility: HENRY

Page: 3

Session: 1 05-10-92 Revision: 0 10-26-92
 System: 1 MANAGEMENT OF CHANGE
 Category: RECOMMENDATIONS

Dwg#:

QUESTION	A	REMARKS	RECOMMENDATIONS	BY	COMMENTS
					FREQUENT THAN QUARTERLY. (COMPLETE) 10/30/92. 8. 2/93: DISCUSSED AND VERIFIED THE ABOVE WITH BDM ON 12/21/92 WHILE PREPARING FOR THE 4TH QUARTER SAFETY AUDIT.

Session: 1 08-10-92 Revision: 0 10-26-92
 System: 2 RESPONSIBLE CARE
 Category: RECOMMENDATIONS

Dwg#:

QUESTION	A	REMARKS	RECOMMENDATIONS	BY	COMMENTS
1. THERE WAS NOT SUFFICIENT DOCUMENTATION SUPPORTING STAGE VI PROGRESS OF THE RESPONSIBLE CARE POLLUTION PREVENTION CODE.			1. PROVIDE AN UP-TO-DATE QUALITATIVE EMISSIONS INVENTORY.	DMK	1. 11/92: THE POLLUTION PREVENTION CODE INVENTORY WILL BE UPDATED AND SUBMITTED. (DMK) 12/1/92.
			2. EVALUATE POTENTIAL IMPACT OF RELEASES ON THE ENVIRONMENT AND THE HEALTH AND SAFETY OF EMPLOYEES AND THE COMMUNITY.	DMK	2. 11/92: AN EVALUATION OF THE POTENTIAL RELEASE ON THE ENVIRONMENT AND THE SAFETY OF EMPLOYEES AND THE COMMUNITY HAS BEEN PERFORMED. THIS WAS PERFORMED IN CONNECTION WITH THE REQUIREMENTS OF THE ILLINOIS CHEMICAL SAFETY ACT. (COMPLETE) 1/1/92
			3. ESTABLISH PRIORITIES TAKING INTO CONCERN POTENTIAL HEALTH AND SAFETY IMPACTS.	DMK	3. 11/92: ONCE THE PRIORITIES HAVE BEEN ESTABLISHED, MEETINGS WITH PLANT EMPLOYEES AND THE PUBLIC WILL BE HELD TO RECEIVE THEIR RECOMMENDATIONS.

NGC 12503

Company: BFGOODRICH

Facility: HENRY

Page: 4

Session: 1 08-10-92

Revision: 0 10-26-92

System: 2 RESPONSIBLE CARE

Category: RECOMMENDATIONS

Dwg#:

QUESTION	A	REMARKS	RECOMMENDATIONS	BY	COMMENTS
					8/1/93
					4. 2/93: THE ABOVE
					ACTIVITY OF MEETING
					WITH THE EMPLOYEES
					AND PUBLIC IS DONE
					ON AN ANNUAL BASIS
					AND IS NORMALLY
					PLANNED FOR LATE
					SUMMER. PROJECT
					COMPLETE.
			4. PROVIDE	DMK	5. UPDATE POLLUTION
			MEASUREMENT OF ON		PREVENTION CODE
			GOING REDUCTION		INVENTORY ANNUALLY.
			PROGRESS.		(DMK) ANNUALLY.
					6. CHANGE ABOVE
					NAMES TO SDJ FOR
					GEON AND DGP FOR
					SP&C.

Session: 1 08-10-92

Revision: 0 10-26-92

System: 3 SOLID AND HAZARDOUS WASTE MANAGEMENT

Category: RECOMMENDATIONS

Dwg#:

QUESTION	A	REMARKS	RECOMMENDATIONS	BY	COMMENTS
1. HAZARD WASTE MANAGEMENT WAS DEFICIENT IN SEVERAL AREAS.	-		1. ALL SEVEN SATELLITE ACCUMULATION AREAS WERE NOT INSPECTED ON A WEEKLY BASIS. ADDRESS.	DMK	1. 11/92: THE PLANT WASTE HANDLING PROCEDURES HAVE BEEN THOROUGHLY REVIEWED WITH RESPECT TO RCRA GUIDELINES, BFG POLICY AND GMP SINCE THE AUDIT AND CORRECTED ACCORDINGLY. ALL SATELLITE ACCUMULATION AREAS ARE NOW INSPECTED WEEKLY BY AN S&E OPERATOR, THE PRODUCTION OPERATORS ARE RESPONSIBLE FOR MAINTAINING THE SATELLITE ACCUMULATION DRUMS

NGC 12504

Company: BFGOODRICH

Facility: HENRY

Page: 5

Session: 1 08-10-92

Revision: 0 10-26-92

System: 3 SOLID AND HAZARDOUS WASTE MANAGEMENT

Category: RECOMMENDATIONS

Dwg#:

QUESTION	A	REMARKS	RECOMMENDATIONS	BY	COMMENTS
					IN ACCORDANCE WITH RCRA REGULATIONS. (COMPLETE) 9/1/92.
		2. DRUMS OF HAZARDOUS WASTE ON THE FLAMMABLE STORAGE PAD WERE NOT LABELED WITH THE WORDS "HAZARDOUS WASTE" OR THE ACCUMULATION DATE. ADDRESS.	DMK		2. PROCEDURES HAVE BEEN ESTABLISHED AND TRAINING GIVEN TO INSURE THAT NO HAZARDOUS WASTE IS STORED ON THE FLAMMABLE STORAGE PAD. THE S&E OPERATORS ARE RESPONSIBLE FOR RECEIVING ALL HAZARDOUS WASTE FROM PRODUCTION'S OPERATIONS. (COMPLETE) 9/1/92.
		3. CONTAMINATED MATERIAL, CONTAINED IN DRUMS LOCATED ON THE FLAMMABLE STORAGE PAD, HAS NOT BEEN DETERMINED TO BE A HAZARDOUS OR NONHAZARDOUS WASTE. RESOLVE.	DMK		3. ALL DRUMS THAT WERE HAZARDOUS OR SPECIAL WASTE WERE LABELED ACCORDINGLY AND MOVED TO PROPER STORAGE LOCATION. (COMPLETE) 9/1/92
		4. ONE BULK CONTAINER OF WASTE WAS IDENTIFIED AS CONTAINING A HAZARDOUS WASTE BUT WAS NOT LABELED AND DID NOT HAVE AN ACCUMULATION DATE. LABEL.	DMK		4. THE BOX IN QUESTION WAS LABELED THE SAME DAY AND WAS SHIPPED 8/21/92. THERE ARE INDICATIONS THAT THE MATERIAL PRESENTLY BEING DISPOSED OF IN THE CONTAINER IS NO LONGER HAZARDOUS SINCE THE MATERIAL WHICH MADE IT HAZARDOUS IS NOW SOLD AS OFF-GRADE PRODUCT. WE ARE IN THE PROCESS OF CHARACTERIZING THE WASTE. (DMK, SDJ)

NGC 12505

Company: BFGOODRICH
Facility: HENRY

Page: 6

Session: 1 08-10-92

Revision: 0 10-26-92

System: 3 SOLID AND HAZARDOUS WASTE MANAGEMENT

Category: RECOMMENDATIONS

Dwg#:

QUESTION	A	REMARKS	RECOMMENDATIONS	BY	COMMENTS
					12/1/93.
					5. 2/93: PROJECT COMPLETE.
			5. A DRUM OF HAZARDOUS WASTE IN THE LABORATORY SATELLITE ACCUMULATION AREA WAS NOT CLOSED WITH A LID. REMEDY.	DMK	6. PROCEDURES AND CHECKS ARE IN PLACE TO INSURE THAT LIDS ARE CLOSED AT ALL TIMES ON SATELLITE ACCUMULATION DRUMS EXCEPT WHEN BEING FILLED. (COMPLETE) 9/1/92.
			6. POTENTIALLY REUSABLE MATERIALS WERE STORED IN DRUMS; LABELED "SCRAP" AND "WASTE" AT THE FLAMMABLE STORAGE PAD. CORRECT.	DMK	7. ALL DRUMS HAVE BEEN LABELED PROPERLY ACCORDING TO THEIR CONTENTS AND MOVED TO PROPER STORAGE AREAS. (COMPLETE) 8/21/92.
2. WASTE OIL WAS SENT TO A FACILITY WHICH WAS NOT AUTHORIZED BY BFG.	-	THE FACILITY DISPOSED OF WASTE OIL AT AN OIL RECYCLING FACILITY THAT WAS NOT INCLUDED ON THE FACILITY'S LIST OF APPROVED TREATMENT, STORAGE AND DISPOSAL (TSD) FACILITIES.	7. CORRECT	DMK	8. 11/92: PERMISSION WAS RECEIVED FROM JIM LEWIS BY PHONE PRIOR TO SHIPPING THE USED OIL TO SAFETY KLEEN. THE DATE PERMISSION WAS GRANTED WAS NOT DOCUMENTED. (COMPLETE) 10/27/92.

Session: 1 08-10-92

Revision: 0 10-26-92

System: 4 DRINKING WATER MANAGEMENT

Category: RECOMMENDATIONS

Dwg#:

QUESTION	A	REMARKS	RECOMMENDATIONS	BY	COMMENTS
1. SAMPLING RESULTS WERE NOT REPORTED TO THE STATE WITHIN 30 DAYS.	-		1. RESOLVE	DMK	1. 11/92: VOC DATA WAS SUBMITTED TO THE PUBLIC HEALTH DEPARTMENT. (COMPLETE) 10/20/89.
2. THERE IS NO DOCUMENTATION THAT POTABLE WATER SYSTEM IS	P		2. GENERATE DOCUMENTATION	DMK	2. 11/92: NO RECORDS ARE AVAILABLE TO

NGC 12506

Company: BFGOODRICH

Facility: HENRY

Page: 7

Session: 1 08-10-92

Revision: 0 10-26-92

System: 4 DRINKING WATER MANAGEMENT

Category: RECOMMENDATIONS

Dwg#:

QUESTION	A	REMARKS	RECOMMENDATIONS	BY	COMMENTS
"LEAD FREE".					DETERMINE IF "LEAD FREE" SOLDER AND FLUX HAS BEEN USED IN THE POTABLE WATER SYSTEM SINCE JUNE 19, 1986. A MONITORING PROCEDURE WILL BE ESTABLISHED FOR LEAD IN THE POTABLE WATER. NOTICE WILL BE POSTED FOR POSSIBLE LEAD CONTAMINATION IN DRINKING WATER. PROCEDURES WILL BE ESTABLISHED TO INSURE THAT "LEAD FREE" PIPES, SOLDER, AND FLUX ARE USED IN ALL FUTURE CHANGES TO THE DRINKING WATER SYSTEM. (DMK) 12/31/92.
					3. 2/93: PLANT HAS INITIATED A SAMPLING PROGRAM OF THE DISTRIBUTION SYSTEM AND IS CURRENTLY WAITING ON ANALYSES. NO NOTICE WILL BE POSTED UNTIL RESULTS HAVE BEEN OBTAINED. POLICY HAS BEEN WRITTEN TO PROHIBIT USE OF LEAD BEARING MATERIALS. ANALYSES WILL BE COMPLETED BY END OF FEBRUARY (DGF) 3/15/93.
3. THERE WAS NO NOTIFICATION POSTED INFORMING PERSONNEL OF THE LEAD CONTENT IN THE	P		3. POST NOTIFICATION	DMK	5. SEE ITEM 2 ABOVE.

NGC 12507

Company: BFGOODRICH

Facility: HENRY

Page: 8

Session: 1 06-10-92

Revision: 0 10-26-92

System: 4 DRINKING WATER MANAGEMENT

Category: RECOMMENDATIONS

Dwg#:

QUESTION	A	REMARKS	RECOMMENDATIONS	BY	COMMENTS
DRINKING WATER.					
4. THE FACILITY HAS NOT DEMONSTRATED THAT THE WATER SYSTEM IS "LEAD FREE".	P		4. ADDRESS	DMK	6. SEE ITEM 2 ABOVE.
5. NON-POTABLE WATER SYSTEM IS NOT LABELED	C		5. LABEL	DMK	7. 11/92: A FLOW DIAGRAM OF THE POTABLE WATER SYSTEM WILL BE DEVELOPED BY 8/31/93. LABELING IS PRESENTLY BEING DONE TO PREVENT INADVERTENT CONSUMPTION OF NON-POTABLE WATER. (DMK) 8/31/93.
					8. 2/93: UNDERGROUND DRAWINGS HAVE BEEN COMPLETED; ABOVE GROUND DRAWINGS ARE PRESENTLY BEING WORKED ON. 1ST QUARTER AUDIT IN 1993 WILL INCLUDE REVIEW OF LABELING OF ALL NON-POTABLE WATER SYSTEMS.
					9. 5/93: ALL ABOVE GROUND DRINKING WATER LINE DRAWINGS HAVE BEEN COMPLETED. (COMPLETE) 5/93.

Session: 1 06-10-92

Revision: 0 10-26-92

System: 5 AIR QUALITY MANAGEMENT

Category: RECOMMENDATIONS

Dwg#:

QUESTION	A	REMARKS	RECOMMENDATIONS	BY	COMMENTS
1. THERE ARE NO WRITTEN PROCEDURES FOR ENSURING AIR POLLUTION SOURCE COMPLIANCE.	-		1. ISSUE PROCEDURES	DMK	1. 11/92: ALL EXISTING WRITTEN PROCEDURES WILL BE CHECKED TO DETERMINE IF PROCEDURES ARE IN PLACE TO INSURE

Company: BFGOODRICH

Facility: HENRY

Page: 9

Session: 1 08-10-92

Revision: 0 10-26-92

System: 5 AIR QUALITY MANAGEMENT

Category: RECOMMENDATIONS

Dwg#:

QUESTION	A	REMARKS	RECOMMENDATIONS	BY	COMMENTS
					PROPER OPERATION OF THE POLLUTION CONTROL DEVICES. ALL AIR POLLUTION CONTROL DEVICES THAT ARE NOT INCLUDED IN WRITTEN PROCEDURES WILL HAVE A PROCEDURE ESTABLISHED TO INSURE PROPER OPERATION. RECORDS OF CONTROL DEVICE MAINTENANCE (WHERE APPLICABLE) WILL BE MAINTAINED. (MEG,JDK) 8/31/93 2. 2/93: ALL PERMITTED SOURCES HAVE BEEN IDENTIFIED AND A LIST OF CONTROL DEVICES MADE FROM THIS. ALL DEVICES HAVE BEEN IDENTIFIED IN THE MAINTENANCE COMPUTER SYSTEM TO INSURE THAT MAINTENANCE RECORDS ARE MAINTAINED. OPERATING PROCEDURES FOR THE CONTROL DEVICES ARE PART OF THE NORMAL PROCESS OPERATING PROCEDURE AND ARE BEING FOLLOWED. COMPLETE

NGC 12509

Company: BFGOODRICH

Facility: HENRY

Page: 10

Session: 1 08-10-92

Revision: 0 10-26-92

System: 6 COMMUNITY-RIGHT-TO-KNOW

Category: RECOMMENDATIONS

Dwg#:

QUESTION	A	REMARKS	RECOMMENDATIONS	BY	COMMENTS
1. THERE IS NO DOCUMENTATION THAT SARA 302 NOTIFICATION WAS SUBMITTED.	-		1. GENERATE DOCUMENTATION	DME	1. 11/92: A COPY OF THE SARA 302 NOTIFICATION LETTER SUBMITTED TO THE SERC IS ON FILE IN THE ENVIRONMENTAL OFFICE. (COMPLETE) 5/6/87.

Session: 1 08-10-92

Revision: 0 10-26-92

System: 7 HAZARD COMMUNICATION

Category: RECOMMENDATIONS

Dwg#:

QUESTION	A	REMARKS	RECOMMENDATIONS	BY	COMMENTS
1. BOXES OF PVC DISPERSION STRAININGS HAD TWO CONFLICTING HAZARD LABELS.	-		1. CORRECT	DEG	1. THE GEON WAREHOUSE WILL BE AUDITED FOR NONCOMPLIANCE AND THE PACKAGING LABELING WILL BE CORRECTED. (MEG) 12/31/92. 2. 2/93: PACKAGING LABELING HAS BEEN CORRECTED. COMPLETE

Session: 1 08-10-92

Revision: 0 10-26-92

System: 8 INDUSTRIAL HYGIENE MANAGEMENT

Category: RECOMMENDATIONS

Dwg#:

QUESTION	A	REMARKS	RECOMMENDATIONS	BY	COMMENTS
1. APPROXIMATELY FIVE (5) PERCENT OF TWA EXPOSURE MONITORING RESULTS FOR VINYL CHLORIDE EXCEEDED THE PEL WITHOUT RESPIRATORY PROTECTION.	-		1. MAINTAIN FOLLOWUP PROGRAM	DEG	1. PLANT CURRENTLY CONDUCTS BOARD OF INQUIRES WHENEVER AN INDIVIDUAL EXCEEDS A PEL WITHOUT RESPIRATORY EQUIPMENT. ACTION ITEMS DESIGNED TO ELIMINATE THE OVER-EXPOSURE ARE GENERATED AND FOLLOWED UP OCCURS AS PART OF OUR BOI PROGRAM. (CONTINUING)

Company: BFGOODRICH
 Facility: HENRY

Page: 11

Session: 1 08-10-92

Revision: 0 10-26-92

System: 8 INDUSTRIAL HYGIENE MANAGEMENT

Category: RECOMMENDATIONS

Dwg#:

QUESTION	A	REMARKS	RECOMMENDATIONS	BY	COMMENTS
					& COMPLETE)
2. PROCEDURE FOR "YELLOW LIGHT" ALARM DOES NOT ENSURE EXPOSURES WILL BE LESS THAN THE PEL.	-		2. CORRECT	DEG	2. ALTERNATIVES ARE BEING INVESTIGATED TO INSURE THAT PERSONNEL ARE NOT EXPOSED TO GREATER THAN THE PEL WITHOUT USE OF A RESPIRATOR WHILE PERFORMING WORK UNDER A YELLOW LIGHT. (MEG/RDM) 3/1/93.
					3. 2/93: ALARM LIGHTS HAVE BEEN MODIFIED TO GO TO RED LIGHT CONDITION AFTER HAVING TWO CONTINUOUS YELLOW LIGHTS. RED LIGHT CONDITION REQUIRES WEARING OF FRESH AIR MASK. COMPLETE
3. THERE IS NOT A FORMAL HEAT STRESS PROGRAM.	C		3. ADDRESS	DEG	4. A PLANT SAFETY POLICY WILL BE ISSUED IDENTIFYING THE CURRENT TRAINING PROGRAM PLUS ADDITIONAL ADMINISTRATIVE AND EQUIPMENT CONTROLS. (DEG) 6/1/93.
					5. 5/93: HEAT STRESS POLICY HAS BEEN DRAFTED AND WILL BE ISSUED IN JUNE AND ANNUAL AWARENESS HEAT STRESS TRAINING HAS BEEN COMPLETED FOR ALL PLANT PEOPLE DURING THE MAY SAFETY MEETINGS BY THE PLANT NURSE. (COMPLETE).

Company: BFGOODRICH

Facility: HENRY

Page: 12

Session: 1 08-10-92

Revision: 0 10-26-92

System: 8 INDUSTRIAL HYGIENE MANAGEMENT

Category: RECOMMENDATIONS

Dwg#:

QUESTION	A	REMARKS	RECOMMENDATIONS	BY	COMMENTS
4. DOCUMENTATION FOR INVESTIGATING STS'S WAS DISORGANIZED AND INCOMPLETE	-		4. ADDRESS	DEC	6. A PLANT PROCEDURE WILL BE ISSUED IDENTIFYING THE ADMINISTRATION OF STS'S AND HEARING RECORDABILITY. THE PROCEDURE WILL INCLUDE THE DOCUMENTATION REQUIREMENTS. (DEC) 12/31/92.
					7. 2/93: DOCUMENTATION SYSTEM HAS BEEN ESTABLISHED ALONG WITH PROCEDURE. COMPLETE.

Session: 1 08-10-92

Revision: 0 11-04-92

System: 9 INDUSTRIAL SAFETY

Category: RECOMMENDATIONS

Dwg#:

QUESTION	A	REMARKS	RECOMMENDATIONS	BY	COMMENTS
1. SEVERAL EXIT SIGNS WERE NOT ILLUMINATED.	-		1. COMPLETE EXIT SIGN PROGRAM	DEC	1. THE PRESENT PROGRAM TO REPLACE EXISTING EXIT SIGNS THAT DO NOT MEET THE ILLUMINATION REQUIREMENTS WILL BE COMPLETED ALONG WITH THE AUDITING OF EXIT SIGNS THAT ARE LOCATED ON THE DOORS. SIGNS THAT ARE NOT VISIBLE WHEN THE DOOR IS OPEN WILL BE RELOCATED. (DEC) 12/31/92.
					2. 2/93: ALL DOORS IN THE PLANT HAVE BEEN RE-AUDITED FOR PROPER EXIT SIGN ILLUMINATION AND PROPER LOCATION DURING THE FOURTH QUARTER SAFETY

NGC 12512

Company: BFGOODRICH

Facility: HENRY

Page: 13

Session: 1 08-10-92

Revision: 0 11-04-92

System: 9 INDUSTRIAL SAFETY

Category: RECOMMENDATIONS

Dwg#:

QUESTION	A	REMARKS	RECOMMENDATIONS	BY	COMMENTS
					AUDIT AND ADDRESSED. COMPLETE
2. PALLETS IN PVC SACK AREA WERE BOWED.	-		2. ADDRESS	DEG	3. THE WOODEN PALLETS THAT WERE BOWING IN THIS APPLICATION HAVE BEEN TAKEN OUT OF SERVICE. IN ADDITION THE SUPER SACKS ARE BEING STACKED IN A MANNER SO THAT INDIVIDUALS ARE NOT PHYSICALLY EXPOSED TO A SECOND LEVEL OF BAGS. (COMPLETE) 8/14/92.
3. EYEWASH STATIONS WERE UNCLEAN.	-		3. ADDRESS	DEG	4. EACH PRODUCTION AREA WILL BE RESPONSIBLE FOR THE CLEANING OF EYEBATHS. LONG RANGE THE PORCELEIN EYEBATHS WILL BE CHANGED OUT WITH MORE MODERN NON-BOWL DESIGNS. (MEG/JDK) 12/31/92.
					5. 2/93: EACH AREA HAS RESPONSIBILITY OF EYEBATHS AND QUARTERLY AUDITS INCLUDE CHECKING THEM FOR CLEANLINESS. COMPLETE

NGC 12513