


FIG. 1. CHART FOR ESTIMATING DOLLAR VALUE OF HEAT LOSS FROM BARE IRON PIPES. (SEE TABLE 1)[a]

[a]This chart is based on 100 linear feet per 1000 hours. For fractions or multiples of these factors, multiply by proper percentage.

monetary value of the loss of heat given in Table 1 may be obtained by means of Fig. 1 for various heating system efficiencies, temperature differences, and calorific values and costs of coal. To solve a problem, select the proper heat loss coefficient from Table 1 and locate this value on the upper left hand margin of the chart. Then draw lines in the order indicated by the dotted lines, the dollar value of the heat loss per 100 linear feet of pipe per 1000 hours being given on the upper right hand scale. In using this chart, the cost of coal should also include the labor for handling it, boiler room expense, etc.

TABLE 2. HEAT LOSS FROM HORIZONTAL BARE BRIGHT COPPER PIPE

Expressed in Btu per hour per linear foot per degree Fahrenheit between the pipe and surrounding still air at 70 F

Nominal Pipe Size (Inches)	Hot Water (Type K Copper Tube)				Steam (Standard Pipe Size Pipe)		
	120 F	150 F	180 F	210 F	227.1 F (5 Lb)	297.7 F (50 Lb)	337.9 F (100 Lb)
	Temperature Difference						
	50 F	80 F	110 F	140 F	157.1 F	227.7 F	267.9 F
½	0.180	0.210	0.218	0.229	0.299	0.338	0.355
¾	0.236	0.275	0.291	0.307	0.357	0.408	0.418
1	0.290	0.338	0.354	0.373	0.440	0.492	0.523
1¼	0.340	0.400	0.418	0.443	0.510	0.571	0.598
1½	0.390	0.463	0.473	0.507	0.598	0.671	0.710
2	0.490	0.525	0.600	0.628	0.719	0.813	0.851
2½	0.580	0.675	0.709	0.750	0.840	0.953	1.008
3	0.680	0.788	0.848	0.871	0.987	1.107	1.165
3½	0.760	0.888	0.946	1.000	1.114	1.235	1.307
4	0.940	1.000	1.045	1.107	1.210	1.361	1.456
4½	.....	.....	.....	.....	1.335	1.495	1.488
5	1.020	1.200	1.255	1.320	1.465	1.670	1.755
6	1.160	1.375	1.410	1.500	1.685	1.890	1.942
8	1.460	1.725	1.820	1.890	2.100	2.373	2.510

TABLE 3. HEAT LOSS FROM BRIGHT COPPER PIPE GIVEN ONE THIN COAT OF CLEAR LACQUER

Expressed in Btu per hour per linear foot per degree Fahrenheit between the pipe and surrounding still air at 70 F

Nominal Pipe Size (Inches)	Hot Water (Type K Copper Tube)				Steam (Standard Pipe Size Pipe)		
	120 F	150 F	180 F	210 F	227.1 F (5 Lb)	297.7 F (50 Lb)	337.9 F (100 Lb)
	Temperature Difference						
	50 F	80 F	110 F	140 F	157.1 F	227.7 F	267.9 F
½	0.240	0.265	0.282	0.307	0.401	0.461	0.478
¾	0.320	0.356	0.373	0.414	0.477	0.571	0.578
1	0.390	0.437	0.463	0.507	0.598	0.681	0.710
1¼	0.470	0.537	0.554	0.614	0.700	0.812	0.840
1½	0.540	0.612	0.645	0.714	1.208	0.966	0.990
2	0.690	0.762	0.818	0.892	1.005	1.164	1.201
2½	0.840	0.937	0.991	1.085	1.178	1.361	1.420
3	0.960	1.025	1.135	1.270	1.400	1.625	1.700
3½	1.100	1.250	1.318	1.442	1.580	1.845	1.905
4	1.241	1.400	1.480	1.556	1.750	2.040	2.130
4½	.....	.....	.....	.....	1.910	2.240	2.350
5	1.480	1.685	1.790	1.965	2.130	2.415	2.610
6	1.700	1.936	2.052	2.272	2.450	2.810	2.990
8	2.200	2.500	2.630	2.854	3.120	3.425	3.730

Heat losses from horizontal copper tubes and pipes with bright, bright lacquered and tarnished surfaces are given in Tables 2, 3 and 4[1].

In order to determine heat losses per linear foot of pipe from known losses per square foot, it is necessary to know the area in square feet per

[1]Heat Loss from Copper Piping, by R. H. Heilman (*Heating Piping and Air Conditioning*, September, 1933, p. 458).