

TABLE 14. TOTAL EQUIVALENT TEMPERATURE DIFFERENTIALS FOR CALCULATING HEAT GAIN THROUGH SUNLIT AND SHADED ROOFS

DESCRIPTION OF ROOF CONSTRUCTION ^a	SUN TIME									
	A.M.					P.M.				
	8	10	12	2	4	6	8	10	12	
LIGHT CONSTRUCTION ROOFS—EXPOSED TO SUN										
1" Wood ^b or 1" Wood ^b + 1" or 2" Insulation	12	38	54	62	50	26	10	4	0	
MEDIUM CONSTRUCTION ROOFS—EXPOSED TO SUN										
2" Concrete or 2" Concrete + 1" or 2" Insulation or 2" Wood ^b	6	30	48	58	50	32	14	6	2	
2" Gypsum or 2" Gypsum + 1" Insulation 1" Wood ^b or 2" Wood ^b or + 4" Rock Wool 2" Concrete or in Furred Ceiling 2" Gypsum	0	20	40	52	54	42	20	10	6	
4" Concrete or 4" Concrete with 2" Insulation	0	20	38	50	52	40	22	12	6	
HEAVY CONSTRUCTION ROOFS—EXPOSED TO SUN										
6" Concrete 6" Concrete + 2" Insulation	4	6	24	38	46	44	32	18	12	
	6	6	20	34	42	44	34	20	14	
ROOFS COVERED WITH WATER—EXPOSED TO SUN										
Light Construction Roof with 1" Water	0	4	16	22	18	14	10	2	0	
Heavy Construction Roof with 1" Water	-2	-2	-4	10	14	16	14	10	6	
Any Roof with 6" Water	-2	0	0	6	10	10	8	4	0	
ROOFS WITH ROOF SPRAYS—EXPOSED TO SUN										
Light Construction	0	4	12	18	16	14	10	2	0	
Heavy Construction	-2	-2	2	8	12	14	12	10	6	
ROOFS IN SHADE										
Light Construction	-4	0	6	12	14	12	8	2	0	
Medium Construction	-4	-2	2	8	12	12	10	6	2	
Heavy Construction	-2	-2	0	4	8	10	10	8	4	

^a Includes 1 in. felt roofing with or without slag. May also be used for shingle roof. ^b Nominal thickness of the wood.

NOTES FOR TABLE 14

Explanation: $\left[\frac{\text{Total heat transmission from solar radiation and temperature difference between outside and room air, Btu per (hr) (sq ft) of roof area}}{\text{Equivalent temperature differential from above table}} \right] \times \left[\frac{\text{Heat transmission coefficient for summer Btu per (hr) (sq ft) F deg}}{\text{Heat transmission coefficient for summer Btu per (hr) (sq ft) F deg}} \right]$

1. *Source.* Calculated by Mackey and Wright method (see reference list) and adjusted after studying ASHVE original test data. Estimated for July in 40 deg north latitude. (For Sol-air temperatures used in calculations see Table 13.) For typical design day where the maximum outdoor temperature is 95 F and minimum temperature at night is approximately 75 F (daily range of temperature, 20 F) mean 24 hr temperature 84 F for a room temperature of 80 F. All roofs have been assumed a dark color which absorbs 90 per cent of solar radiation, and reflects only 10 per cent.

2. *Application.* These values may be used for all normal air conditioning estimates; usually without correction, in latitude 0 deg to 50 deg north or south when the load is calculated for the hottest weather. Note 5 explains how to adjust the temperature differential for other room and outdoor temperatures.

3. *Peaked Roofs.* If the roof is peaked and the heat gain is primarily due to solar radiation, use for the area of the roof, the area projected on a horizontal plane.

4. *Attics.* If the ceiling is insulated and if a fan is used in the attic for positive ventilation, the total temperature differential for a roof exposed to the sun may be decreased 25 per cent.

5. *Corrections.* For temperature difference when outdoor maximum design temperature minus room is different from 15 deg. If the outdoor design temperature minus room temperature is different from the base of 15 deg, correct as follows: When the difference is greater (or less) than 15 deg add the excess to (or subtract the deficiency from) the above differentials.

For outdoor daily range of temperature other than 20 deg. If the daily range of temperature is less than 20 deg, add 1 deg for every 2 deg lower daily range; if the daily range is greater than 20 deg, subtract 1 deg for every 2 deg higher daily range. For example, the daily range in Miami, Florida is 12 deg or 8 deg less than 20 deg, therefore, the correction is + 4 deg at all hours of the day.

Light Colors. Credit should not be taken for light colored roofs except where the permanence of the light color is established by experience, as in rural areas or where there is little smoke. When the exterior surface of roof exposed to the sun is a light color, such as white or aluminum (which absorb approximately 50 per cent and reflect 50 per cent of the solar radiation) add to the temperature differential for roof in shade 55 per cent of the difference between the roof in sun and roof in shade. When the roof exposed to the sun is a medium color such as light grey, blue or green, or bright red, add 80 per cent of this difference.

For solar transmission in latitudes other than 40 deg north, and in other months. The table values of temperature differentials will be approximately correct for a roof in the following months:

NORTH LATITUDE		SOUTH LATITUDE	
Latitude (deg)	Months	Latitude (deg)	Months
0	All Months	0	All Months
10	All Months	10	All Months
20	All Months except Nov, Dec, Jan	20	All Months except May, June, July
30	Mar, Apr, May, June, July, Aug, Sept	30	Sept, Oct, Nov, Dec, Jan, Feb, Mar
40	April, May, June, July, Aug	40	Oct, Nov, Dec, Jan, Feb
50	May, June, July	50	Nov, Dec, Jan

For other months, the total temperature differential (t_z) may be approximated by the use of the following formula:

$$t_z = t_s + \frac{I_z}{I_y} (t_r - t_s)$$

where t_s = temperature differential for the same wall in shade for desired time of day; obtained from Table 14.

I_y = maximum solar transmission through glass, Btu per (hr) (sq ft) for flat skylight in July, 40 deg north latitude (Note: this is maximum value irrespective of time).

I_z = same as I_y except use the maximum value for flat skylight, for month, and latitude desired for t_z .

t_r = temperature differential for particular roof exposed to sun for the desired time of day from Table 14.

(Note that this makes adjustment only for solar radiation and that there may be additional correction for outdoor temperature.)

on 6.0 and 1.65, it is recommended that the overall coefficient U , for walls, be taken directly from the tables in Chapter 9 in which they are based on an outside film conductance of 6.0, corresponding to a 15 mph wind velocity.

Advantages of Equivalent Temperature Differential Method

1. The total sensible heat flow is obtained by multiplying the overall heat transmission coefficient, U , and the equivalent temperature differential indicated in Tables 14 and 15.

2. The temperature differentials listed for a few representative types of construction may be used on all classes of walls and roofs, even though the overall heat transmission coefficient is different, provided the structure has thermal and physical properties similar to one of those listed in Tables 14 and 15.

3. Adjustments can be made, according to instructions given in the footnotes for room and outdoor conditions different from those on which the tables are based.

Examples of Use of Equivalent Temperature Tables

Example 6. Given: A roof is constructed of 6 in. of stone concrete with 2 in. of insulating board and tar felt roofing $\frac{1}{2}$ in. thick, and is exposed to the sun. The location is the central part of the United States. Find the rate of heat flow into building